Claymore Design & Build Ltd

Winterbourne
Bonchurch Village Rd
Ventnor IOW PO38 1RQ

mb: 0773 9891981
tel: 01983 508795
email: scottmacgregor28@hotmail.com

TEST PITS

21 February 2016

44 Downshire Hill, London NW3 1NU

drawing ref: 53021-24

date	Loc.	Pit depth below Existing FFL	adjacent footing	adjacent footing depth	adjacent footing width (approx)	Pit Base Substrate	Est bearing capacity kg/m²
19-Jan-16	1	330mm drilled footing	concrete	330mm	500mm+	Stiff London clays with small rubble	25,000
19-Jan-16	2	180mm	soft brick	180mm	450mm+ ?	Stiff London clays with small rubble	25,000
19-Jan-16	3	250mm	soft brick	250mm	500mm	Moist London clays with small rubble	20,000
27-Jan-16	4	750mm	concrete	745mm	500mm+	Top of footing 450mm . Moist London clays with small rubble	25,000
16-Feb-16	5	1350mm	soft brick, stepped	340mm	500mm	Firm London clays, >5% grit	25,000
18-Feb-16	6	1350mm	soft brick, stepped	340mm	500mm	Firm London clays, >5% grit	25,000
11-Feb-16	7	1350mm	brick, stepped	360mm	580mm	Firm London clays, ivy roots first 300mm	25,000
27-Jan-16	8	340mm	soft brick, stepped	320mm	340mm	Firm London clays	25,000
29-Jan-16	9	300mm	soft brick, stepped	280mm	320mm	Firm London clays, >5% grit	25,000
19-Feb-16	10	1360mm	soft brick, stepped	320mm	520mm	Moist London clays	20,000



GARDEN FLOOR -TEST PITS

44 Downshire Hill, London NW3 1NU

1:100 21 Feb16 53021-24

Claymore Design & Build

copyright 2016