

DUCT USE ABOVE CEILING
TRANSFORM TO
650 X 350

NGN 75 CI. WVP FROM ABOVE OFFICE @ 1350 TO 100 SUP DECK
GENERAL EXTRACT
FAN

2492

125Ø EXTRACT DUCT FROM OFFICE AIR VALVE
100Ø EXTRACT DUCT FROM WC AIR VALVE

800X200 DUCT THRU
WALL ABOVE OPENING

16X12 HOOD OVER
RANGE + FRIER ON
WORKTOP

650 X 350 SUPPLY DUCT
DROP WITH SOFFIT

150Ø EXTRACT DUCT
AT HIGH LEVEL
RISING WITH SOFFIT
350 Ø DUCT AT
H/L

650 X 350 SUPPLY
DUCT UNDER EXTRACT
DUCT

1800X1100 HOOD
OVER PIZZA OVEN

ACCESS FOR
CLEANING
OVEN FLUE UNDER
HOOD

TYPICAL SILENCE
(MINIEX USED)

400 X 350 KITCHEN
EXTRACT FAN RATED
DUCT TO ABOVE EXACT
LOCATION (F.B.C.)
SYSTEMAIR GIGASOX
GSW 450/4/T120
KITCHEN EXTRACT FAN
VENTILATION SYSTEM
CONTROL PANEL

SUPPLY FAN AT
HIGH LEVEL
SYSTEMAIR GIGASOX
GSW 450/4/T120

24kW ELECTRICAL
HEATER BATTERY

INTAKE AIR FILTER
G4 RATING

300 X180 EXTRACT DUCT
TA WITH FD IN FLOOR

INTAKE COUPLER OVER
DOOR

SETTING PLAN
SCALE 1:5(A1)

LEGEND:

SUPPLY DUCT ABOVE CEILING

SUPPLY GRILLE WITH Ø80
DRAIN ADVISOR FOR SUPPLY AIR
DISTRIBUTION IN EXTENDED WALL

ELECTRIC DOOR HEATED
OVER ENTRANCE. SUPPORTED
OVER LOBBY

ENTRANCE

400X350 FIRE RATED DUCT ENCASED
IN 50MM THICK CONCRETE FOIL FACED INSULATION THRU FLOOR ABOVE

BRINKORTH

4-6 ELLSWORTH STREET E2 0AX
T +44 (0)207 613 5341 • VORTH.CO.UK

NOTE: DO NOT SCALE DRAWING. CONTRACTOR TO CHECK ALL DIMENSIONS FROM DRAWINGS TO SITE AND NOTIFY THE ARCHITECT OF ANY DISCREPANCIES PRIOR TO FABRICATION TO ALLOW FOR MODIFICATIONS. DISCREPANCIES NOT BROUGHT TO THE ATTENTION OF THE ARCHITECT WILL BE THE RESPONSIBILITY OF THE RELEVANT CONTRACTOR.
*THE WORKS DESCRIBED AND SPECIFIED ON THIS DRAWING AND ASSOCIATED DRAWINGS SHALL BE UNDERTAKEN IN ACCORDANCE WITH CURRENT HEALTH AND SAFETY PLAN PREPARED BY THE PLANNING SUPERVISOR FOR THE PROJECT.
*THIS DRAWING SHOULD BE READ IN CONJUNCTION WITH ALL SPECIFICATIONS AND ALL RELEVANT DESIGN, ENGINEERS AND SPECIALIST DRAWINGS.
*THE CONTRACTOR MUST ADVISE ON ALL DETAILS TO ENSURE STABILITY AND STRENGTH OF CONSTRUCTION ALL MATERIALS TO BE MATCHED AND BALANCED AS APPROPRIATE.

PI	DATE	DESCRIPTION	ISSUE	DATE	DESCRIPTION
PI	14.4.16	Updated for Range Hood & WVP Summary			

SITE ADDRESS	UNIT 92, Stables Market, Chalk Farm Road, Chalk Farm, London NW1 6AH	DRAWING NAME	PLAN - SETTING OUT
JOB NAME	VOODOO RAYS/ CAMDEN	STATUS	APPROVALS

DRAWN BY	GS	CHECKED BY	SC
JOB N°	3096	DRAWING N°	A203
DATE	10.15	SCALE	1:50 @ A3 1:100 @ A1