





REPORT AS8786.160513.NIA1.1



29B MONTAGUE STREET, LONDON



NOISE IMPACT ASSESSMENT



Prepared: 18 May 2016



Taylor Project Services
No 1 Cornhill
London
EC3V 3ND

CONTENTS

1.0	INTRODUCTION	1
2.0	SURVEY PROCEDURE & EQUIPMENT	1
3.0	RESULTS	2
4.0	DISCUSSION	2
5.0	DESIGN CRITERIA	2
5.1	<i>Local Authority Requirements</i>	2
5.2	<i>BS8233:2014 Guidance on sound insulation and noise reduction for buildings</i>	3
6.0	PREDICTED NOISE IMPACT	3
6.1	<i>Proposed plant</i>	3
6.2	<i>Predicted noise levels</i>	4
6.3	<i>Comparison to BS8233:2014 Criteria</i>	4
7.0	CONCLUSION	4

List of Attachments

AS8786/SP1	Indicative Site Plan
AS8786/TH1-TH5	Environmental Noise Time Histories
Appendix A	Acoustic Terminology
Appendix B	Acoustic Calculations

1.0 INTRODUCTION

Planning approval is being sought for the installation of new plant at 29B Montague Street, London.

Clarke Saunders Associates has been commissioned by Taylor Project Services to undertake an environmental noise survey in order to measure the prevailing background noise climate at the site. The background noise levels measured will be used to determine daytime and night-time noise emission limits and, subsequently, to assess the noise impact of proposed building services plant in accordance with the planning requirements of Camden Council.

2.0 SURVEY PROCEDURE & EQUIPMENT

A survey of the existing background noise levels was undertaken at ground floor level at the location shown in site plan AS8786/SP1. Measurements of consecutive 5-minute L_{Aeq} , L_{Amax} , L_{A10} and L_{A90} sound pressure levels were taken between 10:20 hours on Friday 13th and 10:15 hours on Tuesday 17th May 2016.

These measurements will allow suitable noise criteria to be set for the new building services plant, dependent on hours of operation.

The following equipment was used during the course of the survey:

- Norsonic data logging sound level meter type 118;
- Norsonic sound level calibrator type 1253.

The calibration of the sound level meter was verified before and after use. No significant calibration drift was detected.

The weather during the survey was dry with light winds, which made the conditions suitable for the measurement of environmental noise.

Measurements were made generally in accordance with ISO 1996-2:2007 *Acoustics - Description, measurement and assessment of environmental noise – Part 2: Determination of environmental noise levels*.

Please refer to Appendix A for details of the acoustic terminology used throughout this report.

3.0 RESULTS

Figures AS8786/TH1-TH5 show the L_{Aeq} , L_{Amax} , L_{A10} and L_{A90} sound pressure levels as time histories at the measurement position.

4.0 DISCUSSION

The background noise climate in the area is determined by road traffic noise in the surrounding streets.

Measured minimum background noise levels are shown in Table 4.1 below.

Monitoring period	Minimum $L_{A90,5mins}$
07:00 - 23:00 hours	41 dB 21:30 – 21:35, 15/05/2016
23:00 - 07:00 hours	37 dB 05:25 – 05:30, 15/05/2016
24 hours	41 dB

Table 4.1 - Minimum measured background noise levels

[dB ref. 20 μ Pa]

5.0 DESIGN CRITERIA

5.1 Local Authority Requirements

Camden Council currently requires new plant to be 5dB below the background level.

Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (L_{A90}), expressed in dB(A) when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the L_{A90} , expressed in dB(A).

It is not expected that tonal noise will be generated by the proposed plant units and so the plant noise emissions criteria that should not be exceeded at the nearest noise sensitive receiver are detailed in Table 5.1 .

Daytime (07:00 – 23:00 hours)	Night-time (23:00 – 07:00 hours)	24 hours
L _{Aeq} 36 dB	L _{Aeq} 32 dB	L _{Aeq} 32 dB

Table 5.1 - Proposed design noise criteria

[dB ref. 20µPa]

5.2 BS8233:2014 Guidance on sound insulation and noise reduction for buildings

The guidance in this document indicates suitable noise levels for various activities within residential and commercial buildings.

The relevant sections of this standard are shown in the following table:

Activity	Location	07:00 to 23:00	23:00 to 07:00
Resting	Living Room	35 dB L _{Aeq, 16 hour}	-
Dining	Dining Room	40 dB L _{Aeq, 16 hour}	-
Sleeping (daytime resting)	Bedroom	35 dB L _{Aeq, 16 hour}	30 dB L _{Aeq, 8 hour}

Table 5.2 - Excerpt from BS8233: 2014

[dB ref. 20µPa]

6.0 PREDICTED NOISE IMPACT

6.1 Proposed plant

The selected plant has been confirmed as:

- 2 no. Daikin Condensing Units Type RXYSQ6TY1

The approximate location of the plant to be installed is shown in site plan AS8786/SP1.

Noise levels generated by the type RXYSQ6TY1 condensers to be installed have been confirmed by the manufacturer as follows:

Freq (Hz)	63	125	250	500	1000	2000	4000	8000	dB(A)
Lp @ 1m (dB)	62	55	54	52	48	42	35	28	53

Table 6.1 - Source noise data for the type RXYSQ6TY1 condenser

[dB ref. 20µPa]

6.2 Predicted noise levels

Following an inspection of the site, the most noise sensitive receiver is to the rear of the Grange Buckingham situated on Bedford Place at 4th floor level, as shown on the indicative site plan AS8786/SP1. This window is at least 23 metres away from the proposed plant location.

The cumulative noise level at the nearest noise sensitive receiver has been assessed according to the guidelines set out in BS4142:1997 *Method for rating industrial noise affecting mixed residential and industrial areas* as guidance, using the noise data above. Screening losses afforded by the existing boundary wall have been included in the prediction of the cumulative plant noise level at the nearest receiver.

Predicted cumulative plant noise level at receptor	24 hour design criterion
L _{Aeq} 17 dB	L _{Aeq} 32 dB

Table 6.2 - Predicted noise level and criteria at nearest noise sensitive location

[dB ref. 20 µPa]

6.3 Comparison to BS8233:2014 Criteria

BS8233 assumes a loss of approximately 15dB for a partially open window. The external noise level shown in Table 6.2 would result in an internal noise levels that would meet the level shown in Table 5.2.

7.0 CONCLUSION

An environmental noise survey has been undertaken at 29B Montague Street, London by Clarke Saunders Associates between Friday 13th and Monday 16th May 2016.

Measurements have been made to establish the current background noise climate. This has enabled a 24-hour design criterion to be set for the control of plant noise emissions to noise sensitive properties, in accordance with Camden Council's requirements.

Data for the new Daikin condensing units have been used to predict the noise impact of the new plant on neighbouring residential properties.

Compliance with the noise emission design criterion has been demonstrated. No further mitigation measures are required for external noise emissions.


Jamie Duncan (May 18, 2016)

Jamie Duncan MIOA


CLARKE SAUNDERS ASSOCIATES



Figure AS8786/SP1

29B Montague Street, London

Environmental Noise Time History




Friday 13 May 2016

Figure AS8786/TH1

29B Montague Street, London

Environmental Noise Time History




Saturday 14 May 2016

Figure AS8786/TH2

29B Montague Street, London

Environmental Noise Time History




Sunday 15 May 2016

Figure AS8786/TH3

29B Montague Street, London

Environmental Noise Time History




Monday 16 May 2016

Figure AS8786/TH4

29B Montague Street, London

Environmental Noise Time History



Tuesday 17 May 2016

Figure AS8786/TH5

APPENDIX A

ACOUSTIC TERMINOLOGY & HUMAN RESPONSE TO BROADBAND NOISE

1.0 ACOUSTIC TERMINOLOGY

The annoyance produced by noise is dependent upon many complex interrelated factors such as 'loudness', its frequency (or pitch) and any variations in its level. In order to have some objective measure of the annoyance, scales have been derived to allow for these subjective factors.

- dB (A):** The human ear is more susceptible to mid-frequency noise than the high and low frequencies. To take account of this when measuring noise, the 'A' weighting scale is used so that the measured noise corresponds roughly to the overall level of noise that is discerned by the average human. It is also possible to calculate the 'A' weighted noise level by applying certain corrections to an un-weighted spectrum. The measured or calculated 'A' weighted noise level is known as the dB(A) level.
- L₁₀ & L₉₀ :** If a non-steady noise is to be described it is necessary to know both its level and the degree of fluctuation. The L_n indices are used for this purpose, and the term refers to the level exceeded for n% of the time, hence L₁₀ is the level exceeded for 10% of the time and as such can be regarded as the 'average maximum level'. Similarly, L₉₀ is the average minimum level and is often used to describe the background noise.
- It is common practice to use the L₁₀ index to describe traffic noise, as being a high average, it takes into account the increased annoyance that results from the non-steady nature of traffic noise.
- L_{eq} :** The concept of L_{eq} (equivalent continuous sound level) has up to recently been primarily used in assessing noise in industry but seems now to be finding use in defining many other types of noise, such as aircraft noise, environmental noise and construction noise.
- L_{eq} is defined as a notional steady sound level which, over a stated period of time, would contain the same amount of acoustical energy as the actual, fluctuating sound measured over that period (e.g. 8 hour, 1 hour, etc).
- The use of digital technology in sound level meters now makes the measurement of L_{eq} very straightforward.
- Because L_{eq} is effectively a summation of a number of noise events, it does not in itself limit the magnitude of any individual event, and this is frequently used in conjunction with an absolute noise limit.
- L_{max} :** L_{max} is the maximum sound pressure level recorded over the period stated. L_{max} is sometimes used in assessing environmental noise where occasional loud noises occur, which may have little effect on the L_{eq} noise level.
- D** The sound insulation performance of a construction is a function of the difference in noise level either side of the construction in the presence of a loud noise source in one of the pair of rooms under test. D, is therefore simply the *level difference* in decibels between the two rooms in different frequency bands.
- D_w** D_w is the *Weighted Level Difference* The level difference is determined as above, but weighted in accordance with the procedures laid down in BS EN ISO 717-1.
- D_{nT,w}** D_{nT,w} is the *Weighted Standardised Level Difference* as defined in BS EN ISO 717-1 and represents the *weighted level difference*, as described above, corrected for room reverberant characteristics.
- C_{tr}** C_{tr} is a spectrum adaptation term to be added to a single number quantity such as D_{nT,w}, to take account of characteristics of a particular sound.
- L'_{nT,w}** L'_{nT,w} is the *Weighted Standardised Impact Sound Pressure Level* as defined in BS EN ISO 717-2 and represents the level of sound pressure when measured within room where the floor above is under excitation from a calibrated tapping machine, corrected for the receive room reverberant characteristics.

APPENDIX A

ACOUSTIC TERMINOLOGY & HUMAN RESPONSE TO BROADBAND NOISE

2.0 OCTAVE BAND FREQUENCIES

In order to determine the way in which the energy of sound is distributed across the frequency range, the International Standards Organisation have agreed on "preferred" bands of frequency for sound measurement and analysis. The widest and most commonly used band for frequency measurement and analysis is the Octave Band. In these bands, the upper frequency limit is twice the lower frequency limit, with the band being described by its "centre frequency" which is the average (geometric mean) of the upper and lower limits, eg. 250 Hz octave band runs from 176 Hz to 353 Hz. The most commonly used bands are:

Octave Band Centre Frequency Hz 63 125 250 500 1000 2000 4000 8000

3.0 HUMAN PERCEPTION OF BROADBAND NOISE

Because of the logarithmic nature of the decibel scale, it should be borne in mind that noise levels in dB(A) do not have a simple linear relationship. For example, 100dB(A) is not twice as loud as 50 dB(A) sound level. It has been found experimentally that changes in the average level of fluctuating sound, such as traffic noise, need to be of the order of 3 dB(A) before becoming definitely perceptible to the human ear. Data from other experiments have indicated that a change in sound level of 10 dB(A) is perceived by the average listener as a doubling or halving of loudness. Using this information, a guide to the subjective interpretation of changes in traffic noise level can be given.

INTERPRETATION

Change in Sound Level dB(A)	Subjective Impression	Human Response
0 to 2	Imperceptible change in loudness	Marginal
3 to 5	Perceptible change in loudness	Noticeable
6 to 10	Up to a doubling or halving of loudness	Significant
11 to 15	More than a doubling or halving of loudness	Substantial
16 to 20	Up to a quadrupling or quartering of loudness	Substantial
21 or more	More than a quadrupling or quartering of loudness	Very Substantial

4.0 EARTH BUNDS AND BARRIERS - EFFECTIVE SCREEN HEIGHT

When considering the reduction in noise level of a source provided by a barrier, it is necessary to establish the "effective screen height". For example if a 3 metre high barrier exists between a noise source and a listener, with the barrier close to the listener, the listener will perceive the noise source is louder, if he climbs up a ladder (and is closer to the top of the barrier) than if he were standing at ground level. Equally if he sat on the ground the noise source would seem quieter than it was if he were standing. This may be explained by the fact that the "effective screen height" is changing with the three cases above, the greater the effective screen height, in general, the greater the reduction in noise level.

Where the noise sources are various roads, the attenuation provided by a fixed barrier at a specific property will be greater for roads close to the barrier than for roads further away.

APPENDIX B

EXTERNAL PLANT NOISE EMISSIONS CALCULATIONS

Calculation 1:

			63	125	250	500	1000	2000	4000	8000	dB(A)
Daikin RXYSQ6PV	Lp	1 m	62	55	54	52	48	42	35	28	53
Number of units		2	3	3	3	3	3	3	3	3	
Distance Loss		24 m	-28	-28	-28	-28	-28	-28	-28	-28	
Location Correction (reverberant sound build up)			3	3	3	3	3	3	3	3	
Screening*			-8	-10	-12	-15	-18	-18	-18	-18	
<i>Level At Receiver</i>			32	23	20	15	8	2	-5	-12	17

* Screening limited to -18dB

24-hour plant noise design criterion 32 dB(A)