



LEGEND/NOTES

DO NOT SCALE OFF DRAWING
ALL DIMENSIONS TO BE CHECKED ON SITE

- = ROUTE OF REFRIGERANT PIPEWORK
- - - = ROUTE OF CONDENSATE DRAIN
- = WEATHERPROOF MAINS ISOLATOR
- RC = REMOTE CONTROLLER
- = AIR HANDLING UNIT
- ▨ = BEAM BELOW FALSE CEILING LINE
- = BEAM IN CEILING VOID
- = LOSSNAY HEAT RECOVERY (FRESH AIR) UNIT
- = AIR CONDITIONING DUCT WORK
- = FRESH AIR DUCT WORK
- ⋯ = 200dia INSULATED FLEXIBLE DUCT
- SA = SUPPLY AIR DIFFUSERS (REUSE EXISTING WHERE POSSIBLE)
- RA = 600 x 600 RETURN AIR EGGCRETE GRILLES (NEW)
- = SYSTEM REMOVED

THIS DRAWING TO BE READ INCONJUNCTION WITH DWG No. H0203/1, /2, /3 & /5

REV	AMENDMENT	DATE

© This design and drawing is the property of HUGGINS & SQUIRE LIMITED and must not be copied in any form or passed on to any third party without prior permission in writing from HUGGINS & SQUIRE LIMITED.



incorporating Chiltern Environmental Services
39 Watford Metro Centre, Tolpits Lane, Watford,
Herts WD18 9YE
Tel: 01923 228225 Fax: 01923 227505
Email: info@hugginsandsquire.co.uk

CONTRACT
**44 WICKLOW STREET
LONDON WC1**

TITLE
**SECOND FLOOR
AIR CONDITIONING**

DRWG. NO.	DRAWN	O.L.
H0301/4	DATE	JAN 03
	SCALE	1:50 (A1)

WHERE TRAY IS TO BE REMOVED OR RAISED,
THE FIRE ALARM CABLES, ANY MAINS
CABLES OR ANY SERVICES NOT SERVING THE A/C
EQUIPMENT ARE TO BE RE-ROUTED BY OTHERS

WHERE DRAWING SHOWS TRAYS & DUCTING PASSING
UNDER BEAMS (TO BE BOXED IN) IT MAY BE POSSIBLE TO
PASS OVER BEAMS IF HOLES MADE BY OTHERS