



(A) Proposed Electrical cable from No 7 Grays Inn Square Existing meters 25mm diameter armoured cable in 50mm diameter metal duct 450mm below road + paving levels

Existing Plan showing Proposed Electric Vehicle charging points

Gray's Inn Estate - Proposed Electric Vehicle Charging Points For The Honourable Society of Gray's Inn Proposed Installations North end Grays Inn Square

GHK ARCHITECTS
 Architects · Designers · Historic Building Specialists
 530 Fulham Road, London SW6 5NR
 Tel: +44 (0)20 7471 8000 mail@ghkarchitects.co.uk
 www.ghkarchitects.co.uk

Drawing No: HK2209/SK009
 Scale: 1:100 @ A3
 Date: 3 May 2016
 Drawn LM

Scale Bar