

12.5mm MARINE PLYWOOD LINING  
AND SINGLE LAYER 12.5mm  
PLASTERBOARD TO INTERNAL  
REVEAL; TO BE FITTED  
FOLLOWING INSTALLATION OF  
WINDOWS  
PROPRIETARY CORNER BEAD  
FOR PLASTERBOARD TO TAKE  
SKIM FINISH  
PLASTERBOARD STOP-BEAD;  
ALLOW 5mm GAP FOR FLEXIBLE  
SEALANT UP TO WINDOW FRAME

PROPRIETARY CORNER BEAD  
FOR PLASTERBOARD TO TAKE  
SKIM FINISH

PLASTERBOARD STOP-BEAD:  
ALLOW 5mm GAP FOR FLEXIBLE  
SEALANT UP TO WINDOW FRAME

EPDM / WINDOW SEAL BY  
WINDOW INSTALLER

MINERAL WOOL BY WINDOW  
INSTALLER

THERMALLY BROKEN DOUBLE  
GLAZED WINDOW (E.G. VELFAC  
200 SHOWN)

PROPRIETARY NEOPRENE /  
COMPRIBAND WEATHER SEAL BY  
WINDOW INSTALLER

STRUCTURAL STEEL RHS POST  
AND FIXING PLATE BEYOND TO  
S.E. SPECIFICATION

REINFORCEMENT TO CORNERS  
TO BE ADVISED BY BRICK  
SPECIALIST

WALL TIES TO S.E. SPECIFICATION  
(E.G. HEIGHT ADJUSTABLE  
FRAMING CRAMPS SHOWN)

— EXTERNAL WALL TYPE WT-RC2  
(REFER TO D-TY-WT-RC2)

CONCRETE UPSTAND BELOW TO  
SE DETAILS AND SPECIFICATIONS

LEDGE

### I. Block C - D.

EXTERNAL WALL TYPE WT-RC2  
(REFER TO D-TY-WT-RC2)

CONCRETE UPSTAND BELOW TO  
SE DETAILS AND SPECIFICATIONS

lock C - D-I-RC

- THERMALLY BROKEN DOUBLE GLAZED WINDOW (E.G. VELFAC 200 SHOWN)
- PROPRIETARY NEOPRENE / COMPRIBAND WEATHER SEAL BY WINDOW INSTALLER
- MINERAL WOOL BY WINDOW INSTALLER
- EPDM / WINDOW SEAL BY WINDOW INSTALLER

— PROPRIETARY CORNER BEAD  
FOR PLASTERBOARD TO TAKE  
SKIM FINISH

Alan Camp Architects LLP, 88 Union Street, London, SE1 0NW  
tel: 020 7593 1000. fax 020 7593 1001. mail@alancamp.com


job  
BACTON LOW RISE  
LONDON NW5

drawing  
TYPICAL BLOCK C DETAILS  
External wall junctions - RC129 to RC132

note: all dimensions to be checked on site before commencement of the work. if this drawing exceeds the quantities in any way the quantities are to be informed before the work is commenced. for all other purposes other than planning application purposes do not scale. use dimensions. this drawing is copyright.

\_\_\_\_\_

rev.	date	description	issued by	checked by
C1	20.01.16	First Construction issue	RR	DWW

		
<b>Received</b>		
	<b>Initial</b>	<b>Date</b>
RYDON	RA	25 Jan 16
Client		
Status A – No Comments		<input type="checkbox"/>
Status B – Comments, Revise & Resubmit		<input checked="" type="checkbox"/>
Status C – Rejected		<input type="checkbox"/>
<b>For Information Only</b>		<input type="checkbox"/>

LEDGE

STRUCTURAL STEEL RHS POST  
AND FIXING PLATE BEYOND TO  
S.E. SPECIFICATION

REINFORCEMENT TO CORNERS  
TO BE ADVISED BY BRICK  
SPECIALIST

WALL TIES TO S.E. SPECIFICATION  
(E.G. HEIGHT ADJUSTABLE  
FRAMING CRAMPS SHOWN)

— EXTERNAL WALL TYPE WT-RC2  
(REFER TO D-TY-WT-RC2)

CONCRETE UPSTAND BELOW TO  
SE DETAILS AND SPECIFICATIONS

Block C D

Block C D LDC