

PROPOSED U-VALUE TO ACHIEVE

External Wall - Brickwork with Mestic

Ground Floor

0.11 W/m2.K

0.10 W/m2.K

All dimensions to be verified on site by Main Contractor before the start of any shop drawings or work whatsoever either on their own behalf or that of sub-

Report any discrepancies to the Contract Administrator at once.

ALL JUNCTIONS BETWEEN INTERNAL CEILING & INTERNAL WALLS AND PENETRATIONS IN AIR BARRIER

TO BE SEALED WITH FLEXIBLE SEALANT.

This drawing is to be read with all relevant Architect's and Engineer's drawings

Vision, form and function 1 Alie Street

VARS - IW - XX - ZZ - DR - A - 35.13