

Masonry Wall Tie Spacing

	Horizontal Spacing	Vertical Spacing	
Distance along wall	Max. 900mm	Max. 450mm	
Distance from Openings, Roof Verges, Movement Joints	Max. 225mm	Max. 300mm	

Note; Wall ties along wall may correspond to table above or alternatively be spaced such as not to be less than 2.5 ties/m². Wall ties to be installed to manufacturer instructions

ALL JUNCTIONS BETWEEN INTERNAL CEILING &

INTERNAL WALLS AND PENETRATIONS IN AIR
BARRIER TO BE SEALED WITH FLEXIBLE SEALANT. ALL PLASTERBOARD JOINT LOCATIONS TO BE

TAPED AND JOINT FINISH. ALL PLASTERBOARD ON DABS TO HAVE CONTINUOUS RIBBON OF ADHESIVE AROUND ALL OPENINGS, ALONG TOP AND BOTTOM OF WALL,

AND AT INTERNAL AND EXTERNAL CORNERS.

DETAILS TO BE READ IN CONJUNCTION WITH SECTIONS & GA PLANS - REFER TO SUITABLE PLASTERBOARD TYPE.

## NOTE

Wall tie setouts shown indicatively. Set outs & distances between ties to be installed as per manufacturer instructions

PROPOSED U-VALUE TO ACHIEVE	-
Ground Floor	0.11 W/m2.K
External Wall - Brickwork with Mestic	0.10 W/m2.K
External Wall - Brickwork with Blockwork	0.11 W/m2.K
Separating Walls: Flat / Communal Areas	TBC
Separating Walls: Flat / Lift Shaft	TBC
Separating Walls: Flat / Flat Party Walls	0.0*
Roof	0.11 W/m2.K
External Opaque Doors	1.0 W/m2.K
External Windows	1.5 W/m2.K (g-value of 0.6
External Glazed Doors	1.5 W/m2.K (g-value of 0.6
AIR PREMEABILITY	4m3/m2.h

All dimensions to be verified on site by Main Contractor before the start of any

Report any discrepancies to the Contract Administrator at once.

This drawing is to be read with all relevant Architect's and Engineer's drawings and other relevant information. © Ingleton Wood LLP

LEGEND: DO NOT SCALE

**GENERAL NOTES** This drawing should be read in conjunction with all relevant consultants drawings and specifications. Setting out dimensions and sizing of all RC elements should be taken from structural engineer's drawings and documentation.



