



- Rev C - Proposed acoustic screen shown to surround plant area only - 22 April 16
- Rev B - New access hatch framed out with steel beams anchored to wall of tank room as advised by Fenton Holloway, - 15 April 16
- Rev A - Condenser support method changed to suit structural engineers comments. Proposed modified acoustic screen shown - 13 April 16
- Rev D - Proposed new Access Hatch omitted from contract - 29 April 16

 Comfort Service & Maintenance Ltd comfort works, newchapel road lingfield, surrey, rh7 6le	Title: Proposal for Chiller No 1 alteration to Air Cooled DX System - Roof Layout		Project: New London Theatre	
	Client: Really Useful Group Theatres	Scale: 1:50 @ A2	Date: 3 Mar 16	Drawn By: MFP
	Air Conditioning Engineers Tel: 01342 830600 Fax: 01342 830605 Email: service@comfort.uk.com		Drawing No: S1134Q/9 Rev D	