Ruairi Reeves

From: Nick Olson [Nick.Olson@arup.com]

Sent: 26 May 2016 10:05

To: Mike Hays; Julie Peake (Julie.Peake@riley-consulting.com); Ruairi Reeves

Subject: FW: National Hospital for Neurology and Neurosurgery - plant

Hi All,

Please see definitive response from the planning officer on the chiller noise levels. So we are back within our current design.

Best regards

Nick

From: Davis, Edward [mailto:Edward.Davis@camden.gov.uk]

Sent: 25 May 2016 23:21

To: Nick Olson Cc: Skelli-Yaoz, Tania

Subject: Re: National Hospital for Neurology and Neurosurgery - plant

Hello Nick,

To save any ambiguity on this that is correct 5dB below background as per DP28.

Edward Davis

On 25 May 2016, at 16:31, Nick Olson < Nick.Olson@arup.com > wrote:

Dear Edward,

I understand you have been speaking to Ruairi Reeves of Medical Architecture regarding the above project. I am the mechanical engineer on the project, responsible for designing the chiller.

I am trying to understand the noise criteria we need to meet for planning permission.

The chiller will have no distinctive tonal noises, it will emit a uniform hum. This being the case, am I right in believing we will need to meet a noise level of 5dB less than the prevailing noise levels at the nearest sensitive receptor, in accordance with DP28, and not the more onerous level of -10dB given in the planning consent document?

Many thanks Best regards Nick

Nick Olson

Senior Engineer | Mechanical CEng, MIMechE

Arup

13 Fitzroy Street London W1T 4BQ United Kingdom d: +44 20 7755 2123 m: +44 7747 006 537

www.arup.com

Electronic mail messages entering and leaving Arup business systems are scanned for acceptability of content and viruses

This e-mail may contain information which is confidential, legally privileged and/or copyright protected. This e- mail is intended for the addressee only. If you receive this in error, please contact the sender and delete the material from your computer.