

## Project name

**Hampstead Secondary School**

As designed

Date: Tue Mar 29 08:23:00 2016

## Administrative information

## Building Details

Address: Hampstead Secondary School, ,

## Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.2

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.2

BRUKL compliance check version: v5.2.b.1

## Owner Details

Name:

Telephone number:

Address: , ,

## Certifier details

Name: Nathan Evans

Telephone number: 01423 855 971

Address: Hornbeam House, Hornbeam Park, Hookstone Road, Harrogate, HG2 8QT

Criterion 1: The calculated CO<sub>2</sub> emission rate for the building should not exceed the target

1.1	CO <sub>2</sub> emission rate from the notional building, kgCO <sub>2</sub> /m <sup>2</sup> .annum	24.7
1.2	Target CO <sub>2</sub> emission rate (TER), kgCO <sub>2</sub> /m <sup>2</sup> .annum	24.7
1.3	Building CO <sub>2</sub> emission rate (BER), kgCO <sub>2</sub> /m <sup>2</sup> .annum	15.6
1.4	Are emissions from the building less than or equal to the target?	BER =< TER
1.5	Are as built details the same as used in the BER calculations?	Separate submission

## Criterion 2: The performance of the building fabric and the building services should achieve reasonable overall standards of energy efficiency

Values which do not meet standards in the 2013 Non-Domestic Building Services Compliance Guide are displayed in red.

## 2.a Building fabric

Element	U <sub>a</sub> -Limit	U <sub>a</sub> -Calc	U <sub>i</sub> -Calc	Surface where the maximum value occurs*
Wall**	0.35	0.19	0.19	0C000000:Surf[7]
Floor	0.25	0.16	0.16	0C000000:Surf[0]
Roof	0.25	0.13	0.13	0D000001:Surf[13]
Windows***, roof windows, and rooflights	2.2	1.48	1.48	0C000000:Surf[1]
Personnel doors	2.2	2.2	2.2	0C000000:Surf[2]
Vehicle access & similar large doors	1.5	-	-	No Vehicle access doors in building
High usage entrance doors	3.5	-	-	No High usage entrance doors in building
U <sub>a</sub> -Limit = Limiting area-weighted average U-values [W/(m <sup>2</sup> K)] U <sub>a</sub> -Calc = Calculated area-weighted average U-values [W/(m <sup>2</sup> K)] U <sub>i</sub> -Calc = Calculated maximum individual element U-values [W/(m <sup>2</sup> K)]				
* There might be more than one surface where the maximum U-value occurs.				
** Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.				
*** Display windows and similar glazing are excluded from the U-value check.				
N.B.: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.				

Air Permeability	Worst acceptable standard	This building
m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa	10	5

## 2.b Building services

The standard values listed below are minimum values for efficiencies and maximum values for SFPs. Refer to the Non-Domestic Building Services Compliance Guide for details.

<b>Whole building lighting automatic monitoring &amp; targeting with alarms for out-of-range values</b>	YES
<b>Whole building electric power factor achieved by power factor correction</b>	>0.95

### 1- HVAC1: HTG NV

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0.96	-	0.3	0	-
<b>Standard value</b>	0.91*	N/A	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.					

### 2- HVAC2: HTG EV

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0.96	-	0.3	0	-
<b>Standard value</b>	0.91*	N/A	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.					

### 3- HVAC3: HTG Hybrid

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0.96	-	0.3	0	0.81
<b>Standard value</b>	0.91*	N/A	N/A	N/A	0.5
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.					

### 4- HVAC5B: UFH Hybrid

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0.96	-	0.3	0	0.81
<b>Standard value</b>	0.91*	N/A	N/A	N/A	0.5
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.					

### 5- HVAC4: Split Cooling

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	3.5	3.5	0	0	-
<b>Standard value</b>	2.5*	3.2	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. For types <=12 kW output, refer to EN 14825 for limiting standards.					

### 6- SH HVAC2: HTG EV

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0.96	-	0.3	0	-
<b>Standard value</b>	0.91*	N/A	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.					

7- SH HVAC3: HTG Hybrid

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0.96	-	0.29	0	0.81
<b>Standard value</b>	0.91*	N/A	N/A	N/A	0.5
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.					

8- SH HVAC 1: HTG NV

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0.96	-	0.3	0	-
<b>Standard value</b>	0.91*	N/A	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.					

9- HVAC5: UFH

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0.96	-	0.3	0	-
<b>Standard value</b>	0.91*	N/A	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.					

1- DHW1: General

	Water heating efficiency	Storage loss factor [kWh/litre per day]
<b>This building</b>	0.96	0.003
<b>Standard value</b>	0.8	N/A

"No zones in project where local mechanical ventilation, exhaust, or terminal unit is applicable"

General lighting and display lighting	Luminous efficacy [lm/W]			General lighting [W]
	Luminaire	Lamp	Display lamp	
<b>Zone name</b>				
<b>Standard value</b>	60	60	22	
0 - CIRCULATION 01	-	70	-	283
0 - CIRCULATION 02	-	70	-	130
0 - CIRCULATION 03	-	70	-	109
0 - CLEANER STORE	70	-	-	13
0 - DINING	-	70	-	926
0 - DRAMA STUDIO	70	-	-	690
0 - EXTERNAL PE STORE	70	-	-	20
0 - KITCHEN/SERVERY	-	70	-	1403
0 - MAIN HALL	70	-	-	1949
0 - MUSIC CLASSROOM 01	70	-	-	409
0 - MUSIC CLASSROOM 02	70	-	-	407
0 - MUSIC CLASSROOM 03	70	-	-	387
0 - MUSIC PRACTICE 01	70	-	-	104
0 - MUSIC PRACTICE 02	70	-	-	91
0 - MUSIC PRACTICE 03	70	-	-	87

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name		Luminaire	Lamp	Display lamp	General lighting [W]
	Standard value	60	60	22	
0 - MUSIC PRACTICE 04		70	-	-	88
0 - MUSIC PRACTICE 05		70	-	-	104
0 - MUSIC PRACTICE 06		70	-	-	142
0 - MUSIC PRACTICE 07		70	-	-	93
0 - MUSIC PRACTICE 08		70	-	-	93
0 - MUSIC PRACTICE 09		70	-	-	95
0 - OFFICE 01		70	-	-	145
0 - PLANT		70	-	-	165
0 - RECEPTION		-	70	22	84
0 - STAFF SOCIAL		70	-	-	641
0 - STAIRS		-	70	-	82
0 - STAIRS 02		-	70	-	81
0 - STAIRS 03		-	70	-	82
0 - STORE 01		70	-	-	17
0 - STORE 02		70	-	-	12
0 - STORE 03		70	-	-	11
0 - STORE 04		70	-	-	7
0 - STORE 05		70	-	-	20
0 - STORE 05		70	-	-	0
0 - STORE 06		70	-	-	20
0 - STORE 06		70	-	-	0
0 - WC 01		-	70	-	50
0 - WC 02		-	70	-	240
0 - WC 03		-	70	-	71
1 - CIRCULATION 01		-	70	-	553
1 - CLASSROOM 01		70	-	-	387
1 - CLASSROOM 02		70	-	-	384
1 - CLASSROOM 03		70	-	-	369
1 - CLASSROOM 04		70	-	-	369
1 - CLASSROOM 05		70	-	-	369
1 - CLASSROOM 06		70	-	-	370
1 - CLASSROOM 07		70	-	-	369
1 - CLASSROOM 08		70	-	-	369
1 - CLASSROOM 09		70	-	-	368
1 - CLASSROOM 10		70	-	-	369
1 - CLASSROOM 11		70	-	-	369
1 - CLASSROOM 12		70	-	-	387
1 - OFFICE		70	-	-	104
1 - REPROGRAPHICS		70	-	-	297
1 - STAFF WORK 02		70	-	-	365
1 - STAFF WORK ROOM		70	-	-	225
1 - STAIRS 01		-	70	-	82
1 - STAIRS 02		-	70	-	130

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name	Standard value	Luminaire	Lamp	Display lamp	
		60	60	22	
1 - STAIRS 03		-	70	-	82
1 - STORE 01		70	-	-	13
1 - STORE 04		70	-	-	9
1 - STORE 05		70	-	-	15
1 - STORE 05		70	-	-	15
1 - WC 01		-	70	-	239
1 - WC 02		-	70	-	50
1 - WC 03		-	70	-	62
2 - CHEMICAL STORE		70	-	-	14
2 - CIRCULATION 01		-	70	-	523
2 - LAB 01		70	-	-	527
2 - LAB 02		70	-	-	530
2 - LAB 03		70	-	-	541
2 - LAB 04		70	-	-	525
2 - LAB 05		70	-	-	534
2 - LAB 06		70	-	-	524
2 - LAB 07		70	-	-	573
2 - LAB 08		70	-	-	716
2 - LAB 09		70	-	-	573
2 - LAB 10		70	-	-	531
2 - LAB 11		70	-	-	552
2 - SERVER		70	-	-	45
2 - STAFF WORK ROOM		70	-	-	323
2 - STAIRS 01		-	70	-	82
2 - STAIRS 02		-	70	-	129
2 - STAIRS 03		-	70	-	82
2 - STORE 01		70	-	-	13
2 - WC 01		-	70	-	236
2 - WC 02		-	70	-	49
SPORTS - FEMALE WC		-	70	-	129
SPORTS_activity store		70	-	-	30
SPORTS_activity studio		-	70	-	1013
SPORTS_clnrs store		70	-	-	18
SPORTS_community store		70	-	-	10
SPORTS_corridor		-	70	-	162
SPORTS_ex store		70	-	-	30
SPORTS_office / recep		-	70	22	93
SPORTS_other pupil wcs		-	70	-	94
SPORTS_pe store		70	-	-	42
SPORTS_pupil changing		-	70	-	162
SPORTS_pupil changing		-	70	-	161
SPORTS_sports hall		-	70	-	4067
SPORTS_staff change		-	70	-	33

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name		Luminaire	Lamp	Display lamp	General lighting [W]
	Standard value	60	60	22	
SPORTS_store		70	-	-	56
SPORTS_wc		-	70	-	58

**Criterion 3: The spaces in the building should have appropriate passive control measures to limit solar gains**

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
0 - DINING	NO (-20.9%)	NO
0 - DRAMA STUDIO	NO (-40.8%)	NO
0 - MAIN HALL	NO (-49.1%)	NO
0 - MUSIC CLASSROOM 01	NO (-54.3%)	NO
0 - MUSIC CLASSROOM 02	NO (-47.2%)	NO
0 - MUSIC CLASSROOM 03	NO (-56.5%)	NO
0 - MUSIC PRACTICE 01	N/A	N/A
0 - MUSIC PRACTICE 02	N/A	N/A
0 - MUSIC PRACTICE 03	N/A	N/A
0 - MUSIC PRACTICE 04	N/A	N/A
0 - MUSIC PRACTICE 05	N/A	N/A
0 - MUSIC PRACTICE 06	NO (-65.2%)	NO
0 - MUSIC PRACTICE 07	NO (-39.1%)	NO
0 - MUSIC PRACTICE 08	NO (-56.2%)	NO
0 - MUSIC PRACTICE 09	NO (-42.1%)	NO
0 - OFFICE 01	NO (-70.3%)	NO
0 - RECEPTION	N/A	N/A
0 - STAFF SOCIAL	NO (-61.5%)	NO
1 - CLASSROOM 01	NO (-69.2%)	NO
1 - CLASSROOM 02	NO (-72.9%)	NO
1 - CLASSROOM 03	NO (-33.8%)	NO
1 - CLASSROOM 04	NO (-33.4%)	NO
1 - CLASSROOM 05	NO (-36.4%)	NO
1 - CLASSROOM 06	NO (-41.4%)	NO
1 - CLASSROOM 07	NO (-41.2%)	NO
1 - CLASSROOM 08	NO (-41.2%)	NO
1 - CLASSROOM 09	NO (-41%)	NO
1 - CLASSROOM 10	NO (-41.2%)	NO
1 - CLASSROOM 11	NO (-42.6%)	NO
1 - CLASSROOM 12	NO (-72.9%)	NO
1 - OFFICE	N/A	N/A
1 - REPROGRAPHICS	NO (-20.2%)	NO
1 - STAFF WORK 02	NO (-45.7%)	NO
1 - STAFF WORK ROOM	NO (-40.1%)	NO
2 - LAB 01	NO (-63.6%)	NO
2 - LAB 02	NO (-32.3%)	NO
2 - LAB 03	NO (-41.1%)	NO
2 - LAB 04	NO (-36.7%)	NO

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
2 - LAB 05	NO (-62.7%)	NO
2 - LAB 06	NO (-68.2%)	NO
2 - LAB 07	NO (-43%)	NO
2 - LAB 08	NO (-40.1%)	NO
2 - LAB 09	NO (-45.2%)	NO
2 - LAB 10	NO (-44.6%)	NO
2 - LAB 11	NO (-66%)	NO
2 - SERVER	N/A	N/A
2 - STAFF WORK ROOM	NO (-30.7%)	NO
SPORTS_activity studio	NO (-18.3%)	NO
SPORTS_office / recep	N/A	N/A
SPORTS_sports hall	N/A	N/A

#### Criterion 4: The performance of the building, as built, should be consistent with the BER

Separate submission

#### Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place

Separate submission

#### EPBD (Recast): Consideration of alternative energy systems

<b>Were alternative energy systems considered and analysed as part of the design process?</b>	YES
Is evidence of such assessment available as a separate submission?	YES
Are any such measures included in the proposed design?	YES

# Technical Data Sheet (Actual vs. Notional Building)

## Building Global Parameters

	Actual	Notional
Area [m <sup>2</sup> ]	5344.9	5344.9
External area [m <sup>2</sup> ]	8765	8765
Weather	LON	LON
Infiltration [m <sup>3</sup> /hm <sup>2</sup> @ 50Pa]	5	4
Average conductance [W/K]	2380.02	3292.17
Average U-value [W/m <sup>2</sup> K]	0.27	0.38
Alpha value* [%]	10.01	10

\* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

## Building Use

### % Area Building Type

A1/A2 Retail/Financial and Professional services  
 A3/A4/A5 Restaurants and Cafes/Drinking Est./Takeaways  
 B1 Offices and Workshop businesses  
 B2 to B7 General Industrial and Special Industrial Groups  
 B8 Storage or Distribution  
 C1 Hotels  
 C2 Residential Inst.: Hospitals and Care Homes  
 C2 Residential Inst.: Residential schools  
 C2 Residential Inst.: Universities and colleges  
 C2A Secure Residential Inst.  
 Residential spaces  
 D1 Non-residential Inst.: Community/Day Centre  
 D1 Non-residential Inst.: Libraries, Museums, and Galleries  
**100 D1 Non-residential Inst.: Education**  
 D1 Non-residential Inst.: Primary Health Care Building  
 D1 Non-residential Inst.: Crown and County Courts  
 D2 General Assembly and Leisure, Night Clubs and Theatres  
 Others: Passenger terminals  
 Others: Emergency services  
 Others: Miscellaneous 24hr activities  
 Others: Car Parks 24 hrs  
 Others - Stand alone utility block

## Energy Consumption by End Use [kWh/m<sup>2</sup>]

	Actual	Notional
Heating	12.04	26.98
Cooling	0.27	0.16
Auxiliary	5.84	5.43
Lighting	9.55	10.42
Hot water	49.39	49.74
Equipment*	18.38	18.38
<b>TOTAL**</b>	<b>77.08</b>	<b>92.74</b>

\* Energy used by equipment does not count towards the total for calculating emissions.

\*\* Total is net of any electrical energy displaced by CHP generators, if applicable.

## Energy Production by Technology [kWh/m<sup>2</sup>]

	Actual	Notional
Photovoltaic systems	10.8	0
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0

## Energy & CO<sub>2</sub> Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m <sup>2</sup> ]	41.99	85.98
Primary energy* [kWh/m <sup>2</sup> ]	121.81	141.56
Total emissions [kg/m <sup>2</sup> ]	15.6	24.7

\* Primary energy is net of any electrical energy displaced by CHP generators, if applicable.



## HVAC Systems Performance

System Type	Heat dem MJ/m2	Cool dem MJ/m2	Heat con kWh/m2	Cool con kWh/m2	Aux con kWh/m2	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER
<b>[ST] Central heating using water: radiators, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity</b>									
Actual	44.3	0	13.6	0	2.1	0.9	0	0.96	0
Notional	45.5	0	14.7	0	1	0.86	0	----	----
<b>[ST] Central heating using water: radiators, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity</b>									
Actual	21.9	0	6.8	0	21.7	0.9	0	0.96	0
Notional	26.4	0	8.5	0	16.7	0.86	0	----	----
<b>[ST] Central heating using water: radiators, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity</b>									
Actual	57.8	0	17.8	0	2.2	0.9	0	0.96	0
Notional	57.9	0	18.7	0	1.1	0.86	0	----	----
<b>[ST] Central heating using water: radiators, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity</b>									
Actual	17.9	0	5.5	0	5.6	0.9	0	0.96	0
Notional	84.5	0	27.2	0	6.5	0.86	0	----	----
<b>[ST] Central heating using water: radiators, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity</b>									
Actual	72.1	0	22.2	0	23.7	0.9	0	0.96	0
Notional	75	0	24.2	0	18.3	0.86	0	----	----
<b>[ST] Split or multi-split system, [HS] Heat pump (electric): air source, [HFT] Electricity, [CFT] Electricity</b>									
Actual	1.1	1096.4	0.1	101.9	0	3.43	2.99	3.5	4
Notional	1.9	842.2	0.2	61.7	0	2.56	3.79	----	----
<b>[ST] Central heating using water: floor heating, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity</b>									
Actual	70.3	0	21.7	0	10.8	0.9	0	0.96	0
Notional	102.4	0	33	0	9.6	0.86	0	----	----
<b>[ST] Central heating using water: radiators, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity</b>									
Actual	99.8	0	30.7	0	5.2	0.9	0	0.96	0
Notional	190.5	0	61.4	0	4.7	0.86	0	----	----
<b>[ST] Central heating using water: floor heating, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity</b>									
Actual	79.1	0	24.4	0	6.5	0.9	0	0.96	0
Notional	201.5	0	64.9	0	5.3	0.86	0	----	----

### Key to terms

Heat dem [MJ/m2]	= Heating energy demand
Cool dem [MJ/m2]	= Cooling energy demand
Heat con [kWh/m2]	= Heating energy consumption
Cool con [kWh/m2]	= Cooling energy consumption
Aux con [kWh/m2]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type

# Key Features

The BCO can give particular attention to items with specifications that are better than typically expected.

## Building fabric

Element	U <sub>i-Typ</sub>	U <sub>i-Min</sub>	Surface where the minimum value occurs*
Wall	0.23	0.19	0K000000:Surf[8]
Floor	0.2	0.16	0C000000:Surf[0]
Roof	0.15	0.13	0D000001:Surf[13]
Windows, roof windows, and rooflights	1.5	1.45	SP000001:Surf[2]
Personnel doors	1.5	2.2	0C000000:Surf[2]
Vehicle access & similar large doors	1.5	-	No Vehicle access doors in building
High usage entrance doors	1.5	-	No High usage entrance doors in building
U <sub>i-Typ</sub> = Typical individual element U-values [W/(m <sup>2</sup> K)]		U <sub>i-Min</sub> = Minimum individual element U-values [W/(m <sup>2</sup> K)]	
* There might be more than one surface where the minimum U-value occurs.			

Air Permeability	Typical value	This building
m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa	5	5