


P3133	Rear of 26 New End Square		
BIA AUDIT QUERIES - RESPONSE TRACKER			Rev A - GS/IH for MA 05/07/16
			
Query No	Subject	Query	Action
1	BIA - General	Site Investigation Report to be submitted, including Ground Movement Assessment and Building Damage Assessment.	Our revised BIA and Monitoring Specification are to be submitted along with LBH revised Geotech report and 'LBH4379 BIA Audit Query Responses' document.
2	Stability	Movement management proposal required.	We have amended clause 4.04.10 of the BIA and added a Monitoring Specification document to describe the approach along with new BIA drawings BIA20 & BIA21
3	Stability/Hydrogeology	Construction method statement to be revised with additional information. See sections 5.9 and 5.10	We have amended clauses C01 & C05 of Appendix C of BIA and drawings BIA20 and BIA21 have been added. LBH have also amended their report to reflect this concern; refer to their section 5.2.
4	Hydrogeology	Cumulative effects of existing and proposed basements and lower ground floors on ground water flow. Consideration to adjoining property founding conditions is also required.	Refer to section 5 of LBH report reference LBH4379, with particular reference to clauses 5.1 & 5.2
5	Hydrogeology	Confirmation of aquifer depth and EA approval, if required.	Refer to section 5 of LBH report reference LBH4379 and to their document 'LBH4379 BIA Audit Query Responses'.
6	Stability	Ground Movement Assessment required for No.20 and 20-26 New End Square.	Refer to section 8 of LBH report reference LBH4379, with particular reference to clauses 8.4 & 8.5
7	Stability	Clarification required for net short term movement's calculations.	Refer to section 7 of LBH report reference LBH4379, with particular reference to clauses 7.8 & 7.8.4