

From: Davis, Edward
Sent: 08 August 2016 12:29
To: Grace Douglas, Amy
Subject: RE: Consultee letter for PlanningApplication Application: 2016/3322/P

Follow Up Flag: Follow up
Flag Status: Flagged

Hello Amy,

I have looked at the submitted noise report and from the calculations made there seems to be compliance to our noise criteria. I do not wish to object to the application but on the basis of the information available to me and the requirement of acoustic treatment, I recommend that any approval that might be granted be subject to the following conditions:

The external noise level emitted from plant, machinery or equipment at the development hereby approved shall be lower than the lowest existing background noise level by at least 5dBA, by 10dBA where the source is tonal, as assessed according to BS4142:2014 at the nearest and/or most affected noise sensitive premises, with all machinery operating together at maximum capacity.
Reason: To ensure that the amenity of occupiers of the development site/ surrounding premises is not adversely affected by noise from mechanical installations/ equipment.

Prior to use, plant or equipment at the development shall be mounted with proprietary anti-vibration isolators and fan motors shall be vibration isolated from the casing and adequately silenced and maintained as such.
Reason: To ensure that the amenity of occupiers of the development site and surrounding premises is not adversely affected by vibration.

Regards

Edward Davis
Noise Officer

Telephone: 02079744501

-----Original Message-----

From: Grace Douglas, Amy
Sent: 03 August 2016 14:04
To: Davis, Edward
Subject: RE: Consultee letter for PlanningApplication Application: 2016/3322/P

Hi Edward

Sorry I know you haven't had this long but wondering if you had any comments for this one.

Thank you

Amy

-----Original Message-----

From: Grace Douglas, Amy

Sent: 26 July 2016 12:12

To: Davis, Edward

Subject: Consultee letter for PlanningApplication Application: 2016/3322/P

Please find attached Consultee letter for PlanningApplication application
2016/3322/P

Y439039