

EXISTING
BRICK
WALL

EXISTING
CONCRETE
RETAINING
WALL

ALLOW FOR BREAKING OUT 1m x 0.25m
OF R.C WALL TO ACCOMMODATE NEW
BEAM. ALLOW FOR CONCRETE REPAIRS
TO EXISTING WALL

NEW
R.C SLAB

NEW
R.C
BEAM

SECTION B
(1:50)

NEW MANHOLE APPROXIMATELY 2.8m DEEP

CHARLOTTE STREET

EXISTING MANHOLES
REPLACED BY
NEW MANHOLES

WATER
SUPPLY
RENEWED

EXISTING
BUILDING
LINE

NEW STAIR
BY OTHERS

SLAB AND
BEAMS

NEW R.C
GROUND
BEAMS
450mm
DEEP

25.78
APPROX

SSL
26.95

SSL
27.98

FFL

NEW
PILES

NEW MANHOLE
BEYOND

SECTION A
THROUGH FOUNDATIONS
(1:50)

NOTES

1. PILES TO BE DESIGNED TO SUPPORT
ISOLATED. MAX DIAMETER 450mm.
2. CONCRETE TO BE IN ACCORDANCE
WITH THE SPECIFICATION
3. REFER TO WILD CARTER CLACK
FOR CAFE SUPERSTRUCTURE
4. STAIR TO OTHERS DETAILS

PROPOSED PLAN (1:50)