



**EXISTING REAR ELEVATION,
exposed brickwork**
SCALE 1:100@A3

EXISTING RENDER TO BE STRIPPED OFF AND BRICKWORK CRACKS REPAIRED AS NOTED.
EXTERNAL WALLS TO THEN BE RE-RENDERED USING TRADITIONAL LIME RENDER.

NOTES:

1. All dimensions are in millimetres(mm) & levels in metres(m) unless noted otherwise.
2. Work to indicated dimensions only. Do not scale this drawing.
3. This drawing to be read in conjunction with all relevant Architects, Engineers and Specialists drawings and the specification.
4. All work to comply with the relevant British Standards, Codes of Practice and the Building Regulations.
5. This drawing is to be carefully checked by main contractor against site conditions and any discrepancy reported to KASHEC before construction commences.
6. Fletton bricks should not be used for repairs. Brick types should be submitted to Architect for prior approval.

CRACKS WIDTHS AND ACTIONS REQUIRED	
Hairline	No action required
1-3mm	<u>Contractor Choice (either 1 or 2):</u> 1) Resin injection to ensure a good bond for the cracked brick to work as a single unit after repair. 2) Carefully cut out and replace individual bricks.
3-5mm	Carefully cut out and replace individual bricks.

FOR APPROVAL

02	11-08-16	Revised as per C.W. comments	AA	PS
01	04-08-16	Revised as per A.P. comments	AA	PS
00	29-07-16	Issued for Approval	LD	PS
REV	DATE	AMENDMENT	BY	CHK APPR

COPYRIGHT © KASHEC 2004

KASHEC HOUSE
 MARKET HILL, ROYSTON
 HERTFORDSHIRE SG8 9JN UK
 TEL: +44 (0) 01763 247131
 FAX: +44 (0) 01763 247029

PROJECT
11 PRINCE ALBERT ROAD

CLIENT
HARRISON VARMA

TITLE
EXTERNAL CRACKS REMEDIAL WORKS, REAR ELEVATION

DRAWN LD	CHECKED PS	APPROVED PS	DATE 08-07-16	SCALE AS SHOWN
-------------	---------------	----------------	------------------	-------------------

DRG. NO. K1914/14

REVISION
02