

Ronnie Lancaster <ronnie@lbhgeo.co.uk> 
To: "g.starling@elliottwood.co.uk" <g.starling@elliottwood.co.uk>
Cc: Darcy Kitson-Boyce <darcy@lbhgeo.co.uk>
Hexagon - Ground Movement Query

13 July 2016 09:12

1 Attachment, 18 KB

Hi Graham,

I can confirm that No. 6 Hexagon was not assessed for the purpose of ground movement as it is located approximately 8.5m away from the proposed basement excavation and is not located upslope of the excavation.

Additionally, on the basis of No. 5 Hexagon being assessed as Burland Category 0, it may be expected that the proposed basement will not cause significant ground movement to No. 6 Hexagon.

Kind Regards,

Kind Regards,

Ronnie Lancaster
BSc (Hons) FGS

T: 01280 812310 | www.LBHgeo.co.uk

