




TYPE P3, P3M Independent Wall Lining

Scale 1:10@A1






TYPE P5 & P5M SVP Boxing Scale 1:10@A1




TYPE P8 P8M
Scale 1:10@A1


Independent Wall Lining with Cavity Drain



TYPE P40 & P40M To Boxings / False Walls Scale 1:10@A1




TYPE P41 & P41M Sacrificial Wall Scale 1:10@A1



RC concrete (density 2200

PLAN DETAIL



BASE DETAIL (Upper Levels)

TYPE P45 & P45M Lining to RC, blockwork scale 1:10@A1 columns, walls

Finishes Legend :

External and Separating Wall Lining Types:

Type P3. Independant Wall Lining - Gyplyner IWL at 600mm centres with 1 layer of 15mm British Gypsum Gyproc SoundBloc. Fully filled with unfaced mineralwool with min. density 10kg/m3 between studs. All joints to be taped and jointed, giving a smooth and seamless finish, ready for decoration.

Type P3M. As type P3, but with outer layer replaced with 15mm Gyproc SounBloc Moisture Resistant plasterboard ('wet' side).

Type P4. Thermal Lining to existing walls - Gyplyner GL1 at 600mm centres (offset 75mm) (packed with 50mm Kooltherm K12 board - insulation notched where required) with 32.5mm Kooltherm K118 (20mm rigid insulation with 12.5mm Plasterboard with integrated VCL). All joints to be taped and jointed, giving a smooth and seamless finish, ready for decoration.

Type P4M. As type P4, but with outer layer replaced with 15mm Gyproc Wallboard Moisture Resistant plasterboard ('wet' side).

Type P5 & P5M. SVP Boxing. 2 no. layers 15mm SoundBloc plasterboard, on 60mm Gypframe studwork generally to svp casings. All joints to be taped and jointed, giving a smooth and seamless finish, ready for decoration. Pipework to be wrapped in 50mm unfaced mineral wool. NB. 15mm Moisture Resistant Soundblock MR to replace outer layer of boxing in 'Wet' areas (Bathrooms, WCs, Utility Cupboards, Kitchens, etc). Boxings to be fully filled with insulation when adjoining solid party walls.

Type P8. Thermal Independant Wall Lining - Drained cavity wall - Gyplyner IWL at 600mm centres with 1 layer of 15mm British Gypsum Gyproc Wallboard on 92 I studs. Fully filled with unfaced mineralwool. Density 10kg/m3 between studs, cavityAll joints to be taped and jointed, giving a smooth and seamless finish, ready for decoration.

Type P8M. As type P8, but with outer layer replaced with 15mm Gyproc Wallboard Moisture Resistant plasterboard ('wet' side).

Internal Linings & Boxing Types:

Type P40. Typical Boxing and False Wall - 70mm Gypframe 'C' studs at max. 600mm centres with 1 layer of 12.5mm British Gypsum Wallboard to one side. All joints to be taped and jointed, giving a smooth and seamless finish, ready for decoration.

Type P40M. As type P40 but with the layer of Plasterboard replaced with Gyproc Moisture Resistant plasterboard to 'wet'

Type P41. Typical Sacrificial Wall - Gyplyner GL1 with offset of 35mm at 600mm centres (GL2 fixing brackets) with 1 layer of 12.5mm British Gypsum wallboard. All joints to be taped and jointed, giving a smooth and seamless finish, ready for

Type P41M. As type P41 but with the layer of Plasterboard replaced with Gyproc Moisture Resistant plasterboard to 'wet'

Type P45 - Typical Lining to RC, blockwork columns, walls - 12.5mm Gyproc SoundBloc on dabs. All joints to be taped and jointed, giving a smooth and seamless finish ready for decoration.

Type P45M - As type P45 but with outer layer replaced by 12.5mm SoundBloc MR Board on dabs. All joints to be taped and jointed, giving a smooth and seamless finish ready for decoration.

Type P48. Plaster Repair to existing Walls.

PLANNING

DIMENSION AT ORIGINAL SHEET SIZE

KEY PLAN

drawing: 9000-DRG-11GN-DE001

Timber studs to door opening within partitions.

Contractors must check all dimensions on site. Only figured dimensions are to be worked from. Discrepancies must be reported to the Architect before proceeding. This drawing is Copyright


Floor build-ups may vary depending on the location. Basement and Ground

Floor accommodation will have different floor build-up which derives from

the u-value and waterproofing requirements. For floor build-ups refer to the

Putty Pads for electrical sockets / radiator pipe drop detail within Party wall

For access panel detail refer to British Gypsum Standard ceiling Gyproc





CLIENT MOUNT ANVIL LTD



PROJECT
KIDDERPORE AVENUE

DRAWING
Generally Applicable
Dry Lining Details

SCALE	1:10 @ A1	DATE
		October 2016
DRAWING No.		DRAWN BY
15 230 9000-DRG-00GN-DE930		KrC
		REV
		-

A&Q PARTNERSHIP (LONDON) LTD
THE LUX BUILDING, 2-4 HOXTON SQUARE, LONDON N 1 6 NU
Tel: 020 7613 2244 Fax: 020 7613 2642 Email:london@aqp.co.uk
ARCHITECTURE DESIGN MASTERPLANNING INTERIORS