

Detail 3 Typical Underpinning Detail scale 1 : 25

General Notes

- Drawings shall be referred to for structural work only unless otherwise stated and read in conjuction with Architect's, Service Engineer's and Sub-Contractor's drawings.
- 2. The Contractor shall check all levels and dimensions, any errors or omissions are to be reported at once to the Engineer.


CONTRACTOR TO PROVIDE ALTERNATIVE PRICE WHICH EXCLUDES COMPACTION OF EXISTING SUB-GRADE BUT INCLUDES 2nd LAYER OF A393 BOTTOM MAT REINFORCEMENT TO R.C SLAB.

Existing Basement Level.

## /-150thk. Ground bearing slab with A393 mesh

\_\_\_\_

Finishes to architect's Reinforcement. specification. (Nominal 25mm cover top and bottom). \_\_\_\_\_



DPM to Architects details. —150 min Type 1 Sub Base-material rolled and compacted.

 Existing Sub -Grade proof rolled to achieve 2% CBR. Soft spots removed and any deleterious material to be removed and backfilled with Type 1 graded fill.

NOTE S.S.L.'s (STRUCTURAL SLAB LEVEL) ARE INDICATIVE. T.B.C. BY ARCHITECT.

NOTE WATERPROOFING STRATEGY TO BE CONFIRMED BY OTHERS.

