

LONDON BOROUGH OF CAMDEN

ACCESS COMMENTS

From: Philippa Jackson
Tel. number: 020 7974 2305
Ref: 2016/6132/P
Date: 15th November 2016

To: Oluwaseyi Enirayetan

Re: 20a Hilltop Road , LONDON , NW6 2PY

The steps are not uniform and so do not meet Approved Document M (AD M) volume 1 1.8a.

The steps do not appear to have a suitable tread nosing. (AD M vol 1 1.8b)

Whilst the saps are wider than the current provision; they do not meet AD M vol 1 1.8d in terms of width.

A handrail should be provided on one side. (AD M vol 1 1.8f)