

Development Control Planning Service
London Borough of Camden
Camden Town Hall
Argyle Street
London WC1H 8EQ

Fao Mathias Gentet

25 November 2016

Dear Mathias

Flat 3 145 West End Lane London NW6 2PH

Thank you for your email

The terrace roof will be constructed from the existing joists up:-

12mm WPB Plywood fixed to the existing floor joists
100mm rigid Insulation
Torched roofing felt turned up the walls 150mm with lead flashings
Soft felt separating protection blanket
Hardwood decking on battens

This will provide excellent sound and thermal insulation.

With best wishes

Peter Bell