



T1 = TIMBER STUD PARTITIONS PAINT FINISH (150mm)
 min. 43dB rated acoustic partition to be constructed by
 50x100 C6 timber stud at 350c/c with two layer of 12.5mm
 Gyproc SoundBloc
 RAPID boards each side and
 50mm ROCKWOOL FLEXI Insulation between studs.
 Allow to prepare for decoration each side.

T2 = TIMBER STUD PARTITIONS PAINT AND TILE FINISH
 (168mm) 43dB rated acoustic partition to be constructed by
 50x100 C6 timber stud at 350c/c with one layer of 18mm
 plywood boards at wet-room side and two layer of 12.5mm
 Gyproc SoundBloc RAPID boards at the other side
 timber studs and 50mm ROCKWOOL FLEXI insulation
 between studs. Allow for waterproofing lining boards in
 preparation for tile finish at wet-roomside and allow for
 decoration on other side.

| | | | | | | | | | |
|-----------------|------|--------------|-------------|---------|---------------|-------------|----------|---|---|
| CLIENT: | | PROJECT: | | SCALE: | DESIGN/DRAWN: | CHECKED: | DATE: | © Copyright to all designs, notes and drawings remains with P-U-R-A LTD subject to written authorisation. • All dimensions in mm, unless noted otherwise. • All dimensions and levels to be checked on site. Their accuracy cannot be guaranteed and therefore cannot be used for fabrication, manufacture or construction. • Contractor to verify and to be responsible for all equipments and resistances due to local rules. Contractor to report if there is any discrepancy in the drawings to P-U-R-A LTD in time to specify alternatives. • This drawing is to be read together with all other relevant drawings. • Do not scale from this drawing. | P-U-R-A Ltd 36 Gloucester Avenue, Finsrose Hill NW11 7BB - LONDON info.uk@p-u-r-a.com www.p-u-r-a.com +44-(0)2072 849 753 |
| REV | DATE | BY | DESCRIPTION | CH | CH | CH | 05.01.16 | | |
| DRAWING STATUS: | | P-U-R-A, LTD | | FORMAT: | PROJECT No: | DRAWING No: | REV: | | |
| | | INFORMATION | | A3 | 0995 | 80-100 | C | | |

