



- All dimensions to be checked on site.
- Do not scale from this drawing
- Report any discrepancies and omissions to Llewelyn Davies Weeks Ltd
- All dimensions are shown in mm unless otherwise stated
- Refer to drawing issue sheet for purpose of issue
- If in doubt ask
- This drawing is Copyright © Llewelyn Davies Weeks Ltd

Notes
Secondary framing for ductwork will be designed by Bigfoot Systems or similar approved, and therefore is not shown on this drawing.

All roof plant to be grey powder coated unless noted otherwise.

LEGEND:

- XXXX Cross-hatch denotes extent of acoustic screens referred to in Temple Group Noise Assessment Report consisting of:
New powder coated metal framed min. 5mm thick glazed toughened glass outer acoustic screen to match colour of existing awning and cladding.
Where screens cross over roofing between parapets min. 3mm thick glazed acrylic to be used in lieu of toughened glass for ease of site cutting.
On noise source side of screen 50mm thick Quietstone or similar approved absorbent fire resisting weatherproof lining to be fitted to back of outer screen leaving no air gaps.

No.	Description	Date	By
P4	For approval.	16.11.30	JD
P3	For information only	16.10.21	JD
P2	For information only	16.10.06	YC
P1	For information only	16.10.06	YC

Structural Consultant	Services Consultant
AECOM	ARUP
Project Manager	Cost Consultant

Project Title
The Liver Institute
69-75 Chenies Mews, London
WC1E 6HX

Client
University College London Hospitals Charity (UCLHC)

Drawing Title
Proposed Section B

Drawing number	Revision
CM_P_S_02	P4

Scale @ A3
1:100

Drawn
YC

Date
2016.10.05