

APPENDIX H

Geotechnical test results

INDEX PROPERTIES AND WATER CONTENTS

BS 1377 : Part 2 : 1990

Report Ref	T16/1614	Contract	Centric House, Camden
-------------------	----------	-----------------	-----------------------

BH No.	Sample		Water Content W %	Liquid Limit W _L %	Plastic Limit W _p %	Plasticity Index IP %	% Passing 425 Micron Sieve	Corrected Plasticity Index IP _c %	Clay Fraction %	Colloidal Activity A	Soil Classification	Remarks
	Depth m	Description										
WS02	4.70	Brown clay	30.0	73	25	48	100	48			CV	
WS03	3.70	Brown clay	33.2	86	23	63	100	63			CV	
WS04	3.40	Grey-brown clay, with occasional black flecking	32.3	59	21	38	100	38			CH	
KEY: Soil Type: C - Clay M - Silt S - Sand O - Organic Plasticity: L - Low I - Intermediate H - High V - Very High E - Extremely High												



ALBURY S.I. LTD Miltons Yard, Petworth Road, Witley, Surrey GU8 5LH