

# 1 CHAMBERLAIN STREET, LONDON

## NOISE IMPACT ASSESSMENT

Report **11717-NIA-01**

Prepared on 25 November 2016

Issued For:

**Chiara Sapienza**

**Unit 1, Primrose Mews**

**Sharpleshall Street**

**London NW1 8YW**

## Contents

---

1.0	INTRODUCTION .....	1
2.0	SITE DESCRIPTION .....	1
3.0	ENVIRONMENTAL NOISE SURVEY .....	1
3.1	Procedure .....	1
3.2	Equipment .....	2
4.0	RESULTS.....	2
5.0	NOISE CRITERIA .....	3
6.0	DISCUSSION .....	3
6.1	Proposed Installation .....	3
6.2	Proposed Mitigation Measures .....	4
6.3	Noise Impact Assessment.....	4
6.4	British Standard Requirements .....	5
7.0	CONCLUSION .....	6

## List of Attachments

---

11717-SP1	Indicative Site Plan
11717-TH1	Environmental Noise Time History
Appendix A	Glossary of Acoustic Terminology
Appendix B	Acoustic Calculations

## 1.0 INTRODUCTION

---

Clement Acoustics has been commissioned by Chiara Sapienza to measure existing background noise levels at 1 Chamberlain Street, London NW1 8XB. The measured noise levels have been used to determine noise emission criteria for a proposed plant installation in agreement with the planning requirements of the London Borough of Camden.

This report presents the results of the environmental survey followed by noise impact calculations and outlines any necessary mitigation measures.

## 2.0 SITE DESCRIPTION

---

Current proposals are to install a Mitsubishi MXZ-2C52VA air conditioning condenser unit on the roof of 1 Chamberlain Street at the rear facade.

The nearest identified receiver has been identified as a window to the rear of a property on Regents Park Road, approximately 5m from the proposed plant location. Locations are shown in attached site plan 11717-SP1.

## 3.0 ENVIRONMENTAL NOISE SURVEY

---

### 3.1 Procedure

Measurements were undertaken at one position as shown on indicative site drawing 11717-SP1. The choice of this position was based both on accessibility and on collecting representative noise data in relation to the site.

Continuous automated monitoring was undertaken for the duration of the survey between 16:00 on the 11 November and 05:00 on the 12 November 2016.

Weather conditions were generally dry with light winds, therefore suitable for the measurement of environmental noise.

Background noise levels at the monitoring positions consisted of road traffic noise from Chamberlain Street, Regents Park Road and other surrounding roads, during both installation and collection of equipment.

The measurement procedure generally complied with BS7445:1991. *Description and measurement of environmental noise, Part 2- Acquisition of data pertinent to land use.*

### 3.2 Equipment

The equipment calibration was verified before and after use and no abnormalities were observed.

The equipment used was as follows.

- 1 No. Svantek Type 977 Class 1 Sound Level Meter
- Norsonic Type 1251 Class 1 Calibrator

## 4.0 RESULTS

The  $L_{Aeq: 5min}$ ,  $L_{Amax: 5min}$ ,  $L_{A10: 5min}$  and  $L_{A90: 5min}$  acoustic parameters were measured at the location shown in site drawing 11717-SP1.

The measured noise levels are shown as a time history in Figure 11717-TH1, with ambient and background noise levels summarised in Table 4.1.

	Average ambient noise level	Minimum background noise level
	$L_{Aeq: 5min}$ dB(A)	$L_{A90: 5min}$ dB(A)
Daytime (07:00 - 23:00)	53 dB(A)	49 dB(A)
Night-time (23:00 - 07:00)	48 dB(A)	42 dB(A)

**Table 4.1: Minimum background noise levels**

## 5.0 NOISE CRITERIA

In this instance, the London Borough of Camden criteria for noise emissions are as follows:

*“The Council considers that for new developments involving noisy plant/equipment or other uses, design measures should be taken to ensure that noise levels predicted at a point 1 metre external to sensitive facades are at least 5dB(A) less than the existing background measurement (LA90) when the equipment is in operation. Where it is anticipated that equipment will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses in the noise (bangs, clicks, clatters, thumps), special attention should be given to reducing the noise levels from plant and equipment at any sensitive facade to at least 10dB(A) below the LA90 level.”*

It is understood that the proposed plant(s) will be used for residential purposes and could be operational at any time.

We therefore propose to set the noise criteria at 32 dB(A), the value 10 dB below the minimum measured background noise level during night time hours in order to present a robust assessment.

## 6.0 DISCUSSION

### 6.1 Proposed Installation

The proposed plant installation comprises the following:

- 1 No. Mitsubishi MXZ-2C52VA air conditioning condenser unit

Noise emissions for the proposed plant units, as provided by the manufacturer, are shown in Table 6.1. Loudest modes of operation have been used in order to present a robust worst case assessment.

Sound Pressure Levels (at 1 meters, dB) in each Frequency Band									
Unit	63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz	dB(A)
Mitsubishi MXZ-2C52VA	53	51	50	46	42	45	33	26	50

**Table 6.1: Manufacturer Noise Emissions Levels**

The proposed plant location is to the roof at the rear of the building which is shown on indicative site plan 11717-SP1.

The closest receiver has been identified as the window on the rear facade of a residential property on Regents Park Road which is a minimum of 5m from the proposed plant location.

## 6.2 Proposed Mitigation Measures

In order to meet the proposed criteria stated in Section 5.0, it is recommended that an enclosure is installed around the plant. The enclosure should provide sufficient attenuation to achieve a maximum sound pressure level of 46 dB(A) when measured at 1m in all directions. Based on the information provided, an enclosure meeting the sound reduction indices as stated in Table 6.2 should be suitable to achieve this.

Mitigation	Required Attenuation (dB) in each Frequency Band							
	63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz
Louvred Enclosure	1	1	2	6	11	10	9	8

**Table 6.2: Required Attenuation from Mitigation**

## 6.3 Noise Impact Assessment

Taking into account all necessary acoustic corrections, the resulting noise level at the identified residential windows would be as shown in Table 6.3. Detailed calculations are shown in Appendix B.

Receiver	Night Time Hours Criterion	Noise Level at Receiver (due to proposed plant)
Nearest Residential Property	30 dB(A)	32 dB(A)

**Table 6.3: Noise levels and criteria at noise sensitive receivers**

As presented in Table 6.3 and Appendix B, the proposed plant installation with acoustic enclosure would be expected to meet the requirements of the proposed criteria.

#### 6.4 British Standard Requirements

Further calculations have been undertaken to assess whether the noise emissions from the proposed plant unit would be expected to meet recognised British Standard recommendations, in order to further ensure the amenity of nearby noise sensitive receivers.

British Standard 8233:2014 '*Sound insulation and noise reduction for buildings – Code of Practice*' gives recommendations for acceptable internal noise levels in residential properties. Assuming worst case conditions, of the closest window being for a bedroom, BS8233:2014 recommends 30dB(A) as being acceptable internal resting/sleeping conditions during night-time.

With loudest external levels of 32 dB(A), the window itself would need to provide 1 dB attenuation in order for acceptable conditions to be met. According to BS8233:2014, a typical building facade with a partially open window offers 15 dB attenuation.

It can therefore be predicted that, in addition to meeting the requirements of the set criteria, the emissions from the proposed plant would be expected to meet the most stringent recommendations of the relevant British Standard, with neighbouring windows partially open. Predicted levels are shown in Table 6.4.

Receiver	Design Range – <i>For resting/sleeping conditions in a bedroom, in BS8233:2014</i>	Noise Level at Receiver (due to plant installation)
Inside Residential Window	30 dB(A)	17 dB(A)

**Table 6.4: Noise levels and criteria inside nearest residential space**

## 7.0 CONCLUSION

---

An environmental noise survey has been undertaken at 1 Chamberlain Street, London NW1 8XB. The results of the survey have enabled criteria to be set for noise emissions from the proposed plant units in accordance with the requirements of the London Borough of Camden.

A noise impact assessment has then been undertaken using manufacturer noise data to predict the noise levels, due to the proposed plant, at the nearby noise sensitive receivers.

Calculations show that noise emissions from the proposed plant units should meet the requirements of the London Borough of Camden with the recommended mitigation installed as stated herein.

Report by  
**Josie Nixon TechIOA**

Checked by  
**Duncan Martin MIOA**






# 1 Chamberlain Street, London

Environmental Noise Time History

11/11/2016 to 12/11/2016



## GLOSSARY OF ACOUSTIC TERMINOLOGY

### **dB(A)**

The human ear is less sensitive to low (below 125Hz) and high (above 16kHz) frequency sounds. A sound level meter duplicates the ear's variable sensitivity to sound of different frequencies. This is achieved by building a filter into the instrument with a similar frequency response to that of the ear. This is called an A-weighting filter. Measurements of sound made with this filter are called A-weighted sound level measurements and the unit is dB(A).

### **$L_{eq}$**

The sound from noise sources often fluctuates widely during a given period of time. An average value can be measured, the equivalent sound pressure level  $L_{eq}$ . The  $L_{eq}$  is the equivalent sound level which would deliver the same sound energy as the actual fluctuating sound measured in the same time period.

### **$L_{10}$**

This is the level exceeded for not more than 10% of the time. This parameter is often used as a "not to exceed" criterion for noise

### **$L_{90}$**

This is the level exceeded for not more than 90% of the time. This parameter is often used as a descriptor of "background noise" for environmental impact studies.

### **$L_{max}$**

This is the maximum sound pressure level that has been measured over a period.

### **Octave Bands**

In order to completely determine the composition of a sound it is necessary to determine the sound level at each frequency individually. Usually, values are stated in octave bands. The audible frequency region is divided into 10 such octave bands whose centre frequencies are defined in accordance with international standards.

### **Addition of noise from several sources**

Noise from different sound sources combines to produce a sound level higher than that from any individual source. Two equally intense sound sources operating together produce a sound level which is 3dB higher than one alone and 10 sources produce a 10dB higher sound level.

### Attenuation by distance

Sound which propagates from a point source in free air attenuates by 6dB for each doubling of distance from the noise source. Sound energy from line sources (e.g. stream of cars) drops off by 3dB for each doubling of distance.

### Subjective impression of noise

Sound intensity is not perceived directly at the ear; rather it is transferred by the complex hearing mechanism to the brain where acoustic sensations can be interpreted as loudness. This makes hearing perception highly individualised. Sensitivity to noise also depends on frequency content, time of occurrence, duration of sound and psychological factors such as emotion and expectations. The following table is a reasonable guide to help explain increases or decreases in sound levels for many acoustic scenarios.

Change in sound level (dB)	Change in perceived loudness
1	Imperceptible
3	Just barely perceptible
6	Clearly noticeable
10	About twice as loud
20	About 4 times as loud

### Barriers

Outdoor barriers can be used to reduce environmental noises, such as traffic noise. The effectiveness of barriers is dependent on factors such as its distance from the noise source and the receiver, its height and its construction.

### Reverberation control

When sound falls on the surfaces of a room, part of its energy is absorbed and part is reflected back into the room. The amount of reflected sound defines the reverberation of a room, a characteristic that is critical for spaces of different uses as it can affect the quality of audio signals such as speech or music. Excess reverberation in a room can be controlled by the effective use of sound-absorbing treatment on the surfaces, such as fibrous ceiling boards, curtains and carpets.

## APPENDIX B

11717

1 Chamberlain Street, London

### EXTERNAL PLANT NOISE EMISSIONS CALCULATION

Receiver: Nearest Residential Receiver

Source: Proposed plant installation

	Frequency, Hz								dB(A)
	63	125	250	500	1k	2k	4k	8k	
Manufacturer provided sound pressure level at 1 metre Mitsubishi MXZ-2C52VA	53	51	50	46	42	45	33	26	50
Correction for reflections, dB	3	3	3	3	3	3	3	3	
Distance correction to receiver, dB (5m)	-14	-14	-14	-14	-14	-14	-14	-14	
Mitigation Provided by acoustic enclosure	-1	-1	-2	-6	-11	-10	-9	-8	
Sound pressure level at receiver	41	39	37	29	20	24	13	7	32

Design Criterion	32
------------------	----

### BS 8233 ASSESSMENT CALCULATION

Receiver: Inside Nearest Residential Window

Source: Proposed plant installation

	Frequency, Hz								dB(A)
	63	125	250	500	1k	2k	4k	8k	
Sound pressure level outside window	41	39	37	29	20	24	13	7	32
Minimum attenuation from partially open window, dB	-15	-15	-15	-15	-15	-15	-15	-15	
Sound pressure level inside nearest noise sensitive premises	26	24	22	14	5	9	-2	-8	17

Design Criterion	30
------------------	----