

1 November 2016

Camden Council
5 Pancras Square
London
N1C 4AG

For the attention of Caroline Birchall, Nature Conservation Officer

Re: Fitzjohns Avenue, Hampstead

Further to your recent correspondence regarding the concerns specifically around the proposed light fittings illuminating the trees along the north wall of the rear garden (type XS1), we can confirm that these fittings will provide between 2600 lux at 2 meters from the fitting to 418 lux at 5 meters from the fitting at full brightness. As per our specification they are fully adjustable and will be directed away from the boundary condition as required.

Our Client has confirmed that adjustability of these fittings is something that they propose to make use of for this reason, to avoid any undue negative light spill that may impact the flight path of local species. The external lighting will be turned off at 11pm on the courtyard garden side manually or by the timer to avoid any unnecessary light pollution on the boundary.

Should you have any further questions please do not hesitate to contact us.

Best Regards,



Justyna Staniewska
For and on behalf of
illuminationworks Ltd