

Acoustic assessment of proposed new mechanical services equipment serving 52 Lambs Conduit Street, London

Report Reference: 161207-002B

Date: January 2017

ACA Acoustics Limited

South West Office:
Regus House
Windmill Hill Business Park
Whitehill Way
Swindon
SN5 6QR

London Office:
Hamilton House
Mabledon Place
London
WC1H 9BB

Email: info@aca-acoustics.co.uk

Website: www.aca-acoustics.co.uk

Site Address: 52 Lamb's Conduit St
Camden Town
London
WC1N

Client: Firstplan

Report Reference: 161207-002

| Revision: | Description: | Revision Date: | Author: |
|-----------|---------------------------------|----------------|----------------------------|
| A | First issue | January 2017 | Tommy Burn BSc(hons) AMIOA |
| B | Second issue – Minor amendments | January 2017 | Tommy Burn BSc(hons) AMIOA |

This report has been prepared by ACA Acoustics Limited (ACA) with all reasonable skill, care and diligence in accordance with generally accepted acoustic consultancy principles and taking account of the services and terms agreed between ACA and our client. Any information provided by third-parties and referred to herein may not have been checked or verified by ACA unless expressly stated otherwise. This report is confidential to the client and ACA accepts no responsibility whatsoever to third parties unless formally agreed by ACA. Any such party relies upon the report at their own risk.

CONTENTS

| | |
|--|----|
| 0. SUMMARY | 3 |
| 1. INTRODUCTION | 4 |
| 2. LONDON BOROUGH OF CAMDEN COUNCIL PLANNING CONSENT ACOUSTIC REQUIREMENTS | 5 |
| 3. REVIEW OF SITE LOCATION & DEVELOPMENT PROPOSALS | 6 |
| 4. BACKGROUND SOUND LEVEL SURVEY | 7 |
| 4.1 Sound Level Survey Measurement and Assessment Procedure..... | 7 |
| 4.2 Instrumentation | 7 |
| 4.3 Sound Level Survey Measurement Results..... | 7 |
| 5. SOUND LEVELS FROM NEW MECHANICAL SERVICES EQUIPMENT | 9 |
| 6. VIBRATION FROM MECHANICAL EQUIPMENT..... | 10 |
| 7. RECOMMENDATIONS FOR NOISE CONTROL TREATMENTS | 11 |
| APPENDIX A..... | A1 |
| APPENDIX B..... | A2 |

0. SUMMARY

- ACA Acoustics Limited have been commissioned by the client to assess noise emissions from proposed mechanical equipment associated with a new commercial property at 52, Lambs Conduit Street, London.
- The assessment is required in order to provide evidence that noise emissions from the equipment will not be detrimental to the amenity of nearby residential properties and complies with the requirements of London Borough of Camden Council. London Borough of Camden Council's requirement, applicable at this site, is that noise from the equipment shall not exceed 10dB below the existing background LA90 outside nearby noise-sensitive properties.
- A survey has been carried out in the vicinity to establish existing background sound levels. Lowest background sound levels during the proposed operating times of the new equipment were measured at LAF90 37dB to outside the closest noise-sensitive properties. Based on results of the sound level survey and London Borough of Camden Council's requirement, the overall noise limit for the equipment to outside nearest noise-sensitive windows is set at $\leq 27\text{dBA}$.
- Calculated sound levels from the proposed equipment to outside the nearest residential properties, including benefit of acoustic treatment detailed within this report, are LAeq 26dB at the windows overlooking the equipment, therefore achieving London Borough of Camden Council's requirements. Noise from the equipment should not be detrimental to the amenity of residential occupiers in the vicinity. The assessment includes benefit of noise control treatments as set out in this report.
- The mechanical equipment will not be directly structurally linked to adjoining non-associated properties however it is advised that the equipment is installed on high-performance vibration isolators. Details of suitable isolators are included in this report.

1. INTRODUCTION

New mechanical equipment is to be installed at 52, Lambs Conduit Street, London to serve a new commercial property.

The Planning Department of London Borough of Camden Council requires information in the form of an acoustic report regarding noise from the proposed new equipment. The report is required to demonstrate that the equipment will comply with London Borough of Camden Council's acoustic requirements applicable for mechanical services equipment affecting nearby noise-sensitive properties.

ACA Acoustics Limited has been commissioned by the client to carry out an assessment of noise from the equipment and, where necessary, make recommendation to reduce noise and vibration levels to ensure that the amenity of the adjoining residential properties is not compromised.

This report presents results of the noise survey and assessment and includes:

- Review of London Borough of Camden Council's noise-related planning requirements;
- Measurement of existing background sound levels;
- Calculation of proposed equipment sound levels;
- Review of any noise/vibration control treatments necessary to the equipment to ensure compliance with the requirements of London Borough of Camden Council.

2. LONDON BOROUGH OF CAMDEN COUNCIL PLANNING CONSENT ACOUSTIC REQUIREMENTS

London Borough of Camden Council's policies relating to noise from new mechanical services equipment are contained within the Council's Local Development Framework; Policy DP28.

In Summary, London Borough of Camden's noise-related conditions are:

| Noise level from plant and machinery at which planning permission will not be granted: | |
|---|--------------|
| Noise at 1m external to a sensitive façade; | 5dBA < LA90 |
| Noise that has a distinguishable discrete continuous note (whine, hiss, screech, hum) at 1m external to a sensitive façade; | 10dBA < LA90 |
| Noise that has distinct impulses (bangs, clicks, clatters, thumps) at 1m external to a sensitive façade; | 10dBA < LA90 |
| Noise at 1m external to sensitive façade where LA90 > 60dB | 55dB LAeq |

Table 1: London Borough of Camden Council noise-related planning conditions

Each of the above is applicable over a period of 60 minutes and measured at 1m external to noise-sensitive facades.

The characteristic of noise from the condensing units would typically be described as having distinct impulses as the units power on and off as required by the load on the system. Therefore to ensure that the assessment is robust and that the amenity of nearby occupiers is not detrimentally affected, the more onerous noise condition of 10dBA below the existing background noise is used for the assessment in this report.

3. REVIEW OF SITE LOCATION & DEVELOPMENT PROPOSALS

The development site is at 52, Lambs Conduit Street, London. 52, Lambs Conduit Street is a 4 storey development. The proposed development incorporates a shop to the ground floor and basement level. Existing residential flats are situated at first, second, and third floor level.

New mechanical services equipment is to be installed at rear ground floor level This will include two condensing units only.

The closest noise-sensitive window has been identified by the author as first floor flats above 52 Lambs Conduit Street.

Lambs Conduit Street is a moderately busy street; however the location of the proposed equipment is to the rear of the property and heavily screened from pedestrian and traffic noise. Windows overlooking the equipment are also screened, resulting in a low background sound level. Figure 1 shows aerial photo of the site, with the condensing unit location marked in red.



Figure 1 – Site location aerial photo

4. BACKGROUND SOUND LEVEL SURVEY

In order to assess noise from the mechanical services equipment it is necessary to establish representative background sound levels in the vicinity. Details of the background sound level survey carried out by ACA Acoustics Limited are provided in Sections 4.1 to 4.3 below.

4.1 Sound Level Survey Measurement and Assessment Procedure

The proposed equipment will operate until midnight.

A 24-hour unattended background survey was carried out at ground floor level, from Monday 12th to Tuesday 13th December 2016. The weather remained calm and dry over the period of the proposed equipment's operation.

4.2 Instrumentation

The following equipment was used during the sound level survey; the sound level meter was calibrated before the survey, and checked after, with no change noted:

| Equipment | Serial Number |
|--|---------------|
| Rion sound level meter type NL-31 Class 1 complete with weatherproof and lockable outdoor environmental kit | 00431030 |
| NTi Audio calibrator type CAL200 94/114dB. Compliant to IEC 60942-1:2003 (Calibrated to a reference traceable to NIST) | 11441 |

Table 2: Equipment used

4.3 Sound Level Survey Measurement Results

The lowest measured background sound level during operating times of the equipment was LAF90 37dB. Full results are shown in graphical form in Figure 2 and in tabular form in Table 3 below.

| Description | Lowest measured LAF90 |
|---|-----------------------|
| Monday 12 th to Tuesday 13 th December 2016 | 37dBA |

Table 3: Summary sound level survey results




Figure 2: Sound level survey results

From the results shown in Figure 2 it can be seen the measured background sound level remains fairly constant, fluctuating only a small amount over the proposed equipment operating time. The values recorded by ACA Acoustics Limited are used as basis for acoustic design such that sound levels from the proposed new equipment are ≤ 27 dBA outside the closest noise sensitive residential windows.

5. SOUND LEVELS FROM NEW MECHANICAL SERVICES EQUIPMENT

The development includes the installation of two condensing units.

A computer model has been used to calculate the noise contribution from the equipment to outside nearest noise-sensitive windows. The model incorporates environmental corrections set out in ISO 9613-2:1996.

Table 4 shows the proposed items of mechanical equipment to be installed, along with calculated sound levels at the nearest residential receivers with benefit of acoustic treatment as provided in Section 7. Cumulative levels of the equipment at the nearest residential receivers are shown in Table 5.

| Item | Make/Model | Reference | Equipment sound power level Source: Manufacturers data L _w (dBA) |
|-----------------|----------------------|-----------|---|
| Condensing Unit | Mitsubishi FDC100VNX | CU1 | 66 |
| Condensing Unit | Mitsubishi FDC100VNX | CU2 | 66 |

Table 4: Manufacturers equipment sound power levels

The cumulative calculated sound level from the proposed equipment, including benefit of acoustic treatment detailed within Section 7, to outside the noise sensitive residential window compared with the planning requirement is shown in Table 5. Summary print-outs from the calculation models are included in Appendix A.

| Description | Calculated Equipment Sound Levels | London Borough of Camden Noise Limit |
|------------------------------|--------------------------------------|---|
| Closest residential property | 26dBA | ≤ 27dBA |

Table 5: Calculated cumulative equipment sound levels at 1m outside noise-sensitive windows

Table 5 shows that the overall sound level from the equipment does not exceed a level 10dB below the lowest measured background sound level to outside the closest residential property. Resultant noise from the equipment will not be disturbing or detrimental to the amenity of nearby residential occupants. The calculation includes benefit of noise control treatments to the new equipment. Details of the noise control treatments are provided in Section 7 below.

6. VIBRATION FROM MECHANICAL EQUIPMENT

The proposed condensing units are directly structurally connected to the adjoining non-associated properties and so it is necessary to ensure structure-borne noise does not pass into the residential property. As a result, in order to prevent the units exceeding the maximum permissible limits it is recommended that all new equipment be installed on suitable vibration isolators.

To control the potential for vibration or vibration-induced noise transmitting to the premises, it is recommended that the condensers are installed on rubber or neoprene turret type mounts or pads providing a deflection of not less than 6mm at the working load.

The rubber turret type vibration isolators proposed are readily available from most acoustic hardware suppliers, including Allaway Acoustics Limited (Contact Chris Williams – Tel: 01992 550825).

7. RECOMMENDATIONS FOR NOISE CONTROL TREATMENTS

Note that consideration of non-acoustic aspects such as structural, visual, airflow and construction material are outside the scope of ACA Acoustics Limited and should be considered by others accordingly.

Alternative methods of attenuation to those detailed below may be acceptable, for example relocation of noisy equipment to other, less sensitive, areas of the development. Full details of any alternative scheme, including working drawings and expected attenuation should be submitted and approved prior to manufacture.

It is recommended that the condensers are installed in a high-performance acoustic enclosure such as those supplied by Environ Technologies Limited or equal and approved. Acoustic performance of a suitable enclosure is shown in Appendix B.

Structural supports/steelwork and access panels or doors may be required and should be determined by the successful supplier accordingly.

APPENDIX A

Acoustic Calculations

Calculation Sheet

CU1 to 1st floor window

| | | Octave Band Centre Frequency (Hz) | | | | | | | |
|---|-----|-----------------------------------|-------------|-------------|-------------|-------------|-------------|--------------|--------------|
| | | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k |
| Noise Source | | | | | | | | | |
| Noise Source - CU1 | | | | | | | | | |
| Sound Power Levels | | 51.0 | 58.0 | 62.0 | 64.0 | 62.0 | 59.0 | 54.0 | 46.0 |
| Noise Control Treatments | | | | | | | | | |
| Treatment - High performance enclosure | | | | | | | | | |
| Attenuated Lw | | 37.0 | 42.0 | 39.0 | 34.0 | 25.0 | 20.0 | 16.0 | 7.0 |
| ISO 9613 Calculation | | | | | | | | | |
| Horiz. Distance (m) | 0.5 | | | | | | | | |
| Source Height (m) | 0.5 | | | | | | | | |
| Receiver Height (m) | 5.0 | | | | | | | | |
| Barrier - No Barrier | | | | | | | | | |
| Distance to Barrier (m) | - | | | | | | | | |
| Barrier Height (m) | - | | | | | | | | |
| Screening at (m) | - | | | | | | | | |
| Q Factor - Corner | | | | | | | | | |
| Direct Lp | | 24.9 | 29.9 | 26.9 | 21.9 | 12.9 | 7.8 | 3.7 | -5.6 |
| ISO 9613 Calculation - Reflections | | | | | | | | | |
| Type of Reflecting Surface - Walls with windows, recesses or bays | | | | | | | | | |
| Q Factor - Junction | | | | | | | | | |
| Source Height (m) | 0.5 | | | | | | | | |
| Reflecting Height (m) | 3.0 | | | | | | | | |
| Barrier - No Barrier | | | | | | | | | |
| Distance to Barrier (m) | - | | | | | | | | |
| Barrier Height (m) | - | | | | | | | | |
| Screening at (m) | - | | | | | | | | |
| Reflected Lp | | 0.0 | 12.5 | 9.4 | 4.4 | -4.6 | -9.6 | -13.9 | -23.8 |
| Cumulative Lp at Receiver | | | | | | | | | |
| External Receiver | | | | | | | | | |
| External Receiver - 1st floor window | | | | | | | | | |
| Sound Pressure, Lp: | | 24.9 | 30.0 | 27.0 | 22.0 | 12.9 | 7.9 | 3.8 | -5.6 |

Calculation Sheet

CU2 to 1st floor window

| | | Octave Band Centre Frequency (Hz) | | | | | | | |
|---|-----|-----------------------------------|------|------|------|------|------|-------|-------|
| | | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k |
| Noise Source | | | | | | | | | |
| Noise Source - CU2 | | | | | | | | | |
| Sound Power Levels | | 51.0 | 58.0 | 62.0 | 64.0 | 62.0 | 59.0 | 54.0 | 46.0 |
| Noise Control Treatments | | | | | | | | | |
| Treatment - High performance enclosure | | | | | | | | | |
| Attenuated Lw | | 37.0 | 42.0 | 39.0 | 34.0 | 25.0 | 20.0 | 16.0 | 7.0 |
| ISO 9613 Calculation | | | | | | | | | |
| Horiz. Distance (m) | 0.5 | | | | | | | | |
| Source Height (m) | 0.5 | | | | | | | | |
| Receiver Height (m) | 5.0 | | | | | | | | |
| Barrier - No Barrier | | | | | | | | | |
| Distance to Barrier (m) | - | | | | | | | | |
| Barrier Height (m) | - | | | | | | | | |
| Screening at (m) | - | | | | | | | | |
| Q Factor - Corner | | | | | | | | | |
| Direct Lp | | 24.9 | 29.9 | 26.9 | 21.9 | 12.9 | 7.8 | 3.7 | -5.6 |
| ISO 9613 Calculation - Reflections | | | | | | | | | |
| Type of Reflecting Surface - Walls with windows, recesses or bays | | | | | | | | | |
| Q Factor - Junction | | | | | | | | | |
| Source Height (m) | 0.5 | | | | | | | | |
| Reflecting Height (m) | 3.0 | | | | | | | | |
| Barrier - No Barrier | | | | | | | | | |
| Distance to Barrier (m) | - | | | | | | | | |
| Barrier Height (m) | - | | | | | | | | |
| Screening at (m) | - | | | | | | | | |
| Reflected Lp | | 0.0 | 12.5 | 9.4 | 4.4 | -4.6 | -9.6 | -13.9 | -23.8 |
| Cumulative Lp at Receiver | | | | | | | | | |
| External Receiver | | | | | | | | | |
| External Receiver - 1st floor window | | | | | | | | | |
| Sound Pressure, Lp: | | 24.9 | 30.0 | 27.0 | 22.0 | 12.9 | 7.9 | 3.8 | -5.6 |

Project Name 52 Lambs Conduit Street


Project Reference 161207

Reference 1st floor window

Description

Noise Limit -

dBA 26



Noise Sources

| Reference | Quantity | Noise Levels (dB) | | | | | | | |
|-----------|----------|-------------------|-----|-----|-----|------|-----|-----|------|
| | | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k |
| CU1 | 1 | 24.9 | 30 | 27 | 22 | 12.9 | 7.9 | 3.8 | -5.6 |
| CU2 | 1 | 24.9 | 30 | 27 | 22 | 12.9 | 7.9 | 3.8 | -5.6 |

161207-ER-1A

ACA Acoustics Limited

London Office: Hamilton House, Mabledon Place, London, WC1H 9BB

South West Office: Regus House, Windmill Hill Business Park, Whitehill Way, Swindon, SN5 6QR

Tel: 02075 548 567 Fax: 02075 548 501

Tel: 01793 441 488

w: www.aca-acoustics.co.uk

APPENDIX B

Typical Noise Control Treatments



52 Lambs Conduit Street

Schedule of Noise Control Treatments

| Reference | Description | Location | Pressure Drop (Pa) | Insertion Losses (dB) | | | | | | | |
|----------------------------|--------------------------------|----------|-----------------------|-----------------------|-----|-----|-----|----|----|----|----|
| | | | | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k |
| High performance enclosure | Environlite Acoustic Enclosure | | | 14 | 16 | 23 | 30 | 37 | 39 | 38 | 39 |