

47 Doughty Street, WC1N 2LW  
BIA – Audit

			Impact on roadway and any utilities running beneath to be considered.	
8	Stability	Movement monitoring proposal not provided	Open - Outline proposal to be provided. Details and trigger levels to be agreed as part of Party Wall awards.	Closed