

Mr masoud parvardin
Archetype Associates
121 Gloucester Place
London
W1U 6JY

Application Ref: **2015/3004/P**
Please ask for: **David Peres Da Costa**
Telephone: 020 7974 **5262**

3 February 2017

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted Subject to a Section 106 Legal Agreement

Address:
36 Redington Road
London
NW3 7RT

Proposal:

Erection of 3-storey including basement 4-bed house, front and rear lightwell and associated landscaping following demolition of existing dwelling.

Drawing Nos: Site location plan; 1048 (10): 02 D; 03 E; 04 C; 05 C; 06 C; 07 C; 08 C; 09 F; 10 E; 1048 (00): 04; 03; 05

Addendum to Arboricultural Impact Assessment prepared by Landmark Trees dated 13th April 2016; Flood Risk Assessment dated March 2016; Letter from Zussman Bear dated 17th Dec 2015; Structural Engineering Report prepared by Zussman Bear dated May 2015; Letter from Southern Testing dated 8th Oct 2015; BIA prepared by Southern Testing dated May 2015; Arboricultural Impact Assessment prepared by Landmark Trees dated 27th May 2015; Design and Access Statement prepared by Archetype dated April 2015; Code for Sustainable Homes Pre-Assessment dated Nov 2010; Construction Method Statement dated May 2015; Planning Statement prepared by PDA.

The Council has considered your application and decided to grant permission subject to the following condition(s):



Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 The development hereby permitted shall be carried out in accordance with the following approved plans: Site location plan; 1048 (10): 02 D; 03 E; 04 C; 05 C; 06 C; 07 C; 08 C; 09 F; 10 E; 1048 (00): 04; 03; 05

Addendum to Arboricultural Impact Assessment prepared by Landmark Trees dated 13th April 2016; Flood Risk Assessment dated March 2016; Letter from Zussman Bear dated 17th Dec 2015; Structural Engineering Report prepared by Zussman Bear dated May 2015; Letter from Southern Testing dated 8th Oct 2015; BIA prepared by Southern Testing dated May 2015; Arboricultural Impact Assessment prepared by Landmark Trees dated 27th May 2015; Design and Access Statement prepared by Archetype dated April 2015; Code for Sustainable Homes Pre-Assessment dated Nov 2010; Construction Method Statement dated May 2015; Planning Statement prepared by PDA.

Reason: For the avoidance of doubt and in the interest of proper planning.

- 3 Detailed drawings, or samples of materials as appropriate, in respect of the following, shall be submitted to and approved in writing by the local planning authority before the relevant part of the work is begun:

a) Details including sections at 1:10 of all windows (including jambs, head and cill), external doors and gates;

b) Manufacturer's specification details of all facing materials including windows and door frames and cladding (to be submitted to the Local Planning Authority) and samples of those materials (to be provided on site) with a sample panel of not less than 1m by 1m demonstrating, the proposed colour, texture, face-bond and pointing of brickwork.

c) Details including sections and elevation drawings of boundary treatment and balustrades / railings around lightwells.

The relevant part of the works shall be carried out in accordance with the details thus approved and all approved samples shall be retained on site during the course of the works.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy CS14 of the London Borough of Camden Local Development Framework Core Strategy and policy DP24 and DP25 of the London Borough of Camden Local Development Framework Development Policies.

- 4 All units hereby approved shall be designed and constructed in accordance with Building Regulations Part M 4 (2).

Reason: To ensure that the internal layout of the building provides flexibility for the accessibility of future occupiers and their changing needs over time, in accordance with the requirements of policy CS6 of the London Borough of Camden Local Development Framework Core Strategy and policy DP6 of the London Borough of Camden Local Development Framework Development Policies.

- 5 Before the development commences, details of secure and covered cycle storage area for 2 cycles shall be submitted to and approved by the local planning authority. The approved facility shall thereafter be provided in its entirety prior to the first occupation of any of the new units, and permanently retained thereafter.

Reason: To ensure the development provides adequate cycle parking facilities in accordance with the requirements of policy CS11 of the London Borough of Camden Local Development Framework Core Strategy and policy DP17 of the London Borough of Camden Local Development Framework Development Policies.

- 6 Prior to the commencement of any works on site, details demonstrating how trees to be retained shall be protected during construction work shall be submitted to and approved by the Council in writing. Such details shall follow guidelines and standards set out in BS5837:2012 "Trees in Relation to Construction". These details should include a mitigation strategy for T5 and further investigation at the front of the site to identify any tree roots of T9 within the basement footprint.

All trees on the site, or parts of trees growing from adjoining sites, unless shown on the permitted drawings as being removed, shall be retained and protected from damage in accordance with the approved protection details.

Reason: To ensure that the development will not have an adverse effect on existing trees and in order to maintain the character and amenity of the area in accordance with the requirements of policy CS15 of the London Borough of Camden Local Development Framework Core Strategy.

- 7 Sustainable urban drainage:

A) Prior to commencement of development details of a sustainable urban drainage system shall be submitted to and approved in writing by the local planning authority. Such system shall be designed to accommodate all storms up to and including a 1:100 year storm with a 30% provision for climate change, and shall demonstrate that greenfield run off rates (5l/s) will be achieved.

B) Prior to occupation of the development, evidence that the sustainable drainage system has been implemented shall be submitted to the Local Authority and approved in writing. The systems shall thereafter be retained and maintained in accordance with the approved maintenance plan.

Reason: To reduce the rate of surface water run-off from the buildings and limit the impact on the storm-water drainage system in accordance with policies CS13 and CS16 of the London Borough of Camden Local Development Framework Core Strategy and policies DP22, DP23 and DP32 of the London Borough of Camden Local Development Framework Development Policies.

- 8 No impact piling until a piling method statement, prepared in consultation with Thames Water or the relevant statutory undertaker, detailing the depth and type of piling to be undertaken and the methodology by which such piling will be carried out including measures to prevent and minimise the potential for damage to subsurface water infrastructure, and the programme for the works, has been submitted to and approved in writing by the local planning authority. Any piling must be undertaken in accordance with the terms of the approved piling method statement.

Reason: To safeguard existing below ground public utility infrastructure and controlled waters in accordance with the requirements of policy CS13 of the London Borough of Camden Local Development Framework Core Strategy.

- 9 Notwithstanding the provisions of Article 3 of the Town and Country Planning (General Permitted Development) Order 2015 or any Order revoking and re-enacting that Order, no development within Part 1 (Classes A-H) [and Part 2 (Classes A-C)] of Schedule 2 of that Order shall be carried out without the grant of planning permission having first been obtained from the local planning authority.

Reason: To safeguard the visual amenities of the area and to prevent over development of the site by controlling proposed extensions and alterations in order to ensure compliance with the requirements of policies CS14 and CS5 of the London Borough of Camden Local Development Framework Core Strategy and policies DP24 and DP26 of the London Borough of Camden Local Development Framework Development Policies.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts which cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 6941).
- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Compliance and Enforcement team [Regulatory Services], Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 4444 or on the website <http://www.camden.gov.uk/ccm/content/contacts/council->

contacts/environment/contact-the-environmental-health-team.en or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.

- 3 You are advised that this proposal will be liable for the Mayor of London's Community Infrastructure Levy (CIL) and the Camden CIL as the additional floorspace exceeds 100sqm GIA or one unit of residential accommodation. Based on the Mayor's CIL and Camden's CIL charging schedules and the information given on the plans the charge is likely to be £9750 (195sqm x £50) for the Mayoral CIL and £97,500 (195sqm x £500) for Camden's CIL (Zone C Residential).

This amount is an estimate based on the information submitted in your planning application. The liable amount may be revised on the receipt of the CIL Additional Information Requirement Form or other changes in circumstances. Both CIL's will be collected by Camden after the scheme has started and could be subject to surcharges for failure to assume liability or submit a commencement notice PRIOR to commencement and/or for late payment. We will issue a formal liability notice once the liable party has been established. CIL payments will also be subject to indexation in line with the construction costs index.


- 4 Your attention is drawn to the fact that there is a separate legal agreement with the Council which relates to the development for which this permission is granted. Information/drawings relating to the discharge of matters covered by the Heads of Terms of the legal agreement should be marked for the attention of the Planning Obligations Officer, Sites Team, Camden Town Hall, Argyle Street, WC1H 8EQ.
- 5 You are reminded of the need to provide adequate space for internal and external storage for waste and recyclables. For further information contact Council's Environment Services (Waste) on 020 7974 6914/5 or see the website <http://www.camden.gov.uk/ccm/content/environment/waste-and-recycling/twocolumn/new-recycling-rubbish-and-reuse-guide.en>.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraphs 186 and 187 of the National Planning Policy Framework.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully



David Joyce
Executive Director Supporting Communities

