

[REDACTED]

From: belsize Conservation [REDACTED]
Sent: 11 February 2017 09:11
To: [REDACTED]
Cc: [REDACTED]
Subject: Re: Consultee letter for PlanningApplication Application: 2016/6919/P
Attachments: 6919.DOC

Follow Up Flag: Follow up
Flag Status: Flagged

OBJECT

Insufficient information.

Details needed of existing window frame for comparison with proposed frames.
We oppose the use of UPVC frames in the Conservation Area.
The block as a whole to be considered with refurbishments, not just piecemeal work to individual flats.

Eldred Evans
Chair
Belsize Conservation Area Advisory Committee Belsize - Elsworthy - Parkhill & Upper Park

NOTE

We were unable to reply to your notification by the use of our PIN number [which has now started to give us again access to the page dedicated for Conservation Groups] as you did not include a PIN number in your original notification dated 11th of January: see copy attached. and we are therefore submitting the comments of our committee via our website

Regards
Gian
BCAAC Admin

-----Original Message-----

From: Jones, Evelyn
Sent: Friday, January 06, 2017 9:57 AM

[REDACTED]
Subject: Consultee letter for PlanningApplication Application: 2016/6919/P

Please find attached Consultee letter for PlanningApplication application 2016/6919/P

[REDACTED]

This e-mail may contain information which is confidential, legally privileged and/or copyright protected. This e-mail is intended for the addressee only. If you receive this in error, please contact the sender and delete the material from your computer.