

Dempsey, Matthew


From: Jackson, Philippa
Sent: 08 February 2017 14:09
To: Dempsey, Matthew
Subject: RE: PODWORKS IN CAMDEN Planning/access officer requests

Follow Up Flag: Follow up
Flag Status: Flagged

Matthew
Just to confirm 1500mm shelf height is acceptable as per BS8300 Fig F.3.
Regards
Pip

Philippa Jackson
Access and Service Development Officer (Tuesday & Wednesday in office and Friday morning from home)

Telephone: 02079742305



From: Dempsey, Matthew
Sent: 08 February 2017 11:16
To: Miles Broe
Cc: admin@milesbroearchitects.co.uk
Subject: RE: PODWORKS IN CAMDEN Planning/access officer requests

Hi Miles,

Thanks for your amended drawings.

Please can I query the 'countdown timer' size as shown on pages 3 and 4 – The one currently at Russell Square would appear to be approximately this size and is clearly visible from outside the box, even across the road. We will need to condition the illumination level and would prefer it to be a lot smaller. Is it necessary for it to display time/numbering, i.e.) 00:00, when not in use?

Also; We require the shelving to be black the match the back plate and stool seat, so as to not stand out from a distance from the outside. I am sorry if this was not clear previously. It may also be necessary to condition the colour of the phone/ printer & scanner, so that these do not stand out. The examples shown are grey/ black which would be acceptable, but we would not want any garish or bright colours to replace these should they be upgraded at any point in the future.

And; if there is a proposed water cooler - it should be shown on the drawings. If not – it should be removed and any mention of 'tbc' should also be removed. There are some other items listed on Page 2 which I cannot identify on the plans? Where is the bin, the network controller, the router? Only items under consideration should be shown on the proposed plans.

Kind regards,
Matthew

Matthew Dempsey
Planning Technician

Telephone: 0207 974 3862



From 1 October 2016 you will not receive a letter from us if your neighbour submits a planning application. You can still find out about planning applications:

- on new improved posters on lamp posts
- by signing up to [planning e-alerts](#)
- in the planning section of the [Camden Account](#)
- through adverts in the Camden New Journal and Ham & High

You can [sign up](#) to our new and improved planning e-alerts to let you know about new planning applications, decisions and appeals.

From: Miles Broe [mailto:miles@milesbroearchitects.co.uk]
Sent: 07 February 2017 17:06
To: Dempsey, Matthew
Cc: admin@milesbroearchitects.co.uk
Subject: RE: PODWORKS IN CAMDEN Planning/access officer requests

Dear Matthew

Here are the revised Podworks designs; which I believe deal with your Heritage officer queries. Regarding the external fittings; they have to be fitted as shown for their locking and security requirements. They would also colour code the Russell square fittings retrospectively if preferred. You have the other written confirmations by previous email today.

The Lovefone drawings are also in hand incidentally.

Kind regards

Miles