

Application No:	Consultees Name:	Consultees Addr:	Received:	Comment:	Response:
2017/0808/L	Meredith Whitten	Covent Garden Community Association 42 Earlham Street WC2H 9LA	06/03/2017 00:44:16	COMMNT	The CGCA queries whether an acoustic report is needed. The proposed rear elevation shows three repositioned AC condenser units. However, the existing rear elevation shows only two units. Thus, there appears to be an additional AC condenser being proposed to be installed near a noise-sensitive window.
