

Mr Owen Lewis
Nicholas Lee Architects Ltd.
34A Rossllyn Hill
Hampstead
London
NW3 1NH

Application Ref: **2016/6928/P**
Please ask for: **Helaina Farthing**
Telephone: 020 7974 **3303**

21 March 2017

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Householder Application Granted

Address:
14 Rossllyn Hill
London
NW3 1PD

Proposal:
Installation of an external air-conditioning unit on the side elevation of the existing dwelling house at ground level (Class C3).
Drawing Nos: 1243/EP-001; 1243/EE-001; 1243/EE-002; 1243/AP-001; 1243/AE-001; 1243/AE-002; 1243/OS-001; Acoustic Assessment Report prepared by PC Environmental dated the 13th December 2016.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).



- 2 The development hereby permitted shall be carried out in accordance with the following approved plans 1243/EP-001; 1243/EE-001; 1243/EE-002; 1243/AP-001; 1243/AE-001; 1243/AE-002; 1243/OS-001; Acoustic Assessment Report prepared by PC Environmental dated the 13th December 2016.

Reason: For the avoidance of doubt and in the interest of proper planning.

- 3 The external noise level emitted from plant, machinery or equipment at the development with specified noise mitigation hereby approved shall be lower than the lowest existing background noise level by at least 5dBA, by 10dBA where the source is tonal, as assessed according to BS4142:2014 at the nearest and/or most affected noise sensitive premises, with machinery operating at maximum capacity.

Reason: To ensure that the amenity of occupiers of the development site/ surrounding premises is not adversely affected by noise from mechanical installations/ equipment.

- 4 Prior to use, plant or equipment and associated ducting at the development shall be mounted with proprietary anti-vibration isolators and fan motors shall be vibration isolated from the casing and adequately silenced and maintained as such.

Reason: To ensure that the amenity of occupiers of the development site and surrounding premises is not adversely affected by vibration.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts which cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 6941).
- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Compliance and Enforcement team [Regulatory Services], Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 4444 or on the website <http://www.camden.gov.uk/ccm/content/contacts/council-contacts/environment/contact-the-environmental-health-team.en> or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.
- 3 Camden Local Plan Submission Draft 2016: The emerging Camden Local Plan is reaching the final stages of its public examination. Consultation on proposed modifications to the Submission Draft Local Plan began on 30 January and ends on 13 March 2017. The modifications have been proposed in response to


Inspector's comments during the examination and seek to ensure that the Inspector can find the plan 'sound' subject to the modifications being made to the Plan. The Emerging Local Plan at this stage is a material consideration in decision making, but pending publication of the Inspector's report into the examination only has limited weight.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraphs 186 and 187 of the National Planning Policy Framework.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully

A handwritten signature in black ink that reads "David T. Joyce". The signature is written in a cursive, slightly slanted style.

David Joyce
Director of Regeneration and Planning