

Room	Window	Room Use	Flat Number	Orientation	Window									Room						
					Existing		Proposed		Winter Loss	Annual Loss	Winter %Loss	Annual %Loss	Pass/Fail	Existing		Proposed		Winter %Loss	Annual %Loss	Pass/Fail
					Winter APSH	Annual APSH	Winter APSH	Annual APSH						Winter APSH	Annual APSH	Winter APSH	Annual APSH			
<b>1A PHOENIX STREET (NO RIGHTS OF LIGHT)</b>																				
R2/1699	W2/1699	BEDROOM		150	1	2	1	1	0	1	0.00	50.00	PASS	1	2	1	1	0.0	50	PASS
R3/1699	W3/1699	BEDROOM		150	1	3	1	2	0	1	0.00	33.33	PASS	1	3	1	2	0.0	33	PASS
R4/1699	W4/1699	BEDROOM		151	0	0	0	0	0	0	0.00	0.00	PASS	0	0	0	0	0.0	0	PASS
R5/1699	W5/1699	BEDROOM		150	0	0	0	0	0	0	0.00	0.00	PASS	0	0	0	0	0.0	0	PASS
R6/1699	W6/1699	BEDROOM		150	0	3	0	0	0	3	0.00	100.00	PASS	0	3	0	0	0.0	100	PASS
R1/1700	W1/1700	LKD		150	0	0	0	4	0	0	0.00	0.00	PASS							
R1/1700	W2/1700	LKD		150	0	0	0	6	0	0	0.00	0.00	PASS							
R1/1700	W3/1700	LKD		150	0	0	0	8	0	0	0.00	0.00	PASS	0	0	0	8	0.0	0	PASS
R2/1700	W4/1700	LKD		151	0	6	0	15	0	-9	0.00	-150.00	PASS							
R2/1700	W5/1700	LKD		150	0	7	1	17	0	-10	0.00	-142.86	PASS							
R2/1700	W6/1700	LKD		150	0	11	1	17	0	-6	0.00	-54.55	PASS	0	12	1	18	0.0	-50	PASS
R1/1701	W1/1701	LKD		150	0	2	0	7	0	-5	0.00	-250.00	PASS	0	2	0	7	0.0	-250	PASS
R2/1701	W2/1701	BEDROOM		150	1	1	1	7	0	-6	0.00	-600.00	PASS	1	1	1	7	0.0	-600	PASS
R3/1701	W3/1701	Bedroom		151	0	0	0	0	0	0	0.00	0.00	PASS							
R3/1701	W7/1701	Bedroom		150	0	9	0	17	0	-8	0.00	-88.89	PASS	0	9	0	17	0.0	-89	PASS
R4/1701	W4/1701	Bedroom		151	0	7	1	18	0	-11	0.00	-157.14	PASS							
R4/1701	W8/1701	Bedroom		150	1	11	1	20	0	-9	0.00	-81.82	PASS	1	16	1	23	0.0	-44	PASS
R5/1701	W5/1701	BEDROOM		150	0	9	2	21	0	-12	0.00	-133.33	PASS	0	9	2	21	0.0	-133	PASS
R6/1701	W6/1701	UNKNOWN		150	0	8	1	15	0	-7	0.00	-87.50	PASS	0	8	1	15	0.0	-88	PASS
R1/1702	W1/1702	LKD		150	0	2	0	8	0	-6	0.00	-300.00	PASS	0	2	0	8	0.0	-300	PASS
R2/1702	W2/1702	BEDROOM		150	1	2	1	9	0	-7	0.00	-350.00	PASS	1	2	1	9	0.0	-350	PASS
R3/1702	W3/1702	Bedroom		151	0	0	0	0	0	0	0.00	0.00	PASS							
R3/1702	W7/1702	Bedroom		150	1	15	1	21	0	-6	0.00	-40.00	PASS	1	15	1	21	0.0	-40	PASS
R4/1702	W4/1702	Bedroom		151	0	9	1	21	0	-12	0.00	-133.33	PASS							
R4/1702	W8/1702	Bedroom		150	1	17	1	25	0	-8	0.00	-47.06	PASS	1	22	1	28	0.0	-27	PASS
R5/1702	W5/1702	BEDROOM		150	0	11	2	23	0	-12	0.00	-109.09	PASS	0	11	2	23	0.0	-109	PASS
R6/1702	W6/1702	UNKNOWN		150	1	10	2	19	-1	-9	-100.00	-90.00	PASS	1	10	2	19	-100.0	-90	PASS

Room	Window	Room Use	Flat Number	Orientation	Window									Room						
					Existing		Proposed		Winter Loss	Annual Loss	Winter %Loss	Annual %Loss	Pass/Fail	Existing		Proposed		Winter %Loss	Annual %Loss	Pass/Fail
					Winter APSH	Annual APSH	Winter APSH	Annual APSH						Winter APSH	Annual APSH	Winter APSH	Annual APSH			
R1/1703	W1/1703	LKD		150	0	9	0	8	0	1	0.00	11.11	PASS	0	9	0	8	0.0	11	PASS
R2/1703	W2/1703	BEDROOM		150	1	9	1	9	0	0	0.00	0.00	PASS	1	9	1	9	0.0	0	PASS
R3/1703	W3/1703	Bedroom		151	0	2	0	1	0	1	0.00	50.00	PASS							
R3/1703	W7/1703	Bedroom		150	1	24	1	24	0	0	0.00	0.00	PASS	1	26	1	24	0.0	8	PASS
R4/1703	W4/1703	Bedroom		151	0	12	2	19	0	-7	0.00	-58.33	PASS							
R4/1703	W8/1703	Bedroom		150	1	26	2	28	-1	-2	-100.00	-7.69	PASS	1	34	2	30	-100.0	12	PASS
R5/1703	W5/1703	BEDROOM		150	0	13	3	21	0	-8	0.00	-61.54	PASS	0	13	3	21	0.0	-62	PASS
R6/1703	W6/1703	UNKNOWN		150	2	14	3	18	-1	-4	-50.00	-28.57	PASS	2	14	3	18	-50.0	-29	PASS
R1/1704	W1/1704	BEDROOM		150	2	37	1	20	1	17	50.00	45.95	FAIL	2	37	1	20	50.0	46	FAIL
R2/1704	W2/1704	BEDROOM		150	3	41	2	24	1	17	33.33	41.46	FAIL	3	41	2	24	33.3	41	FAIL
R3/1704	W3/1704	BEDROOM		150	2	43	1	30	1	13	50.00	30.23	FAIL	2	43	1	30	50.0	30	FAIL
R4/1704	W4/1704	BEDROOM		150	2	47	4	36	-2	11	-100.00	23.40	PASS	2	47	4	36	-100.0	23	PASS
R5/1704	W5/1704	BEDROOM		150	2	49	5	38	-3	11	-150.00	22.45	PASS	2	49	5	38	-150.0	22	PASS
R6/1704	W6/1704	BEDROOM		150	4	54	4	40	0	14	0.00	25.93	PASS	4	54	4	40	0.0	26	PASS
R1/1705	W1/1705	LKD		150	5	54	3	34	2	20	40.00	37.04	FAIL	5	54	3	34	40.0	37	FAIL
R2/1705	W2/1705	LKD		150	8	62	6	46	2	16	25.00	25.81	PASS	8	62	6	46	25.0	26	PASS