

## **Dempsey, Matthew**

---

**From:** BCTAdmin@thameswater.co.uk  
**Sent:** 10 April 2017 10:57  
**To:** Planning  
**Subject:** 3rd Party Planning Application - 2016/6959/P - Further Info

London Borough of Camden  
Camden Town Hall  
Argyle Street  
Euston Road  
London  
WC1H 8EQ

Our DTS Ref: 54409  
Your Ref: 2016/6959/P - Further Info

10 April 2017

Dear Sir/Madam

Re: KOKO 1A, CAMDEN HIGH STREET, LONDON, NW1 1TP

### Waste Comments

Surface Water Drainage - With regard to surface water drainage it is the responsibility of a developer to make proper provision for drainage to ground, water courses or a suitable sewer. In respect of surface water it is recommended that the applicant should ensure that storm flows are attenuated or regulated into the receiving public network through on or off site storage. When it is proposed to connect to a combined public sewer, the site drainage should be separate and combined at the final manhole nearest the boundary. Connections are not permitted for the removal of groundwater. Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. The contact number is 0800 009 3921. Reason - to ensure that the surface water discharge from the site shall not be detrimental to the existing sewerage system.

Thames Water recommends the installation of a properly maintained fat trap on all catering establishments. We further recommend, in line with best practice for the disposal of Fats, Oils and Grease, the collection of waste oil by a contractor, particularly to recycle for the production of bio diesel. Failure to implement these recommendations may result in this and other properties suffering blocked drains, sewage flooding and pollution to local watercourses.

Thames Water would advise that with regard to sewerage infrastructure capacity, we would not have any objection to the above planning application.

A Trade Effluent Consent will be required for any Effluent discharge other than a 'Domestic Discharge'. Any discharge without this consent is illegal and may result in prosecution. (Domestic usage for example includes - toilets, showers, washbasins, baths, private swimming pools and canteens). Typical Trade Effluent processes include: - Laundrette/Laundry, PCB manufacture, commercial swimming pools, photographic/printing, food preparation, abattoir, farm wastes, vehicle washing, metal plating/finishing, cattle market wash down, chemical manufacture, treated cooling water and any other process which produces contaminated water. Pre-treatment, separate metering, sampling access etc, may be required before the Company can give its consent. Applications should be made at <http://www.thameswater.co.uk/business/9993.htm> or alternatively to Waste Water Quality, Crossness STW, Belvedere Road, Abbeywood, London. SE2 9AQ. Telephone: 020 3577 9200.

'We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Groundwater discharges typically result from construction site dewatering, deep excavations, basement infiltration, borehole installation, testing and site remediation. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. Should the Local Planning Authority be minded to approve the planning application, Thames Water would like the following informative attached to the planning permission: "A Groundwater Risk Management Permit from Thames Water will be required for discharging groundwater into a public sewer. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 02035779483 or by emailing [wwqriskmanagement@thameswater.co.uk](mailto:wwqriskmanagement@thameswater.co.uk). Application forms should be completed on line via [www.thameswater.co.uk/wastewaterquality](http://www.thameswater.co.uk/wastewaterquality)."

#### Water Comments

On the basis of information provided, Thames Water would advise that with regard to water infrastructure capacity, we would not have any objection to the above planning application.

Thames Water recommend the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

#### Supplementary Comments

Surface Water should be addressed in accordance with the London Plan and we expect a significant reduction from current peak discharge rates.

Yours faithfully  
Development Planning Department

Development Planning,  
Thames Water,  
Maple Lodge STW,  
Denham Way,  
Rickmansworth,  
WD3 9SQ  
Tel:020 3577 9998  
Email: [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk)

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to  
[devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk)

Did you know you can manage your account online? Pay a bill, set up a Direct Debit, change your details or even register a change of address at the click of a button, 24 hours a day. Please visit [www.thameswater.co.uk](http://www.thameswater.co.uk).

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales each with their registered office at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and intended solely for the use of the individual to whom it is addressed. Any views or opinions presented are solely those of the author and do not necessarily represent those of Thames Water Limited or its subsidiaries. If you are not the intended recipient of this email you may not copy, use, forward or disclose its contents to any other person; please notify our Computer Service Desk on +44 (0) 203 577 8888 and destroy and delete the message and any attachments from your system.

We provide the essential service that's at the heart of daily life.