

**LBC – Technical Advice – blue plaque
31 Mornington Crescent**

From: Harper, Ian
Sent: 15 February 2017 10:52
To: Power, Cathy
Subject: RE: Blue Plaque Tech advice Spencer GORE

Dear Cathy

I like this position between the two windows. The brick walling will be of solid construction at least 9" thick and quite possibly 13.5" and be sound enough for the insertion. Location is bound to be a little compromised by the supports to the railings. I wonder if LBC was obtained for this unconventional strengthening work! In detail the plaque should be set symmetrically within the brick coursing.

With best wishes and in haste,

Ian

Ian Harper | Architect, Heritage at Risk
Direct Line: 020 7973 3786
Mobile: 07974 979620

Historic England | 1 Waterhouse Square
138 - 142 Holborn | London | EC1N 2ST