

Project name

Shell and Core

# 1 Triton Square - New Extension - Planning Issue

As designed

Date: Wed Jan 04 10:21:27 2017

## Administrative information

### Building Details

Address: 1 Triton Square, London, NW1 3HF

### Owner Details

Name:

Telephone number:

Address: , ,

### Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.6

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.6

BRUKL compliance check version: v5.2.g.3

### Certifier details

Name:

Telephone number:

Address: , ,

## Criterion 1: The calculated CO<sub>2</sub> emission rate for the building should not exceed the target

CO <sub>2</sub> emission rate from the notional building, kgCO <sub>2</sub> /m <sup>2</sup> .annum	21.7
Target CO <sub>2</sub> emission rate (TER), kgCO <sub>2</sub> /m <sup>2</sup> .annum	21.7
Building CO <sub>2</sub> emission rate (BER), kgCO <sub>2</sub> /m <sup>2</sup> .annum	18.8
Are emissions from the building less than or equal to the target?	BER =< TER
Are as built details the same as used in the BER calculations?	Separate submission

## Criterion 2: The performance of the building fabric and the building services should achieve reasonable overall standards of energy efficiency

Values not achieving standards in the Non-Domestic Building Services Compliance Guide and Part L are displayed in red.

### Building fabric

Element	U <sub>a</sub> -Limit	U <sub>a</sub> -Calc	U <sub>i</sub> -Calc	Surface where the maximum value occurs*
Wall**	0.35	0.26	0.26	7C000000:Surf[0]
Floor	0.25	0.22	0.22	7F000001:Surf[0]
Roof	0.25	0.18	0.18	7C000003:Surf[0]
Windows***, roof windows, and rooflights	2.2	1.52	1.52	8F00000D:Surf[0]
Personnel doors	2.2	-	-	No Personnel doors in building
Vehicle access & similar large doors	1.5	-	-	No Vehicle access doors in building
High usage entrance doors	3.5	-	-	No High usage entrance doors in building
U <sub>a</sub> -Limit = Limiting area-weighted average U-values [W/(m <sup>2</sup> K)] U <sub>a</sub> -Calc = Calculated area-weighted average U-values [W/(m <sup>2</sup> K)] U <sub>i</sub> -Calc = Calculated maximum individual element U-values [W/(m <sup>2</sup> K)]				
* There might be more than one surface where the maximum U-value occurs. ** Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows. *** Display windows and similar glazing are excluded from the U-value check. N.B.: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.				

Air Permeability	Worst acceptable standard	This building
m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa	10	3

## Building services

The standard values listed below are minimum values for efficiencies and maximum values for SFPs. Refer to the Non-Domestic Building Services Compliance Guide for details.

<b>Whole building lighting automatic monitoring &amp; targeting with alarms for out-of-range values</b>	YES
<b>Whole building electric power factor achieved by power factor correction</b>	>0.95

### 1- FCU System - Office

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0.91	4.9	0	1.8	0.7
<b>Standard value</b>	0.91*	2.7	N/A	1.6^	0.65
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.					
^ Allowed SFP may be increased by the amounts specified in the Non-Domestic Building Services Compliance Guide if the system includes additional components as listed in the Guide.					

"No HWS in project, or hot water is provided by HVAC system"

### Local mechanical ventilation, exhaust, and terminal units

ID	System type in Non-domestic Building Services Compliance Guide
A	Local supply or extract ventilation units serving a single area
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal supply and extract ventilation units serving a single room or zone with heating and heat recovery
E	Local supply and extract ventilation system serving a single area with heating and heat recovery
F	Other local ventilation units
G	Fan-assisted terminal VAV unit
H	Fan coil units
I	Zonal extract system where the fan is remote from the zone with grease filter

Zone name	SFP [W/(l/s)]										HR efficiency	
	ID of system type	A	B	C	D	E	F	G	H	I	Zone	Standard
	Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1		
8_Office_A_VZ2		-	-	-	-	-	-	-	0.3	-	-	N/A
8_Office_A_VZ3		-	-	-	-	-	-	-	0.3	-	-	N/A
8_Office_A_VZ4		-	-	-	-	-	-	-	0.3	-	-	N/A
8_Office_I_VZ1		-	-	-	-	-	-	-	0.3	-	-	N/A
8_Office_I_VZ3		-	-	-	-	-	-	-	0.3	-	-	N/A
8_Office_I_VZ4		-	-	-	-	-	-	-	0.3	-	-	N/A
8_Office_P_VZ1_East		-	-	-	-	-	-	-	0.3	-	-	N/A
8_Office_P_VZ1_SE		-	-	-	-	-	-	-	0.3	-	-	N/A
8_Office_P_VZ1_South		-	-	-	-	-	-	-	0.3	-	-	N/A
8_Office_P_VZ2_South		-	-	-	-	-	-	-	0.3	-	-	N/A
8_Office_P_VZ2_West		-	-	-	-	-	-	-	0.3	-	-	N/A
8_Office_P_VZ3_North		-	-	-	-	-	-	-	0.3	-	-	N/A
8_Office_P_VZ3_West		-	-	-	-	-	-	-	0.3	-	-	N/A
8_Office_P_VZ4_East		-	-	-	-	-	-	-	0.3	-	-	N/A
8_Office_P_VZ4_North		-	-	-	-	-	-	-	0.3	-	-	N/A
7_Office_A_VZ2		-	-	-	-	-	-	-	0.3	-	-	N/A

Zone name	SFP [W/(l/s)]									HR efficiency		
	ID of system type	A	B	C	D	E	F	G	H	I	Zone	Standard
Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1			
7_Office_A_VZ3	-	-	-	-	-	-	-	0.3	-	-	-	N/A
7_Office_A_VZ4	-	-	-	-	-	-	-	0.3	-	-	-	N/A
7_Office_I_VZ1	-	-	-	-	-	-	-	0.3	-	-	-	N/A
7_Office_I_VZ3	-	-	-	-	-	-	-	0.3	-	-	-	N/A
7_Office_I_VZ4	-	-	-	-	-	-	-	0.3	-	-	-	N/A
7_Office_P_VZ1_East	-	-	-	-	-	-	-	0.3	-	-	-	N/A
7_Office_P_VZ1_SE	-	-	-	-	-	-	-	0.3	-	-	-	N/A
7_Office_P_VZ1_South	-	-	-	-	-	-	-	0.3	-	-	-	N/A
7_Office_P_VZ2_South	-	-	-	-	-	-	-	0.3	-	-	-	N/A
7_Office_P_VZ2_West	-	-	-	-	-	-	-	0.3	-	-	-	N/A
7_Office_P_VZ3_North	-	-	-	-	-	-	-	0.3	-	-	-	N/A
7_Office_P_VZ3_West	-	-	-	-	-	-	-	0.3	-	-	-	N/A
7_Office_P_VZ4_East	-	-	-	-	-	-	-	0.3	-	-	-	N/A
7_Office_P_VZ4_North	-	-	-	-	-	-	-	0.3	-	-	-	N/A
6_Office_A_VZ2	-	-	-	-	-	-	-	0.3	-	-	-	N/A
6_Office_A_VZ3	-	-	-	-	-	-	-	0.3	-	-	-	N/A
6_Office_A_VZ4	-	-	-	-	-	-	-	0.3	-	-	-	N/A
6_Office_I_VZ1	-	-	-	-	-	-	-	0.3	-	-	-	N/A
6_Office_I_VZ3	-	-	-	-	-	-	-	0.3	-	-	-	N/A
6_Office_I_VZ4	-	-	-	-	-	-	-	0.3	-	-	-	N/A
6_Office_P_VZ1_East	-	-	-	-	-	-	-	0.3	-	-	-	N/A
6_Office_P_VZ1_SE	-	-	-	-	-	-	-	0.3	-	-	-	N/A
6_Office_P_VZ1_South	-	-	-	-	-	-	-	0.3	-	-	-	N/A
6_Office_P_VZ2_South	-	-	-	-	-	-	-	0.3	-	-	-	N/A
6_Office_P_VZ2_West	-	-	-	-	-	-	-	0.3	-	-	-	N/A
6_Office_P_VZ3_North	-	-	-	-	-	-	-	0.3	-	-	-	N/A
6_Office_P_VZ3_West	-	-	-	-	-	-	-	0.3	-	-	-	N/A
6_Office_P_VZ4_East	-	-	-	-	-	-	-	0.3	-	-	-	N/A
6_Office_P_VZ4_North	-	-	-	-	-	-	-	0.3	-	-	-	N/A
8_Office_I_VZ2	-	-	-	-	-	-	-	0.3	-	-	-	N/A
7_Office_I_VZ2	-	-	-	-	-	-	-	0.3	-	-	-	N/A
6_Office_I_VZ2	-	-	-	-	-	-	-	0.3	-	-	-	N/A

### Shell and core configuration

Zone	Assumed shell?
8_Core 1A_Lift Lobby	NO
8_Core 1A_Stairs	NO
8_Core 1B_Acc WC_VZ1	NO
8_Core 1B_Cleaners Cupboard	NO
8_Core 1B_Female WC_VZ1	NO
8_Core 1B_Male WC_VZ1	NO
8_Core 1B_Stairs	NO
8_Core 1B_Storage	NO
8_Core 2_Cleaners Cupboard	NO
8_Core 2_DWC_VZ2	NO

### Shell and core configuration

Zone	Assumed shell?
8_Core 2_Female WC_VZ2	NO
8_Core 2_Lobby	NO
8_Core 2_Lobby 1	NO
8_Core 2_Lobby 2	NO
8_Core 2_Male WC_VZ2	NO
8_Core 2_Stairs	NO
8_Core 2_Storage 1	NO
8_Core 2_Storage 2	NO
8_Core 3_Cleaners Cupboard 1	NO
8_Core 3_Cleaners Cupboard 2	NO
8_Core 3_DWC_VZ3	NO
8_Core 3_Female WC_VZ3	NO
8_Core 3_Lobby	NO
8_Core 3_Lobby 2	NO
8_Core 3_Lobby 3	NO
8_Core 3_Male WC_VZ3	NO
8_Core 3_Stairs	NO
8_Core 4_Cleaners Cupboard	NO
8_Core 4_DWC_VZ4	NO
8_Core 4_Female WC_VZ4	NO
8_Core 4_Lobby 2	NO
8_Core 4_Lobby 3	NO
8_Core 4_Male WC_VZ4	NO
8_Core 4_Stairs	NO
8_Core 4_Storage 1	NO
8_Core 4_Storage 2	NO
8_Office_A_VZ2	NO
8_Office_A_VZ3	NO
8_Office_A_VZ4	NO
8_Office_I_VZ1	NO
8_Office_I_VZ3	NO
8_Office_I_VZ4	NO
8_Office_P_VZ1_East	NO
8_Office_P_VZ1_SE	NO
8_Office_P_VZ1_South	NO
8_Office_P_VZ2_South	NO
8_Office_P_VZ2_West	NO
8_Office_P_VZ3_North	NO
8_Office_P_VZ3_West	NO
8_Office_P_VZ4_East	NO
8_Office_P_VZ4_North	NO
9_Core 1A_Stairs	NO
9_Core 1B_Male WC	NO
9_Core 1B_Stairs	NO
9_Core 1B_Storage	NO
9_Core 2_Lobby 1	NO
9_Core 2_Stairs	NO

### Shell and core configuration

Zone	Assumed shell?
9_Core 2_Storage 1	NO
9_Core 2_Storage 2	NO
9_Core 3_Lobby 3	NO
9_Core 3_Stairs	NO
9_Core 4_Lobby 3	NO
9_Core 4_Stairs	NO
9_Core 4_Storage	NO
7_Core 1A_Lift Lobby	NO
7_Core 1A_Stairs	NO
7_Core 1B_Acc WC_VZ1	NO
7_Core 1B_Cleaners Cupboard	NO
7_Core 1B_Female WC_VZ1	NO
7_Core 1B_Male WC_VZ1	NO
7_Core 1B_Stairs	NO
7_Core 1B_Storage	NO
7_Core 2_Cleaners Cupboard	NO
7_Core 2_DWC_VZ2	NO
7_Core 2_Female WC_VZ2	NO
7_Core 2_Lobby	NO
7_Core 2_Lobby 1	NO
7_Core 2_Lobby 2	NO
7_Core 2_Male WC_VZ2	NO
7_Core 2_Stairs	NO
7_Core 2_Storage 1	NO
7_Core 2_Storage 2	NO
7_Core 3_Cleaners Cupboard 1	NO
7_Core 3_Cleaners Cupboard 2	NO
7_Core 3_DWC_VZ3	NO
7_Core 3_Female WC_VZ3	NO
7_Core 3_Lobby	NO
7_Core 3_Lobby 2	NO
7_Core 3_Lobby 3	NO
7_Core 3_Male WC_VZ3	NO
7_Core 3_Stairs	NO
7_Core 4_Cleaners Cupboard	NO
7_Core 4_DWC_VZ4	NO
7_Core 4_Female WC_VZ4	NO
7_Core 4_Lobby 2	NO
7_Core 4_Lobby 3	NO
7_Core 4_Male WC_VZ4	NO
7_Core 4_Stairs	NO
7_Core 4_Storage 1	NO
7_Core 4_Storage 2	NO
7_Office_A_VZ2	NO
7_Office_A_VZ3	NO
7_Office_A_VZ4	NO
7_Office_I_VZ1	NO

### Shell and core configuration

Zone	Assumed shell?
7_Office_I_VZ3	NO
7_Office_I_VZ4	NO
7_Office_P_VZ1_East	NO
7_Office_P_VZ1_SE	NO
7_Office_P_VZ1_South	NO
7_Office_P_VZ2_South	NO
7_Office_P_VZ2_West	NO
7_Office_P_VZ3_North	NO
7_Office_P_VZ3_West	NO
7_Office_P_VZ4_East	NO
7_Office_P_VZ4_North	NO
6_Core 1A_Lift Lobby	NO
6_Core 1A_Stairs	NO
6_Core 1B_Acc WC_VZ1	NO
6_Core 1B_Cleaners Cupboard	NO
6_Core 1B_Female WC_VZ1	NO
6_Core 1B_Male WC_VZ1	NO
6_Core 1B_Stairs	NO
6_Core 1B_Storage	NO
6_Core 2_Cleaners Cupboard	NO
6_Core 2_DWC_VZ2	NO
6_Core 2_Female WC_VZ2	NO
6_Core 2_Lobby	NO
6_Core 2_Lobby 1	NO
6_Core 2_Lobby 2	NO
6_Core 2_Male WC_VZ2	NO
6_Core 2_Stairs	NO
6_Core 2_Storage 1	NO
6_Core 2_Storage 2	NO
6_Core 3_Cleaners Cupboard 1	NO
6_Core 3_Cleaners Cupboard 2	NO
6_Core 3_DWC_VZ3	NO
6_Core 3_Female WC_VZ3	NO
6_Core 3_Lobby	NO
6_Core 3_Lobby 2	NO
6_Core 3_Lobby 3	NO
6_Core 3_Male WC_VZ3	NO
6_Core 3_Stairs	NO
6_Core 4_Cleaners Cupboard	NO
6_Core 4_DWC_VZ4	NO
6_Core 4_Female WC_VZ4	NO
6_Core 4_Lobby 2	NO
6_Core 4_Lobby 3	NO
6_Core 4_Male WC_VZ4	NO
6_Core 4_Stairs	NO
6_Core 4_Storage 1	NO
6_Core 4_Storage 2	NO

### Shell and core configuration

Zone	Assumed shell?
6_Office_A_VZ2	NO
6_Office_A_VZ3	NO
6_Office_A_VZ4	NO
6_Office_I_VZ1	NO
6_Office_I_VZ3	NO
6_Office_I_VZ4	NO
6_Office_P_VZ1_East	NO
6_Office_P_VZ1_SE	NO
6_Office_P_VZ1_South	NO
6_Office_P_VZ2_South	NO
6_Office_P_VZ2_West	NO
6_Office_P_VZ3_North	NO
6_Office_P_VZ3_West	NO
6_Office_P_VZ4_East	NO
6_Office_P_VZ4_North	NO
8_Office_I_VZ2	NO
7_Office_I_VZ2	NO
6_Office_I_VZ2	NO

General lighting and display lighting Zone name	Luminous efficacy [lm/W]			General lighting [W]
	Luminaire	Lamp	Display lamp	
<b>Standard value</b>	60	60	22	
8_Core 1A_Lift Lobby	-	90	-	84
8_Core 1A_Stairs	-	90	-	52
8_Core 1B_Acc WC_VZ1	-	70	-	33
8_Core 1B_Cleaners Cupboard	82	-	-	10
8_Core 1B_Female WC_VZ1	-	70	-	106
8_Core 1B_Male WC_VZ1	-	70	-	76
8_Core 1B_Stairs	-	90	-	51
8_Core 1B_Storage	82	-	-	21
8_Core 2_Cleaners Cupboard	82	-	-	8
8_Core 2_DWC_VZ2	-	70	-	33
8_Core 2_Female WC_VZ2	-	70	-	98
8_Core 2_Lobby	-	90	-	35
8_Core 2_Lobby 1	-	90	-	19
8_Core 2_Lobby 2	-	90	-	43
8_Core 2_Male WC_VZ2	-	70	-	76
8_Core 2_Stairs	-	90	-	48
8_Core 2_Storage 1	82	-	-	14
8_Core 2_Storage 2	82	-	-	11
8_Core 3_Cleaners Cupboard 1	82	-	-	10
8_Core 3_Cleaners Cupboard 2	82	-	-	8
8_Core 3_DWC_VZ3	-	70	-	34
8_Core 3_Female WC_VZ3	-	70	-	69
8_Core 3_Lobby	-	90	-	40

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name	Standard value	Luminaire	Lamp	Display lamp	
		60	60	22	
8_Core 3_Lobby 2		-	90	-	41
8_Core 3_Lobby 3		-	90	-	16
8_Core 3_Male WC_VZ3		-	70	-	90
8_Core 3_Stairs		-	90	-	49
8_Core 4_Cleaners Cupboard		82	-	-	8
8_Core 4_DWC_VZ4		-	70	-	33
8_Core 4_Female WC_VZ4		-	70	-	70
8_Core 4_Lobby 2		-	90	-	40
8_Core 4_Lobby 3		-	90	-	18
8_Core 4_Male WC_VZ4		-	70	-	82
8_Core 4_Stairs		-	90	-	49
8_Core 4_Storage 1		82	-	-	14
8_Core 4_Storage 2		82	-	-	15
8_Office_A_VZ2		90	-	-	1736
8_Office_A_VZ3		90	-	-	596
8_Office_A_VZ4		90	-	-	1197
8_Office_I_VZ1		90	-	-	832
8_Office_I_VZ3		90	-	-	2842
8_Office_I_VZ4		90	-	-	4679
8_Office_P_VZ1_East		90	-	-	288
8_Office_P_VZ1_SE		90	-	-	162
8_Office_P_VZ1_South		90	-	-	231
8_Office_P_VZ2_South		90	-	-	1113
8_Office_P_VZ2_West		90	-	-	1062
8_Office_P_VZ3_North		90	-	-	775
8_Office_P_VZ3_West		90	-	-	483
8_Office_P_VZ4_East		90	-	-	1058
8_Office_P_VZ4_North		90	-	-	768
9_Core 1A_Stairs		-	90	-	52
9_Core 1B_Male WC		-	70	-	178
9_Core 1B_Stairs		-	90	-	51
9_Core 1B_Storage		82	-	-	33
9_Core 2_Lobby 1		-	90	-	19
9_Core 2_Stairs		-	90	-	48
9_Core 2_Storage 1		82	-	-	11
9_Core 2_Storage 2		82	-	-	14
9_Core 3_Lobby 3		-	90	-	16
9_Core 3_Stairs		-	90	-	49
9_Core 4_Lobby 3		-	90	-	18
9_Core 4_Stairs		-	90	-	49
9_Core 4_Storage		82	-	-	14
7_Core 1A_Lift Lobby		-	90	-	84
7_Core 1A_Stairs		-	90	-	52



General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name		Luminaire	Lamp	Display lamp	General lighting [W]
	<b>Standard value</b>	60	60	22	
7_Core 1B_Acc WC_VZ1		-	70	-	33
7_Core 1B_Cleaners Cupboard		82	-	-	10
7_Core 1B_Female WC_VZ1		-	70	-	106
7_Core 1B_Male WC_VZ1		-	70	-	76
7_Core 1B_Stairs		-	90	-	51
7_Core 1B_Storage		82	-	-	21
7_Core 2_Cleaners Cupboard		82	-	-	8
7_Core 2_DWC_VZ2		-	70	-	33
7_Core 2_Female WC_VZ2		-	70	-	98
7_Core 2_Lobby		-	90	-	35
7_Core 2_Lobby 1		-	90	-	19
7_Core 2_Lobby 2		-	90	-	43
7_Core 2_Male WC_VZ2		-	70	-	76
7_Core 2_Stairs		-	90	-	48
7_Core 2_Storage 1		82	-	-	14
7_Core 2_Storage 2		82	-	-	11
7_Core 3_Cleaners Cupboard 1		82	-	-	10
7_Core 3_Cleaners Cupboard 2		82	-	-	8
7_Core 3_DWC_VZ3		-	70	-	34
7_Core 3_Female WC_VZ3		-	70	-	69
7_Core 3_Lobby		-	90	-	40
7_Core 3_Lobby 2		-	90	-	41
7_Core 3_Lobby 3		-	90	-	16
7_Core 3_Male WC_VZ3		-	70	-	90
7_Core 3_Stairs		-	90	-	49
7_Core 4_Cleaners Cupboard		82	-	-	8
7_Core 4_DWC_VZ4		-	70	-	33
7_Core 4_Female WC_VZ4		-	70	-	70
7_Core 4_Lobby 2		-	90	-	40
7_Core 4_Lobby 3		-	90	-	18
7_Core 4_Male WC_VZ4		-	70	-	82
7_Core 4_Stairs		-	90	-	49
7_Core 4_Storage 1		82	-	-	14
7_Core 4_Storage 2		82	-	-	15
7_Office_A_VZ2		90	-	-	1736
7_Office_A_VZ3		90	-	-	596
7_Office_A_VZ4		90	-	-	1197
7_Office_I_VZ1		90	-	-	832
7_Office_I_VZ3		90	-	-	2842
7_Office_I_VZ4		90	-	-	4679
7_Office_P_VZ1_East		90	-	-	288
7_Office_P_VZ1_SE		90	-	-	162
7_Office_P_VZ1_South		90	-	-	231

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name	Standard value	Luminaire	Lamp	Display lamp	
		60	60	22	
7_Office_P_VZ2_South		90	-	-	1113
7_Office_P_VZ2_West		90	-	-	1062
7_Office_P_VZ3_North		90	-	-	775
7_Office_P_VZ3_West		90	-	-	483
7_Office_P_VZ4_East		90	-	-	1058
7_Office_P_VZ4_North		90	-	-	768
6_Core 1A_Lift Lobby		-	90	-	84
6_Core 1A_Stairs		-	90	-	52
6_Core 1B_Acc WC_VZ1		-	70	-	33
6_Core 1B_Cleaners Cupboard		82	-	-	10
6_Core 1B_Female WC_VZ1		-	70	-	106
6_Core 1B_Male WC_VZ1		-	70	-	76
6_Core 1B_Stairs		-	90	-	51
6_Core 1B_Storage		82	-	-	21
6_Core 2_Cleaners Cupboard		82	-	-	8
6_Core 2_DWC_VZ2		-	70	-	33
6_Core 2_Female WC_VZ2		-	70	-	98
6_Core 2_Lobby		-	90	-	35
6_Core 2_Lobby 1		-	90	-	19
6_Core 2_Lobby 2		-	90	-	43
6_Core 2_Male WC_VZ2		-	70	-	76
6_Core 2_Stairs		-	90	-	48
6_Core 2_Storage 1		82	-	-	14
6_Core 2_Storage 2		82	-	-	11
6_Core 3_Cleaners Cupboard 1		82	-	-	10
6_Core 3_Cleaners Cupboard 2		82	-	-	8
6_Core 3_DWC_VZ3		-	70	-	34
6_Core 3_Female WC_VZ3		-	70	-	69
6_Core 3_Lobby		-	90	-	40
6_Core 3_Lobby 2		-	90	-	41
6_Core 3_Lobby 3		-	90	-	16
6_Core 3_Male WC_VZ3		-	70	-	90
6_Core 3_Stairs		-	90	-	49
6_Core 4_Cleaners Cupboard		82	-	-	8
6_Core 4_DWC_VZ4		-	70	-	33
6_Core 4_Female WC_VZ4		-	70	-	70
6_Core 4_Lobby 2		-	90	-	40
6_Core 4_Lobby 3		-	90	-	18
6_Core 4_Male WC_VZ4		-	70	-	82
6_Core 4_Stairs		-	90	-	49
6_Core 4_Storage 1		82	-	-	14
6_Core 4_Storage 2		82	-	-	15
6_Office_A_VZ2		90	-	-	1736

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name	Standard value	Luminaire	Lamp	Display lamp	
		60	60	22	
6_Office_A_VZ3		90	-	-	596
6_Office_A_VZ4		90	-	-	1197
6_Office_I_VZ1		90	-	-	832
6_Office_I_VZ3		90	-	-	2842
6_Office_I_VZ4		90	-	-	4679
6_Office_P_VZ1_East		90	-	-	288
6_Office_P_VZ1_SE		90	-	-	162
6_Office_P_VZ1_South		90	-	-	231
6_Office_P_VZ2_South		90	-	-	1113
6_Office_P_VZ2_West		90	-	-	1062
6_Office_P_VZ3_North		90	-	-	775
6_Office_P_VZ3_West		90	-	-	483
6_Office_P_VZ4_East		90	-	-	1058
6_Office_P_VZ4_North		90	-	-	768
8_Office_I_VZ2		90	-	-	6003
7_Office_I_VZ2		90	-	-	6003
6_Office_I_VZ2		90	-	-	6003

**Criterion 3: The spaces in the building should have appropriate passive control measures to limit solar gains**

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
8_Office_A_VZ2	NO (-78.5%)	NO
8_Office_A_VZ3	NO (-74.7%)	NO
8_Office_A_VZ4	NO (-66.5%)	NO
8_Office_I_VZ1	NO (-87.9%)	NO
8_Office_I_VZ3	NO (-88.2%)	NO
8_Office_I_VZ4	NO (-90.7%)	NO
8_Office_P_VZ1_East	NO (-60.8%)	NO
8_Office_P_VZ1_SE	NO (-58.4%)	NO
8_Office_P_VZ1_South	NO (-69.1%)	NO
8_Office_P_VZ2_South	NO (-49.6%)	NO
8_Office_P_VZ2_West	NO (-50.5%)	NO
8_Office_P_VZ3_North	NO (-63.9%)	NO
8_Office_P_VZ3_West	NO (-53.8%)	NO
8_Office_P_VZ4_East	NO (-74.6%)	NO
8_Office_P_VZ4_North	NO (-63.4%)	NO
7_Office_A_VZ2	NO (-80.8%)	NO
7_Office_A_VZ3	NO (-67.3%)	NO
7_Office_A_VZ4	NO (-64.1%)	NO
7_Office_I_VZ1	NO (-88.7%)	NO
7_Office_I_VZ3	NO (-88.5%)	NO
7_Office_I_VZ4	NO (-91.2%)	NO
7_Office_P_VZ1_East	NO (-61.9%)	NO
7_Office_P_VZ1_SE	NO (-61.3%)	NO

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
7_Office_P_VZ1_South	NO (-70.7%)	NO
7_Office_P_VZ2_South	NO (-54.7%)	NO
7_Office_P_VZ2_West	NO (-52.7%)	NO
7_Office_P_VZ3_North	NO (-64.4%)	NO
7_Office_P_VZ3_West	NO (-55.7%)	NO
7_Office_P_VZ4_East	NO (-76.4%)	NO
7_Office_P_VZ4_North	NO (-63.8%)	NO
6_Office_A_VZ2	NO (-82.6%)	NO
6_Office_A_VZ3	NO (-70.2%)	NO
6_Office_A_VZ4	NO (-68.9%)	NO
6_Office_I_VZ1	NO (-89.2%)	NO
6_Office_I_VZ3	NO (-88.8%)	NO
6_Office_I_VZ4	NO (-91.8%)	NO
6_Office_P_VZ1_East	NO (-63.1%)	NO
6_Office_P_VZ1_SE	NO (-63.6%)	NO
6_Office_P_VZ1_South	NO (-72.1%)	NO
6_Office_P_VZ2_South	NO (-58.2%)	NO
6_Office_P_VZ2_West	NO (-55.2%)	NO
6_Office_P_VZ3_North	NO (-64.5%)	NO
6_Office_P_VZ3_West	NO (-57.2%)	NO
6_Office_P_VZ4_East	NO (-77.9%)	NO
6_Office_P_VZ4_North	NO (-63.9%)	NO
8_Office_I_VZ2	NO (-88.5%)	NO
7_Office_I_VZ2	NO (-89.5%)	NO
6_Office_I_VZ2	NO (-90.2%)	NO

**Criterion 4: The performance of the building, as built, should be consistent with the calculated BER**

Separate submission

**Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place**

Separate submission

**EPBD (Recast): Consideration of alternative energy systems**

<b>Were alternative energy systems considered and analysed as part of the design process?</b>	<b>NO</b>
Is evidence of such assessment available as a separate submission?	NO
Are any such measures included in the proposed design?	NO

# Technical Data Sheet (Actual vs. Notional Building)

## Building Global Parameters

	Actual	Notional
Area [m <sup>2</sup> ]	10478.1	10478.1
External area [m <sup>2</sup> ]	11124.3	11124.3
Weather	LON	LON
Infiltration [m <sup>3</sup> /hm <sup>2</sup> @ 50Pa]	3	3
Average conductance [W/K]	5493.04	3997.12
Average U-value [W/m <sup>2</sup> K]	0.49	0.36
Alpha value* [%]	17.5	10

\* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

## Building Use

### % Area Building Type

	A1/A2 Retail/Financial and Professional services
	A3/A4/A5 Restaurants and Cafes/Drinking Est./Takeaways
<b>100</b>	<b>B1 Offices and Workshop businesses</b>
	B2 to B7 General Industrial and Special Industrial Groups
	B8 Storage or Distribution
	C1 Hotels
	C2 Residential Inst.: Hospitals and Care Homes
	C2 Residential Inst.: Residential schools
	C2 Residential Inst.: Universities and colleges
	C2A Secure Residential Inst.
	Residential spaces
	D1 Non-residential Inst.: Community/Day Centre
	D1 Non-residential Inst.: Libraries, Museums, and Galleries
	D1 Non-residential Inst.: Education
	D1 Non-residential Inst.: Primary Health Care Building
	D1 Non-residential Inst.: Crown and County Courts
	D2 General Assembly and Leisure, Night Clubs and Theatres
	Others: Passenger terminals
	Others: Emergency services
	Others: Miscellaneous 24hr activities
	Others: Car Parks 24 hrs
	Others - Stand alone utility block

## Energy Consumption by End Use [kWh/m<sup>2</sup>]

	Actual	Notional
Heating	5.56	2.13
Cooling	4.84	5.68
Auxiliary	12.26	11.97
Lighting	16.31	23.17
Hot water	3.33	2.7
Equipment*	37.15	37.15
<b>TOTAL**</b>	<b>42.3</b>	<b>45.66</b>

\* Energy used by equipment does not count towards the total for calculating emissions.

\*\* Total is net of any electrical energy displaced by CHP generators, if applicable.

## Energy Production by Technology [kWh/m<sup>2</sup>]

	Actual	Notional
Photovoltaic systems	0	0
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0

## Energy & CO<sub>2</sub> Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m <sup>2</sup> ]	98.13	84.16
Primary energy* [kWh/m <sup>2</sup> ]	110.85	128.09
Total emissions [kg/m <sup>2</sup> ]	18.8	21.7

\* Primary energy is net of any electrical energy displaced by CHP generators, if applicable.

## HVAC Systems Performance

System Type	Heat dem MJ/m <sup>2</sup>	Cool dem MJ/m <sup>2</sup>	Heat con kWh/m <sup>2</sup>	Cool con kWh/m <sup>2</sup>	Aux con kWh/m <sup>2</sup>	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER
<b>[ST] Fan coil systems, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity</b>									
<b>Actual</b>	19.6	95.5	6.5	5.7	14.1	0.83	4.67	0.91	6
<b>Notional</b>	7.8	91	2.5	6.7	13.9	0.86	3.79	----	----
<b>[ST] No Heating or Cooling</b>									
<b>Actual</b>	0	0	0	0	0	0	0	0	0
<b>Notional</b>	0	0	0	0	0	0	0	----	----

### Key to terms

Heat dem [MJ/m <sup>2</sup> ]	= Heating energy demand
Cool dem [MJ/m <sup>2</sup> ]	= Cooling energy demand
Heat con [kWh/m <sup>2</sup> ]	= Heating energy consumption
Cool con [kWh/m <sup>2</sup> ]	= Cooling energy consumption
Aux con [kWh/m <sup>2</sup> ]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type

# Key Features

The BCO can give particular attention to items with specifications that are better than typically expected.

## Building fabric

Element	U <sub>i-Typ</sub>	U <sub>i-Min</sub>	Surface where the minimum value occurs*
Wall	0.23	0.26	7C000000:Surf[0]
Floor	0.2	0.22	7F000001:Surf[0]
Roof	0.15	0.18	7C000003:Surf[0]
Windows, roof windows, and rooflights	1.5	1.5	TR000002:Surf[0]
Personnel doors	1.5	-	No Personnel doors in building
Vehicle access & similar large doors	1.5	-	No Vehicle access doors in building
High usage entrance doors	1.5	-	No High usage entrance doors in building
U <sub>i-Typ</sub> = Typical individual element U-values [W/(m <sup>2</sup> K)]		U <sub>i-Min</sub> = Minimum individual element U-values [W/(m <sup>2</sup> K)]	
* There might be more than one surface where the minimum U-value occurs.			

Air Permeability	Typical value	This building
m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa	5	3