

1281/bs

04 May 2017

David Peres Da Costa London Borough of Camden Regeneration and Planning Development Management Town Hall Judd Street London WC1H 9JE

Dear Sirs

## 17 BRANCH HILL, LONDON NW3 REF: 2015/3377/P

In response to Item 9 of the Planning Permission for 17 Branch Hill dated 27<sup>th</sup> April we can confirm that the surface water run off has been limited to 5l/s in accordance with the Camden requirements. Please see enclosed drawings showing the proposed attenuation system to achieve this.

Yours sincerely

Brett Scott for and on behalf of Engineers Haskins Robinson Waters

cc. SHH Architects - Pawel Nawojczyk

enc.