




angestrahle Fläche
illuminated surface
surface éclairée



Notes

1. DO NOT SCALE.
2. THIS DRAWING TO BE READ IN CONJUNCTION WITH LATEST ARCHITECTURAL AND STRUCTURAL DRAWINGS.
3. ALL DIMENSIONS IN MILLIMETRES UNLESS STATED OTHERWISE.
4. ALL DATUM LEVELS IN METRES UNLESS NOTED OTHERWISE.
5. FOR STANDARD SYMBOLS AND NOTATION REFER TO DRG No. 15301-00-50-000-0000.
6. FOR EQUIPMENT DETAILS REFER TO TECHNICAL SCHEDULES.
7. THIS DRAWING TO BE READ IN CONJUNCTION WITH RELEVANT DRAWINGS AND TECHNICAL SPECIFICATIONS.
8. REFER TO RELEVANT SERVICES SCHEMATIC FOR SIZES.
9. THIS DRAWING SHALL ONLY BE USED FOR THE SPECIFIC SERVICE(S) INTENDED.
10. TO BE READ IN CONJUNCTION WITH SPIERS AND MAJOR DRAWINGS & LUMINAIRE SCHEDULES.
11. EXTERNAL LIGHTING

MINIS. 230V CIRCUIT	DALI CONTROL CIRCUIT LUMINAIRE SUPPLIES
08/81/EX2/1/L1	1.0.05 1.0.11
08/81/EX2/7/L1	1.0.13 1.0.14
08/GF/APE/7/L1	1.1.07

REFER TO SPECIALIST LIGHTING DESIGNER'S INFORMATION FOR CONFIRMED EXTERNAL LUMINAIRE REFERENCES, GROUPINGS AND QUANTITIES.


12. REFER TO DISTRIBUTION BOARD SCHEDULES FOR CIRCUIT REFERENCES

13. A3 FITTINGS HAVE INTERNAL PIR AND SELF TEST EMERGENCY PACK

This Drawing is Based Upon The Following Information:

106610-E-2411 REV 10

Rev	Description	Drawn	Checked	Date
0	APPROVAL	CH	CB	22/03/17



Stewart House,
Kenton Road, Harrow,
Middlesex, HA3 9TU,
Telephone: 020-8732 2000
Facsimile: 020-8204 9453
www.lornestewart.co.uk

IBSECAD

14 Hosiery Lane London, EC1A 9LD Telephone: +44 (0) 20 7618 1150 Email: london@ibsecad.net

Project Name: **CENTRE POINT**

Drawing Status: **APPROVAL**

Drawn By: **ISSE** Drawn Date: **MAR 17** Scale: **1:50@A0**

Title: **CENTER POINT HOUSE GROUND FLOOR LOW LEVEL LANDLORD LIGHTING LAYOUT RETAIL 1**

Page	1	Total Pages	1
------	---	-------------	---