Kanegroup Building Services



Mechanical Testing and Commissioning Certificates

West Hampstead Square



2016-2017



Certificate of Combined Heat and Power System Commissioning

Client: Kane Group Ltd.	Project Name: West Hampstead Square
	Scope of Project: Supply & commission
	Machine Serial No(s): 200630
	Commissioning Engineer: David Scales
	Veolia Project Reference: C596
In accordance with the standard Veolia Limited commissioning procedures, the commissioning of this Combined Heat and Power System has been completed to the satisfaction of the Engineer above named.	
a) Commissioning Information	CAPITAL SALE
i) Date commissioning completed:-	23/12/2016
ii) Date G59/3 demonstrated:-	22/12/2016
iii) REC involved and representative:	- UKPN
iv) Date CHP system operational:-	TBC*
v) Operational hours set:-	TBC
vi) RMS Telephone No(s):-	TBC*
b) System Information:	
i) Parallel Operation	
ii) Heat Dump Fitted: No	
iii) kW Output: Electrical 135kW,	Thermal 207 kW.
iv) System Return Temperature: 70 °	°C, Delta T °C: 10°C.
The Project Manager hereby confirms that the commissioning of the CHP unit has been completed to their satisfaction	
Name: Signature:Date: 12/01/17	

*Unit cannot be operated until the telephone line has been installed and our commissioning engineer has proven communications