

Building Services Report

**Melia White House Hotel
Albany Street London NW1 3UP**



CONTENTS

1.0	Introduction.....	3
2.0	Environment (heating and cooling) and Ventilation Proposed Solutions.....	4
3.0	Overlay Plans to show proposed plant and riser locations	5
4.0	Fire Alarm System.....	6
5.0	Recommendations.....	7
6.0	Appendices.....	8
7.0	Survey Photos.....	9

1.0 Introduction

Mike Harvey Associates (MHA) were commissioned to visit The Melia White House Hotel to carry out a High level review of the mechanical and electrical engineering services to look at the feasibility and type of plant solutions as a priority to serve the new works proposals for the 3 Phases of works on the ground floor.

The very limited documentation that has been made available would suggest some of the base building original services were installed circa 25 years ago, eg the fire alarms, more recently some of the mechanical drawings are dated 2002 circa 15 years ago and these have been supplemented by 2 No new Chillers at Roof level in the last year. Some Record drawings were made available but no landlord base building original record Operation and Maintenance Manual information was provided for review.

The contents in this report have been based on a desk top review and a non-intrusive visual inspection only, within the limitations of the building system enclosure.

No attempt was made to remove system enclosures, access covers and a very limited inspection was carried out. The visit also reviewed the ground floor office area.

No attempt has been made to introduce any mechanical or electrical load tests, carry out any scan or commissioning tests/data to identify the systems compliance with the IEE Regulations/CIBSE Commissioning Codes.

Confidential

This document contains confidential material solely for the use of Ken Mackay and Partners. All reasonable precautionary methods in handling the document and the information contained herein shall be taken to prevent any third party from obtaining access. No responsibility is taken by MHA for the use of this report by any third party.

Copyright © 2017 by Mike Harvey Associates Limited (MHA)

All rights reserved. No part of this document may be reproduced or transmitted in any form by parties other than those employed or engaged by MHA by any means without the written permission of the publisher.

Liability

This report is prepared in good faith and with due care for information purposes only and should not be relied upon as providing any warranty or guarantee as to the nature and condition of the building and/or its services or equipment. In particular, attention is drawn to the nature of the inspection and investigations undertaken and the limitations these impose in determining with accuracy the state of the building, its services or equipment.

MHA or their report collaborators shall not be held liable for any loss or damage resulting from any defect of the building or its services or equipment or for any non-compliance of the building or its services or equipment with any legislative or operational requirements, whether or not such defect or non-compliance is referred to or reported upon in this report, unless such defect or non-compliance should have been apparent to a competent Engineer undertaking inspection of the type undertaken for the purpose of preparing this report.

2.0 Environment (heating and cooling) and Ventilation Proposed Solutions

Plant and Risers / Options considered

The site was reviewed and walkaround by the team with Miguel and Gary during our walkround on 16th February 2017 and subsequently on 23rd February 2017 and 2nd March 2017. Following the receipt of survey drawings on 8th March 2017, several plant locations and potential riser locations were considered and these have been highlighted on the drawings in colour for ease.

We have estimated the loads and sized the plant and risers required.

There is one *stand out* option and again this is shown on the drawings. the proposed riser is a store location and in principle there is enough space in the riser for the ductwork and pipework to go to the roof.

Ventilation

The original outside air solution is via holes through the façade at low level to the back of the perimeter fancoils. This method would no longer be efficient or compliant. A new ventilation plant is required to serve the restaurant and hospitality areas. This will provide better quality of air from the roof rather than from ground floor level.

Environmental/Heating and cooling options considered.

- Installing new 4 pipe fan coils onto the existing LTHW and CHW circuits.
This was discounted for contamination and performances reasons and a total clean and continual clean of the system would be prohibitively expensive and hard to achieve.

Commentary

The discussion with the technical staff reported problems and issues with the CHW and LTHW system contamination. This of course will prevent the fan coil terminals from working properly as the control valves will clog up. Unless a very rigorously controlled cleansing and back flushing of the whole system was undertaken prior to connecting any new systems, it would not be advisable to install new pipework and fancoils directly onto these systems in the same manner. That said the depth of these fancoils would preclude Architectural improvement in the void height dimensions being achieved. The smallest depth fancoil available is manufacture by Mitsubishi Electric as a VRF slimline FCU at 200mm deep.

- Installing new 4 pipe fan coils onto the existing LTHW and CHW circuits but with hydraulic separation via a plate heat exchanger.

This would protect the new pipework and fancoils from cross contamination but there would be a circa 3oC temperature loss across the HX and thus larger fancoils would be required.

- A New VRF heat pump and fancoil system (s) that will provide simultaneous heating and cooling utilising slimline (by Mitsubishi) chassis type fancoils in the ceiling void.

This type of system readily allows for standalone phasing without phase interference and downtime.


The plant space is available at roof level and by utiling the space replacement of the previous chiller, no planning is impacted.

It is a more efficient controllable system.

This would make spare capacity available on the existing CHW and LTHW systems.

Slimline fancoils should allow the Architectural requirement of smaller ceiling voids to be achieved – see drawing section.

3.0 Overlay Plans to show proposed plant and riser locations



OPTION PLANT SPACE CONSIDERED BUT LOW HEADROOM AND ACCESS NON COMPLIANT

CLIMATIZADOR
TECHVEL THF 3/3-B
A) REJILLA DE 1200 x 300 (EXISTENTE)
B) REJILLA DE 800 x 600 (EXISTENTE)

BATHROOM AIR EXHAUST (BASEMENT)
AIR EXHAUST FAN TD-1000/250 VL
FLOW RATE 1000 m³/h
FROM 200 m²

B) REJILLA DE 800 x 600 (EXISTENTE)
FLOW RATE 1000 m³/h

- PHASE 1 - Zone C
- Bar and Restaurant
- PHASE 2 - Zone C
- Terrace
- PHASE 3 - Zone B
- New Meeting Rooms

PLANT AREA CONSIDERED HERE BUT THE SPACE FOR AHU & VRF WAS TOO SMALL @ APPROX 3m LONG x 1.7m WIDE x 2.0m HIGH INCLUDING ACCESS + CLEARANCE


- OUTSIDE AIR INTAKE LOUVER**
- TOUR LAS REJILLAS DE 800 x 600 mm DE 1000 m³/h
- CL-1
CL-2
CL-3
CL-4
CL-5
CL-6
- BATHROOM/MEETING ROOM AIR EXHAUST**
- TOUR LAS REJILLAS DE 800 x 600 mm DE 1000 m³/h
- CL-1
CL-2
CL-3
CL-4
CL-5
CL-6
- STORE OFFICE AND BUFFET AIR EXHAUST**
- TOUR LAS REJILLAS DE 800 x 600 mm DE 1000 m³/h
- CL-1
CL-2
CL-3
CL-4
CL-5
CL-6

PROPOSED DUCTWORK & PIPEWORK RISER FROM HIGH LEVEL GROUND TO ROOF

PHASE 3


PHASE 1

PHASE 2




- 2 FAN-COIL FL-200-T (4 PT)
- 3 FAN-COIL FL-300-T (4 PT)
- 4 FAN-COIL FL-450-T (4 PT)
- 6 FAN-COIL FL-650-T (4 PT)

- 2 FAN-COIL FL-200 (3+1)
- 3 FAN-COIL FL-300 (3+1)
- 4 FAN-COIL FL-450 (3+1)
- 6 FAN-COIL FL-650 (3+1)




DETALLE EXTRACCION BAÑOS (APART. ALA -A-)
esc. 1/20



DETALLE EXTRACCION COCINA (APART. ALA -A-)
esc. 1/20

DETALLE DE LOS EXTRACTOS EN LAS ZONAS DE BARRIO Y TOILETAS
AT THE APARTMENT WINGS (FLOORS 3, 4, 5, 6 and 7)

HOTEL MELIA WHITE HOUSE		PROYECTO	MEJORAS DE
MELIA WHITE HOUSE HOTEL - LONDON		FECHA	15/05/2018
PLANTA SEPTIMA		CLIENTE	MELIA
CLIMATIZACION		PROYECTISTA	FRANKLINA
7th FLOOR		FECHA	15/05/2018
		ESCALA	1:100
		PROYECTO	24667p17



PUMPS ROOM

RTAA-217 SQ
RATED 0.000 kw

RTAA-217 SQ
RATED 0.000 kw

EUWAB-120
RATED 0.000 kw

AHU

SERVICES ROUTE
TO RISER

PROPOSAL IS TO REUSE
THE 'OLD' CHILLER
PLANT SPACE +
STEELWORK BASE

- BARRERA DE SEGURIDAD
- PLATAFORMA PARA C/E DE LAS ENFRIADORAS
- ESCALA PASO DE TUBERIAS

ROOF

HOTEL MELIA WHITE HOUSE		PROYECTO	FECHA
MELIA WHITE HOUSE HOTEL - LONDON		ESTADO	13.01.21
PLANTA CUBIERTAS 8th FLOOR		ESCALA	1:100
		FECHA DE EMISIÓN	13.01.21
		HOJA	13
		24667cub	



4.0 Fire Alarm System

ICS visited site several times and their correspondence and options proposed are in the Appendices section.

Summary

There is spare capacity on loops 2,3 and 4 serving the proposed phased areas.

It is possible to continue to support the existing system albeit they advise that the existing equipment/ system is now obsolete and the detectors and panel will only be supported by Siemens until 2017/18. They advise that this is not to say that it cannot continue to be supported but to do so will require a software upgrade; (only by Siemens); and they have some spares going forward in the immediate future. Please note their advice that the newer Siemens smaller detector heads will not be backward compatible with the existing system.

So to Answer Miguel's question; now is a good time to consider and begin to implement a new fire alarm system and a strategy needs to be agreed.

ICS propose 2 options:-

Continue to use the existing system and panel, but piggy back (a new panel) and migrate a gradual upgrade with a new switch; ie with planned replacement for the new works but thereafter planned phased replacement to the rest of the hotel over a period of time to suit budget years with either:-

- 1) A new switch by Siemens (closed protocol).
- or
- 2) A new different manufacturer open protocol switch.

This will need to be discussed in more detail and the Way Forward agreed.

5.0 Recommendations

5.1 Proposed

- New VRF heat pumps providing simultaneous heating and cooling to be located at roof level (see drawings) utilising slimline Fan Coil Units.
- New Eco ventilation plant with Heat recovery to be located at roof level
- Reuse the existing steelwork at roof level to locate the plant
- Riser interconnection as shown on the drawings as discussed on site with Miguel using the “sacrificial” store.

5.2 The Way Forward

It is suggested a quick meeting is held with Miguel and Gary to review to :-

- Obtain feedback from the client team on the ideas and agree the proposed environmental and Ventilation Strategies to be adopted.
- Agree the Fire Alarm strategy to be implemented.
- Engage a structural engineer to detail the works required to the proposed riser and connection through to the roof plant area.
- Undertake a power availability evaluation review when the LV schematic is made available.

6.0 Appendices

- 6.1 Survey photos
- 6.2 Fire Alarm correspondence from ICS.

7.0 Survey Photos



IMG001 EXISTING STEELWORK; PREVIOUS CHILLER



IMG002 NEW CHILLER; SPARE PLANT SPACE




IMG003 VIEW OF CHILLERS + ADJACENT PLANT SPACE



IMG004 PIPEWORK + VIEW ACROSS ROOF



IMG005 EXISTING AHU PLANTROOM – NO SPARE SPACE



IMG006 EXISTING AHU PLANTROOM – REDUCED HEADROOM




IMG007 OUTSIDE AIR LOUVRES TO RESTAURANT PERIMETER FAN COILS



IMG008 POTENTIAL PLANT SPACE BEHIND SCREEN




IMG009 POTENTIAL PLANT SPACE (AS DISCUSSED ON SITE)



IMG010 DOOR TO LONG STORAGE 'SACRIFICIAL' FOR NEW PROPOSED RISER LOCATION



IMG011 SERVICES AT BACK OF PROPOSED RISER CUPBOARD



IMG012 GROUND FLOOR VIEW OF RISER (ABOVE) LOCATION



IMG013 REDUCED HEADROOM IN ALBUFERA RESTAURANT



IMG014 REVIEW OF LINES OF SIGHT FROM STREET PERIMETER FOR 'CORNER' OPTION

Mike Harvey

From: Martin Taylor <MartinTaylor@icservice.uk.com>
Sent: 23 March 2017 10:12
To: Mike Harvey
Subject: FW: Re: Fire Alarm System - Melia Whitehouse
Attachments: MHA Melia White House Report.pdf

Hi Mike,

Further to the report attached, please find below the two options regarding the fire alarm system both short term and long term.

Option 1. Gradual Upgrade of existing Siemens System

The manufacturers recommendation is introduce a new panel, introducing new technology, to accommodate the areas being refurbished an link to network to existing system.
Change out all existing panels with relevant new technology, but supporting the devices installed at present with a gradual upgrade on a loop by loop basis.
Initially this would be detection devices to allow a smooth transition, with manual call points and interfaces following on.
As the detection on each loop is upgraded loop card would be changed to suit.
Please note any upgrade whatsoever requires to be done on a loop by loop basis.

Option 2. Gradual Change of System to "open protocol"

The procedure would be as above but would require new panels to piggyback with existing. **IC is at present carrying out this procedure at 55 King William Street.**
The only difference in how the works would be instigated would be that the interfaces and call points on each loop would require changing on the loop by loop basis.

On both options a full set of as installed drawings and the disc containing all device information and the Cause & Effects would be required.
A full survey could then be carried out to verify the information submitted and a programme could then be offered.

IC Service & Maintenance would be pleased to offer their services for one or all of the following:

- Project Management
- System Verification
- Install of new system (either option)

Should the client remain with the Siemen product the operational design responsibility would be with Siemens, regardless of the appointed fire alarm contractor.
With the installation of a new "open protocol" system the design responsibility would be with the fire alar contractor and for this purpose we would recommend an LPS1014 approved company.

These works can be carried out with minimum disruption and downtime and we would be happy to meet with you to go through the procedures to avoid any problems.

Kind regards

Martin Taylor
Managing Director
IC Service & Maintenance Ltd
T. 01634 290300
F. 01634 290700
www.icservice.uk.com



Head Office UK: I.C. Service & Maintenance Ltd. Unit K3, Temple Court, Knights Park, Knight Road, Strood, Kent, ME2 2LT
Ireland Office: I.C. Service & Maintenance Ltd. Unit G6, Centrepoint Business Park, Oak Road, Dublin 12, D12 X5K5 Tel: 00353 14500804

The information contained in this message is confidential and may be legally privileged. The message is intended solely for the addressee(s). If you are not the intended recipient, you are hereby notified that any use, dissemination or reproduction is strictly prohibited and may be unlawful. If you are not the intended recipient please contact the sender by email and destroy all copies of the original message.

 Please consider the environment before printing this email.

From: Martin Taylor
Sent: 10 March 2017 11:25
To: 'mike.harvey@mhassociates.co.uk' <mike.harvey@mhassociates.co.uk>
Subject: Re: Fire Alarm System - Melia Whitehouse

Hi Mike,

Please find attached our findings on the above.

Regards

Martin Taylor
Managing Director
IC Service & Maintenance Ltd
T. 01634 290300
F. 01634 290700
www.icservice.uk.com



Head Office UK: I.C. Service & Maintenance Ltd. Unit K3, Temple Court, Knights Park, Knight Road, Strood, Kent, ME2 2LT
Ireland Office: I.C. Service & Maintenance Ltd. Unit G6, Centrepoint Business Park, Oak Road, Dublin 12, D12 X5K5 Tel: 00353 14500804

The information contained in this message is confidential and may be legally privileged. The message is intended solely for the addressee(s). If you are not the intended recipient, you are hereby notified that any use, dissemination or reproduction is strictly prohibited and may be unlawful. If you are not the intended recipient please contact the sender by email and destroy all copies of the original message.

 Please consider the environment before printing this email.



Ref No. MRT/Melia
Please use this number on all correspondence
Date: 10th March 2017

MHA
Attention Mike Harvey

Dear Mike,

Re: Fire Alarm System – Melia Whitehouse Hotel

Further to our site visit and the subsequent visit by our engineer, please find below our observations.

Our brief was to assess the loop loadings on the ground floor for potential expansion to accommodate fit out works in these areas. As per our report issued 3rd March there is spare capacity on loops 2,3 and 4.

The existing system was installed pre 2001 and the equipment is now obsolete, the detectors and panel will only be supported until 2017/2018.

This is not to say it cannot be supported, or devices added to the existing system, but will probably require a “software upgrade”, as there is no evidence of an upgrade on site. As there are no software discs on site, devices cannot be added to the system without these.

This upgrade can only be carried out by Siemens, as can any device additions or changes to “cause & effects”. In essence at present the system installed is “closed protocol” with all changes under the control of Siemens.

We are sure the System installed has afforded your client many years of protection and comfort, but time marches on.

Our recommendation would be to support the existing system while replacing with “open protocol” on a gradual basis.

This will give the client much more control of his system, allowing the opportunity to go to the open market for maintenance support, which will obviously ensure a quality service at a competitive price.

Should MHA require our support or assistance with regards to a full system survey or any other matters relating to the system, please do not hesitate to contact us.

Subject: Melia White House Hotel



Head Office UK: IC Service & Maintenance Ltd. Unit K3, Temple Court, Knights Park, Knight Road, Strood, Kent, ME2 2LT
Tel: 0044 1634 290300 Fax: 0044 1634 290700 Email: sales@icservice.uk.com Web: www.icservice.uk.com
Company Registration No. 3112378
Ireland Office: IC Service & Maintenance Ltd. Unit G6, Centrepoint Business Park, Oak Road, Dublin 12, D12 X5K5
Tel: 00353 14500804 Fax: 00353 14500804 Email: service@icservices.ie

Hi Lulu,

Further to my earlier site visit, please see below confirmation of current fire alarm detection line loadings on the Ground Floor.

Martin advised me that there is a project on the Ground Floor (Restaurant extension?) and he wanted to know if the Siemens panel had the capacity to add more devices.

The two detection circuits covering the Ground Floor both have spare capacity. There is also a spare detection circuit that could be used if the quantity of devices required exceeds the availability on lines 1 & 2.

Melia White House Hotel			
Detection Line No.	Area	Line Loading	Spare Capacity
2	Not Used	0	128
3	Ground Floor	111	17
4	Ground Floor	105	23

Please note the following important points:

1. As explained, the Siemens system is closed-protocol and therefore requires Siemens to modify any programming. It is not possible for others to carry out the modifications due to licensed software.
2. The site programming disk is missing, therefore Siemens would need to rely on having the latest files backed up on their servers. As I understand Siemens have not had any involvement with the site for a number of years, the backup files they have may not be accurate.
3. Siemens AlgoRex A+ detection devices are no longer available, but there is a base adapter and compatible device that could be used.

IC are comfortable supporting the system from a maintenance point of view, however the modifications identified can only be completed by Siemens. Therefore if this project was to commence we'd suggest you deal direct with Siemens.


Please do not hesitate to contact me if you require any further information.

Regards,

Martin

 Please consider the environment before printing this e-mail

Yours faithfully,



Martin Taylor
IC SERVICE & MAINTENANCE LTD.



Regards

Lulu Steer

IC Service & Maintenance Ltd

T. 01634 290300

F. 01634 290700

www.icservice.uk.com



Head Office UK: I.C. Service & Maintenance Ltd. Unit K3, Temple Court, Knights Park, Knight Road, Strood, Kent, ME2 2LT
Ireland Office: I.C. Service & Maintenance Ltd. Unit G6, Centrepoint Business Park, Oak Road, Dublin 12, D12 X5K5 Tel: 00353 14500804

The information contained in this message is confidential and may be legally privileged. The message is intended solely for the addressee(s). If you are not the intended recipient, you are hereby notified that any use, dissemination or reproduction is strictly prohibited and may be unlawful. If you are not the intended recipient please contact the sender by email and destroy all copies of the original message.

Please consider the environment before printing this email.

From: Ian Smith

Sent: 02 March 2017 13:53

To: Lulu <Lulusteer@icservice.uk.com>

Subject: Melia White House Hotel

Hi Lulu,

Further to my earlier site visit, please see below confirmation of current fire alarm detection line loadings on the Ground Floor.

Martin advised me that there is a project on the Ground Floor (Restaurant extension?) and he wanted to know if the Siemens panel had the capacity to add more devices.

The two detection circuits covering the Ground Floor both have spare capacity. There is also a spare detection circuit that could be used if the quantity of devices required exceeds the availability on lines 1 & 2.

Melia White House Hotel			
Detection Line No.	Area	Line Loading	Spare Capacity
2	Not Used	0	128
3	Ground Floor	111	17
4	Ground Floor	105	23

Please note the following important points:

1. As explained, the Siemens system is closed-protocol and therefore requires Siemens to modify any programming. It is not possible for others to carry out the modifications due to licensed software.
2. The site programming disk is missing, therefore Siemens would need to rely on having the latest files backed up on their servers. As I understand Siemens have not had any involvement with the site for a number of years, the backup files they have may not be accurate.
3. Siemens AlgoRex A+ detection devices are no longer available, but there is a base adapter and compatible device that could be used.

IC are comfortable supporting the system from a maintenance point of view, however the modifications identified can only be completed by Siemens. Therefore if this project was to commence we'd suggest you deal direct with Siemens.

Please do not hesitate to contact me if you require any further information.

Regards,

Martin

 Please consider the environment before printing this e-mail

This email and any files transmitted with it are confidential and contain privileged or copyright information. You must not present this message to another party without gaining permission from the sender. If you are not the intended recipient you must not copy, distribute or use this email or the information contained in it for any purpose other than to notify us. If you have received this message in error, please notify the sender immediately, and delete this email from your system. We do not guarantee that this material is free from viruses or any other defects although due care has been taken to minimise the risk. We accept no liability for any loss or damage suffered by any person arising from use of this e-mail. Any views expressed in this message are those of the individual sender, except where the sender specifically states them to be the views of BTE Systems Ltd.

**Produced by MHA Associates
Level 3
1-5 Clerkenwell Road
London
EC1M 5PA**