

## Gentet, Matthias

---

**From:** BCTAdmin@thameswater.co.uk  
**Sent:** 01 June 2017 11:49  
**To:** Planning  
**Subject:** 3rd Party Planning Application - 2017/2666/P

London Borough of Camden  
Camden Town Hall  
Argyle Street  
Euston Road  
London  
WC1H 8EQ

Our DTS Ref: 41178  
Your Ref: 2017/2666/P

1 June 2017

Dear Sir/Madam

Re: 101 , CAMLEY STREET, LONDON, N1C 4PF

### Waste Comments

Thames Water have reviewed the documentation provided and agree to discharge Condition 12 (surface water drainage).

### Water Comments

Thames Water have reviewed the documentation provided and cannot agree to the discharging of Condition 19 (Piling Method Statement) Supplementary Comments

Please submit a single piling layout plan clearly indicating the locations of all piles across the development site that are to be installed and indicate the minimum horizontal separation between the proposed piles and all Thames Water assets in separate detailed drawings. This plan should also show the positions of the piles in relation to Thames Water assets and local topography such as roads, waterways (please include road names), existing buildings and/or any other notable features. Do not include other assets in the area on the plan drawings. Please ensure that all drawings have a scale bar.

If any basements are intended to be constructed as part of the development, please clearly indicate the location and footprint and produce separate details with cross sectional views showing depths and location in relation to our assets.

Without a drawing showing the clearances between the face of the piles/ other type of foundations and confirmed location of the Thames Water assets the condition cannot be discharged.

The developer is also requested to confirm whether they have been in touch with Thames Water to discuss or arrange for the abandonment of the existing sewer beneath the development site. Please give a short summary of any correspondence to date. If the developer has had any correspondence with the Thames Water Build Over or Diversions teams relating to the assets below their site, please forward details of this correspondence to us also.

Please see the guidance document 'Working Near Our Assets' available at the following link for more details on Thames Water policy with regards to piling, demolition, excavation and abnormal

loading: (available online at <https://developers.thameswater.co.uk/developing-a-large-site/planning-your-development/working-near-or-diverting-our-pipes> ).

Plans of Thames Water apparatus can be obtained through our website at [www.thameswater-propertysearches.co.uk](http://www.thameswater-propertysearches.co.uk). Please contact Developer Services if you wish to discuss further (by email at [developer.services@thameswater.co.uk](mailto:developer.services@thameswater.co.uk) & [DSCLX2039@thameswater.co.uk](mailto:DSCLX2039@thameswater.co.uk) ). Please use the following reference in all future correspondence: DTS 41178.

Yours faithfully  
Development Planning Department

Development Planning,  
Thames Water,  
Maple Lodge STW,  
Denham Way,  
Rickmansworth,  
WD3 9SQ  
Tel:020 3577 9998  
Email: [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk)

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk)

Did you know you can manage your account online? Pay a bill, set up a Direct Debit, change your details or even register a change of address at the click of a button, 24 hours a day. Please visit [www.thameswater.co.uk](http://www.thameswater.co.uk).

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales each with their registered office at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and intended solely for the use of the individual to whom it is addressed. Any views or opinions presented are solely those of the author and do not necessarily represent those of Thames Water Limited or its subsidiaries. If you are not the intended recipient of this email you may not copy, use, forward or disclose its contents to any other person; please notify our Computer Service Desk on +44 (0) 203 577 8888 and destroy and delete the message and any attachments from your system.

We provide the essential service that's at the heart of daily life.