

BEDFORD HOUSE, 21A JOHN STREET, LONDON

PROVISIONAL PLANT NOISE ASSESSMENT

Report 15392.PPCR.01 Rev.A

For:

Benesco Charity Ltd

8/10 Hallam Street

London

W1W 6NS

Site Address	Report Date	Revision History
Bedford House, 21A John Street, London	26/01/2017	Rev.A – 16/02/2017

CONTENTS

1.0 INTRODUCTION 2

2.0 ENVIRONMENTAL NOISE SURVEY AND EQUIPMENT 2

2.1 Procedure 2

2.2 Equipment 2

3.0 RESULTS 3

4.0 NOISE CRITERIA 3

5.0 DISCUSSION 4

6.0 CONCLUSION 4

List of Attachments

15392.SP1	Indicative Site Plan
15392.TH1-3	Environmental Noise Time History
Appendix A	Glossary of Acoustic Terminology

1.0 INTRODUCTION

KP Acoustics Ltd, Britannia House, 11 Glenthorne Road, London, W6 0LH, has been commissioned by Benesco Charity Ltd, 8/10 Hallam Street, London, W1W 6NS, to undertake an environmental noise survey at Bedford House, 21A John Street, London. The background noise levels measured will be used to determine daytime and night-time noise emission criteria for the proposed plant unit installation.

This report presents the overall methodology and results from the environmental survey followed by calculations to demonstrate the feasibility of the plant unit installation to satisfy the emissions criterion at the closest noise-sensitive receiver and outline mitigation measures as appropriate.

2.0 ENVIRONMENTAL NOISE SURVEY AND EQUIPMENT

2.1 Procedure

Automated noise monitoring was undertaken at the position shown in Site Plan 15392.SP1. The choice of this position was based on security, accessibility and on collecting representative noise data in relation to the nearest noise sensitive receiver relative to the operations on site. Continuous automated monitoring was undertaken for the duration of the survey between 05/01/17 and 06/01/17.

Initial inspection of the site revealed that the background noise profile at the monitoring location was largely dominated by road traffic noise from the surrounding roads.

The weather during the course of the survey was generally dry with wind speeds within acceptable tolerances and therefore suitable for the measurement of environmental noise. The measurement procedure complied with ISO 1996-2:2007 Acoustics "*Description, measurement and assessment of environmental noise - Part 2: Determination of environmental noise levels*".

2.2 Equipment

The equipment calibration was verified before and after the survey and no calibration irregularities were observed.

The equipment used was as follows.

- 2 No. Svantek Type 958 Class 1 Sound Level Meter
- 1 No. Svantek Type 948 Class 1 Sound Level Meter
- B&K Type 4231 Class 1 Calibrator

3.0 RESULTS

The results from the continuous noise monitoring are shown as a time history of L_{Aeq} , L_{Amax} , L_{A10} and L_{A90} averaged over 5 minute sample periods in Figure 15392.TH2.

Minimum background noise levels are shown in Table 3.1.

Minimum background noise level	
$L_{A90: 5min}$ dB(A)	
Daytime (07:00-23:00)	45
Night-time (23:00-07:00)	45

Table 3.1: Minimum measured background noise levels

4.0 NOISE CRITERIA

The criterion of The London Borough of Camden for noise emissions of new plant in this instance is as follows:

“The Council considers that for new developments involving noisy plant/equipment or other uses, design measures should be taken to ensure that noise levels predicted at a point 1 metre external to sensitive facades are at least 5dB(A) less than the existing background measurement (L_{A90}) when the equipment is in operation. Where it is anticipated that equipment will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses in the noise (bangs, clicks, clatters, thumps), special attention should be given to reducing the noise levels from plant and equipment at any sensitive facade to at least 10dB(A) below the L_{A90} level.”

We therefore propose to set the noise criteria as shown in Table 4.1 in order to comply with the above requirement.

	Daytime (07:00 to 23:00)	Night-time (23:00 to 07:00)
Noise criterion at nearest residential receiver (10dB below minimum L_{A90})	35	35

Table 4.1: Proposed Noise Emissions Criteria

5.0 DISCUSSION

Based on the measured minimum background noise levels in the area, the maximum overall noise emissions criteria of the proposed plant units is 35 dB(A) at the nearest noise sensitive receiver.

It is considered that it would possible to achieve this noise emissions criterion, however the addition of some mitigation measures, such as an acoustic enclosure, or acoustic screening may be necessary.

Currently, the exact details of the proposed plant installation are unknown. Once all M&E proposals have been finalised, calculations will be undertaken to confirm compliance to the criterion set in Table 4.1.

6.0 CONCLUSION

An environmental noise impact survey has been undertaken at Bedford House, 21A King Street, London, by KP Acoustics Ltd between 05/01/2017 and 06/01/2017. The results of the survey have enabled criteria to be set for noise emissions from proposed plant.


A maximum noise emissions criterion for the proposed plant unit installation has been set based on the requirement of demonstrating inaudibility of the plant at the nearest noise sensitive receiver. Further calculations will be undertaken once all M&E proposals are finalised in order to confirm compliance.

Report by:

Duncan Arkley AMIOA
KP Acoustics Ltd.

Checked by:

Kyriakos Papanagiotou MIOA
KP Acoustics Ltd.



Title:

Indicative site plan showing noise monitoring positions

Ref: Google Maps

Date: 27 January 2017

FIGURE 15392.SP1



Bedford House, 21A John Street, London
Environmental Noise Time History
5th January to 6th January 2017




Figure 15392.TH1.Front

Bedford House, 21A John Street, London
Environmental Noise Time History
5th January to 6th January 2017




Figure 15392.TH2.Central Facades

Bedford House, 21A John Street, London
Environmental Noise Time History
5th January to 6th January 2017




Figure 15392.TH3.Rear Facade

GENERAL ACOUSTIC TERMINOLOGY

Decibel scale - dB

In practice, when sound intensity or sound pressure is measured, a logarithmic scale is used in which the unit is the 'decibel', dB. This is derived from the human auditory system, where the dynamic range of human hearing is so large, in the order of 10^{13} units, that only a logarithmic scale is the sensible solution for displaying such a range.

Decibel scale, 'A' weighted - dB(A)

The human ear is less sensitive at frequency extremes, below 125Hz and above 16Khz. A sound level meter models the ears variable sensitivity to sound at different frequencies. This is achieved by building a filter into the Sound Level Meter with a similar frequency response to that of the ear, an A-weighted filter where the unit is dB(A).

L_{eq}

The sound from noise sources often fluctuates widely during a given period of time. An average value can be measured, the equivalent sound pressure level L_{eq} . The L_{eq} is the equivalent sound level which would deliver the same sound energy as the actual fluctuating sound measured in the same time period.

L_{10}

This is the level exceeded for no more than 10% of the time. This parameter is often used as a "not to exceed" criterion for noise.

L_{90}

This is the level exceeded for no more than 90% of the time. This parameter is often used as a descriptor of "background noise" for environmental impact studies.

L_{max}

This is the maximum sound pressure level that has been measured over a period.

Octave Bands

In order to completely determine the composition of a sound it is necessary to determine the sound level at each frequency individually. Usually, values are stated in octave bands. The audible frequency region is divided into 11 such octave bands whose centre frequencies are defined in accordance with international standards. These centre frequencies are: 16, 31.5, 63, 125, 250, 500, 1000, 2000, 4000, 8000 and 16000 Hertz.

Environmental noise terms are defined in BS7445, *Description and Measurement of Environmental Noise*.

APPLIED ACOUSTIC TERMINOLOGY

Addition of noise from several sources

Noise from different sound sources combines to produce a sound level higher than that from any individual source. Two equally intense sound sources operating together produce a sound level which is 3dB higher than a single source and 4 sources produce a 6dB higher sound level.

Attenuation by distance

Sound which propagates from a point source in free air attenuates by 6dB for each doubling of distance from the noise source. Sound energy from line sources (e.g. stream of cars) drops off by 3dB for each doubling of distance.

Subjective impression of noise

Hearing perception is highly individualised. Sensitivity to noise also depends on frequency content, time of occurrence, duration of sound and psychological factors such as emotion and expectations. The following table is a guide to explain increases or decreases in sound levels for many scenarios.

Change in sound level (dB)	Change in perceived loudness
1	Imperceptible
3	Just barely perceptible
6	Clearly noticeable
10	About twice as loud

Transmission path(s)

The transmission path is the path the sound takes from the source to the receiver. Where multiple paths exist in parallel, the reduction in each path should be calculated and summed at the receiving point. Outdoor barriers can block transmission paths, for example traffic noise. The effectiveness of barriers is dependent on factors such as its distance from the noise source and the receiver, its height and construction.

Ground-borne vibration

In addition to airborne noise levels caused by transportation, construction, and industrial sources there is also the generation of ground-borne vibration to consider. This can lead to structure-borne noise, perceptible vibration, or in rare cases, building damage.

Sound insulation - Absorption within porous materials

Upon encountering a porous material, sound energy is absorbed. Porous materials which are intended to absorb sound are known as absorbents, and usually absorb 50 to 90% of the energy and are frequency dependent. Some are designed to absorb low frequencies, some for high frequencies and more exotic designs being able to absorb very wide ranges of frequencies. The energy is converted into both mechanical movement and heat within the material; both the stiffness and mass of panels affect the sound insulation performance.