

Mark,

Thanks for showing me the details of the proposed building.

Whilst Bauder are keen to promote green roofs where ever possible it look highly unlikely that the roof on this building will receive adequate light and air movement to make the sedum viable.

Holly is particularly dense and unless the tree were removed or substantially reduced in height then I would not consider sedum to be a viable roof finish.

Regards

Chris Roddick

Green Roof Product Manager

Bauder Limited

United Kingdom

70 Landseer Road, Ipswich, Suffolk, IP3 0DH

Ireland

O'Duffy Centre, Cross lane, Carrickmacross, Co.Monaghan.