

<b>Application No:</b>	<b>Consultees Name:</b>	<b>Consultees Addr:</b>	<b>Received:</b>	<b>Comment:</b>	<b>Response:</b>
2017/2902/P	james beggs	10 Little Green Street NW5 1BL NW5 1BL	30/06/2017 07:09:13	AMEND	major re-roofing works at this scale require a fully comprehensive survey and analysis of existing roof conditions, materials and finished levels, followed by a cost/benefit analysis and a construction method statement including the care and re-use of existing finishes. Reference should be made to English Heritage document Energy Efficient and Historic Buildings: Insulating Roofs at Rafter Level. The complete and detailed proposals should be set out in a construction method statement, reviewed by LBC Conservation officer and by the Conservation Dept of English Heritage. The risks to programme, cost, performance and impact of any change to finished levels are great and the proposals must be vigorously examined and approved prior to work commencing.

---