



PROPOSED TEF/VF
2No. ANTENNAS
FIXED TO WALL

EXISTING WALL
MOUNTED KIT

PROPOSED VF 1No.
RRU & 2No. ERS
FIXED TO WALL

EXISTING SKYLIGHT

EXISTING ENTRANCE
TO BUILDING AT
GROUND LEVEL

EXISTING STRUCTURAL
PART WALLS BELOW

PROPOSED METER CABINET
ON CONCRETE BASE

+13.00m

GROUND LEVEL
+00.00m

MAIN ROOF LEVEL
+9.00m

EXISTING EARTH TAPE

PROPOSED TEF ELTEK AND 2No.
FPF AND VF CSC ON NEW STEEL
GRILLAGE. (ELTEK TO HOUSE
PROPOSED TEF COMMS)

PROPOSED AC
DISTRIBUTION BOARD FIXED
TO HANDRAILING

PROPOSED 1100 HIGH
FREESTANDING HANDRAIL

PROPOSED 300 WIDE CABLE
TRAY ON RUBBER BLOCKS

PROPOSED 300
WIDE CABLE TRAY

PROPOSED TEF/VF
4No. ANTENNAS
FIXED TO CHIMNEY

PROPOSED VF
4No. ERS &
2No. RRU's
FIXED TO WALL

EXISTING ROOF
ACCESS HATCH TO
BE UPGRADED TO
BILCOSTYLE HATCH

PROPOSED SUBMAIN TO BE
INSTALLED ON NEW 75mm
WIDE TRAY ACROSS ROOF,
CLIPPED EXTERNALLY DOWN
WALL TO GROUND LEVEL
THEN WITHIN DUCTS TO
METER CABINET. REFER TO
DRG. 100 FOR METER
CABINET LOCATION

PROPOSED SITE PLAN

(1:250)

10000 5000 0 5000 10000 15000 20000 25000

ORIGINAL SCALE AT A3 - 1:250

ALL DIMENSIONS IN MILLIMETRES

ALL DIMENSIONS ARE IN mm UNLESS NOTED OTHERWISE

N.G.R E: 526540 N: 185505

CONCESSION REQUIRED YES

NOTES:

CHERRY PICKER CONCESSION REQUIRED.

NO EDGE PROTECTION AROUND ROOFTOP
EXTENTS.

VARIOUS FLUES AROUND ROOFTOP - TRIP
HAZARDS.

F	Cherry picker Location & Note Amended	MS	LB	16.06.17
E	Sub-main cable route clarified	BB	LB	27.01.17
D	Issued for Construction	BB	LB	27.01.17
C	Site Re-Designed (No ERS & RRU Rocks)	DB	JS	28.10.16
B	Client Redline Comments	DW	LB	08.07.16
A	Issued for Approval	DW	LB	03.07.16

REV	MODIFICATION	BY	CH	DATE
-----	--------------	----	----	------

GallifordTry
WOLVEY - HINCKLEY - LEICESTERSHIRE - LE10 3JF
Tel: +44 (0)1455 222792 Fax: +44 (0)1455 222758

O₂
CTIL

Cell Name Opt.

HENDERSON COURT -

Cell ID No

CTIL	TEF	VF
148399	072473	86104

Site Address / Contact Details

HENDERSON COURT
102 FITZJOHNS AVENUE
LONDON
NW3 6NR

Drawing Title: PROPOSED SITE PLAN

Purpose of Issue: CONSTRUCTION

Drawing Number: 201

101

Surveyed By: CT Original Sheet Size: A3 Issue: F

Drawn: DW Date: 03.07.16 Checked: CT Date: 03.07.16

The drawings comply with CTIL Beacon Standard ICNIRP guidelines.
Designed in accordance with CTIL Beacon documents: SDN0008 & SDN0009 'ICNIRP Compliance Summary'