

From: Rebekka Andrinudottir

Sent: 16 June 2017 16:17

To: Young, Tony

Subject: RE: Advertisement application - 2017/3354/A - 52 Gray's Inn Road

Hi Tony,

Thank you for your email and apologies for my delayed reply, I was awaiting contractor confirmation.

1. There has been some error in the input at the point of application as this was the illumination colour. I have now confirmed that the signage luminance levels are as follows:

Projecting sign – 200cd/m

Fascia sign – 200 cd/m

Menu case – 100 cd/m

2. Yes confirmed. The projecting sign will have a warm white halo illumination (see attached reference image). The Fascia sign will only have a soft light wash across the back cut through section of the timber (the logo), not to any other part of the timber fascia.

We have already submitted a pavement license application for the proposed table and chairs.

Thank you for support and please do not hesitate to contact me if you require any further information.

Kind Regards

Rebekka Andrinudottir

Designer

WINNERS 2017

FAB Awards

Casual Dining Awards

WINNERS 2016

Hotelympia

Retail Week Interior Awards

designlsm.com | [facebook](#) | [twitter](#) | [linkedin](#) | [instagram](#)

93 Islingword Road, Brighton, East Sussex, United Kingdom, BN2 9SJ

DesignLSM Chartered Architects is a division of DesignLSM and a RIBA accredited practice | ISO 9001 registered | [view privacy disclaimer](#)