

2017/3175/P	8 Makepeace Avenue	Replacement of uPvc French doors and side glazed panels at rear ground floor elevation with aluminium folding, sliding doors within enlarged opening and blocking-up of existing clerestory window to ground floor east elevation.	Tony Young
<p><b>No Objection</b></p> <p><b>Comment</b></p> <p>There are minor inconsistencies between the drawings, the Application Form &amp; the description on the website;</p> <ul style="list-style-type: none"> <li>• The drawings state that the existing side windows (from the room off the kitchen to the raised terrace) are being replaced with white powder coated aluminium sliding folding doors, however no elevation is supplied to fully understand the change nor is reference made to this in the Application Form.</li> <li>• The Application Form (section 11) refers to new French Doors whereas the drawings refer to folding sliding doors.</li> </ul> <p>M Narraway HLE CAAC</p>			

---

**Conservation Area Advisory Committee**

Advisory Committee	Holly Lodge
Application ref	2017/3175/P
Address	8 Makepeace Avenue LONDON N6 6EJ
Planning Officer	Tony Young
Comments by	20 Jul 2017
Proposal	Replacement of uPvc French doors and side glazed panels at rear ground floor elevation with aluminium folding, sliding doors within enlarged opening and blocking-up of existing clerestory window to ground floor east elevation.
No Objection	Yes
Comment	Yes
Observations	See attached

**Documents attached**

No details entered

**Documents attached**

[2017-3175-P, CAAC Comments](#)

**About this form**

Issued by Contact Camden  
5 Pancras Square  
London N1C 4AG

Form reference 21002961

**Data Protection**

No personal information you have given us will be passed on to third parties for commercial purposes. The Council's policy is that all information will be shared among officers and other agencies where the legal framework allows it, if this will help to improve the service you receive and to develop other services. If you do not wish certain information about you to be exchanged within the Council, you can

**Data Protection**

request that this does not happen.