



Cables/pipes to 3rd floor internal unit to enter through roof at this location

Cables/pipes to 1st and 2nd floor units to enter through roof at this location

3No. External heat pump units PUMY-P140VKM2 or similar. Mounted on roof through anti-vibration fixings.

Cables/pipes to 3rd floor internal unit to enter through roof at this location

NOTES:

DO NOT SCALE FROM DRAWING.

ALL DIMENSIONS TO BE CONFIRMED ON SITE.

LOCATION PLAN @ 1:1250

D	Heat-pump units moved 150mm away from party wall. Fixing to roof only specified.	19-07-17
C	Heat-pump unit location changed	14-06-17
B	A/C cable/pipe riser added. Internal unit locations changed.	24-04-17
A	Heat-pump unit location changed	28-03-17

DRAWING TITLE

**ROOF
as Proposed**

ADDRESS

**29 Museum Street
WC1A 1LH**

PROJECT NAME	DATE
Installation of Roof Plant + Internal Alterations	Jan 2017
SCALE	
	1:50 @ A3
CLIENT	DRAWING NO.
Alhambra Hotel Ltd	23544- P04D

Fresson & Tee
CHARTERED SURVEYORS

1 SANDWICH STREET
LONDON WC1H 9PF

Tel: (020) 7391 7100 Fax: (020) 7391 7121