

Gentet, Matthias

From: BCTAdmin@thameswater.co.uk
Sent: 04 August 2017 15:58
To: Planning
Subject: 3rd Party Planning Application - 2017/0963/P - Further info

London Borough of Camden
Camden Town Hall
Argyle Street
Euston Road
London
WC1H 8EQ

Our DTS Ref: 33649
Your Ref: 2017/0963/P - Further info

4 August 2017

Dear Sir/Madam

Re: LAND AND GARAGES ADJACENT 42, FALKLAND ROAD, LONDON, NW5 2PX

Waste Comments

Thames Water have reviewed the documentation provided and cannot agree to the discharging of Condition 8.

Water Comments

Supplementary Comments

The supplied documentation consists of a letter from T.A Tompson LLP dated 02/04/2017 and referenced TAT/16091. The letter refers to surface water attenuation as per an attached drawing. This document is not available as part of the Planning documentation for us to consider and has therefore not been taken into account. Please supply the required evidence to the Planning Authority to demonstrate the net reduction in surface water flows proposed by the redevelopment.

Yours faithfully
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ
Tel:020 3577 9998
Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to

devcon.team@thameswater.co.uk