



NEW 800X500 FIRE RATED DUCT TO CONNECT TO EXISTING CARPARK DUCT AND DROP TO LL ROUTING TO CARPARK EXTRACT FANS

NEW COMMON 2700X1200X2000H FIRE RATED PLENUM, CONNECTING TO NEW 2700X2000 LOUVER TO ATMOSPHERE. EXISTING CARPARK EXTRACT FIRE RATE DUCTS TO BE MODIFIED AND CONNECT INTO PLENUM AT HIGH AND LOW LEVEL.

NEW 700X500 KITCHEN EXTRACT DUCT CONNECT IN TO NEW PLENUM AT HIGH LEVEL WITH FIRE DAMPER AND ATTENUATOR

1300X600 DUCT CONNECTING TO NEW KITCHEN EXTRACT UNIT. 700X500 KITCHEN EXTRACT DUCT RISE TO HL ROUTING TO EXTRACT PLENUM AND LOUVER

NEW KITCHEN EXTRACT AIR HANDLING UNIT INCLUDING BAG FILTER, CARBON FILTER AND EXTRACT FAN

700X600 FIRE RATED KITCHEN EXTRACT DUCT FROM RISER ABOVE. CONTRACTOR TO ALLOW FOR MODIFICATION OF EXISTING SERVICES WITHIN VENTILATION PLANT AND STORE ROOM

700X500 KITCHEN EXTRACT DUCT DROP TO CONNECT TO 1300X700 DUCT CONNECTING TO NEW KITCHEN EXTRACT UNIT

NEW 800X500 FIRE RATED DUCT TO CONNECT TO EXISTING CARPARK DUCT AND ROUTE AT HL TO CARPARK EXTRACT FANS

**Legend:**

- Existing
- Proposed

**General Arrangement Notes:**

- 1 New windows throughout
- 2 New extended entry
- 3 New glazed atrium roof
- 4 New M&E equipment

Rev.	Date	Details	By

Client: Warner Bros.

Project name: Project Phoenix

Drawing title: Proposed Basement

Status: Planning Application

Scale: 1:100@A1, 1:200@A3	Drawn by: CF
Date: Aug 2017	Checked by: RL
Drawing number: 1539-P-112-Pr. Basement	Revision: -

